



CrossMark
click for updates

Cite this: *Lab Chip*, 2016, 16, 1197

Enhanced versatility of fluid control in centrifugal microfluidic platforms using two degrees of freedom†

Xiaobao Cao, A. J. deMello and K. S. Elvira*

Centrifugal microfluidic platforms have significant potential in commercial applications because of their operational flexibility and minimal external infrastructure requirements. However, the dynamic and real-time control of fluid flow within traditional centrifugal microfluidic platforms is problematic. To address this significant limitation, we propose a two degrees of freedom platform, in which a digital servo is located at each end of an arm driven by a motor. This allows for reversible inward pumping between multiple chambers with perfect efficiency. Furthermore, the addition of a second degree of freedom allows position-based pressure controlled burst valves to be accessed and operated in an independent fashion. To demonstrate the efficacy of this technical innovation, we show rapid and configurable flow switching between three target chambers within a centrifugal microfluidic device.

Received 14th December 2015,
Accepted 18th February 2016

DOI: 10.1039/c5lc01530h

www.rsc.org/loc

Introduction

Centrifugal microfluidic platforms integrate fluidic control units into “CD-like” disks and manipulate fluids using the centrifugal force created by device rotation.¹ Such platforms have significant potential in chemical and biological experimentation since they simplify the ‘world-to-chip’ interface and are low cost with respect to both the device and the associated control architecture.^{2–6} Unsurprisingly, centrifugal microfluidics has been applied to a range of analytical processes including enzyme-linked immunosorbent assays,⁷ DNA extraction,⁸ DNA amplification⁹ and single cell analysis.¹⁰ However, centrifugal microfluidic platforms lack flexibility in fluid control when compared to other microfluidic technologies, since traditional (one degree of freedom, *i.e.* using only one motor) centrifugal platforms can only pump fluid radially outwards from the centre of the device, thus limiting the number and variety of fluidic operations that can be performed in an integrated manner, and/or necessitating the use of complex on-chip components to perform simple operations.^{1,11,12}

In recent years, much effort has been focused on increasing the variety of fluidic operations possible within

centrifugal microfluidic platforms. For example, to move fluid radially inwards, three main methods are typically used. In the first, air is compressed within a closed cavity on the outer edge of the device by centrifugal force.^{13,14} When the device stops rotating, the pressure in the cavity pumps the liquid radially inwards. However, there are problems associated with such a method, including the lack of control over liquid motion and the difficulty in adding additional steps to the process (due to the fact that radial motion automatically occurs once the device stops rotating). The second approach uses additional components to apply the pressure needed to drive the fluid radially inward, such as compressed air from an external gas source² or an integrated air chamber heated by infrared radiation.^{14–16} Finally, the use of an additional (and immiscible) liquid can be used to move the analyte radially inwards.¹⁷ However, all the above methods do not allow liquid to be pumped amongst multiple chambers located at different distances from the device centre. In other words, process reversibility is limited due to the need to “re-charge” the chambers used for inward pumping, or the requirement for additional off-chip components to function. These features severely limit the use of contemporary platforms outside research laboratory environments.

The limitations associated with directional pumping also compromise precise control over on-chip components, such as valves. Valves are critical components in centrifugal microfluidic platforms since they enable operations such as metering, mixing and dosing. A variety of valves, including burst valves (hydrophobic valves⁷ and capillary valves^{18,19}), wax valves²⁰ and siphon valves²¹ have all been used to good effect in centrifugal formats. Burst valves are the most

Department of Chemistry and Applied Biosciences, Institute of Chemical and Bioengineering, ETH Zürich, 8093 Zürich, Switzerland.

E-mail: katherine.elvira@chem.ethz.ch

† Electronic supplementary information (ESI) available: Video S1 – inward pumping, Video S2 – independent burst valves (design 1), Video S3 – independent burst valves (design 2), and Video S4 – flow switching. CAD files of designs for two types of independent burst valves, inward pumping and flow switching modules. See DOI: 10.1039/c5lc01530h



commonly used due to their simple structure (a narrow channel with a sudden expansion^{22,23} or a hydrophobic patch²⁴) and because they contain no movable parts. DNA hybridization,²⁵ nucleic acid analysis,²⁶ and enzymatic assays¹⁸ have all been realized based on the use of burst valves in centrifugal microfluidic platforms. Another type of valve was developed by Kawai *et al.*, where a manually adjusted valve (a rotational reagent cartridge) was used for fluidic control and dosing in centrifugal microfluidic platforms.²⁷ However, the requirement for manual operation limits the automation of the analytical process.

In traditional centrifugal microfluidic platforms, once a certain rotational speed is reached all valves whose threshold pressure is below the pressure generated by the centrifugal force will open. This means that burst valves cannot be operated independently without *a priori* variation of threshold pressures in the design process. This severely limits the versatility of the platform, with each application requiring a bespoke valve layout.

A final and important area where fluid control affects the applicability of the device is flow switching. Flow switching is used to direct liquid from one chamber to a given target chamber. Previous studies^{28,29} have shown the use of the Coriolis force to drive the liquid in this manner, but unacceptably high rotational speeds are normally required to generate Coriolis forces able to drive the liquid. Flow switching can also be achieved through the use of an external pressure source;³⁰ however, such an approach is affected by the previously highlighted problems, and to date has only been able to switch flows between two target chambers.

Based on the aforementioned limitations to the centrifugal format, we herein describe a novel two degrees of freedom (2-DoF) centrifugal microfluidic platform, which allows complex fluidic control in a direct manner and requires no external components. Since the addition of a second degree of freedom is facile and significantly enhances fluidic control, we expect that the approach will extend the use of centrifugal microfluidic technologies to more complex multi-step chemical and biological applications. In our platform, two microfluidic devices are installed on two digital servos and mounted on each side of a rotating arm driven by a motor. By adjusting the position of the digital servos, the centrifugal force applied on the liquid and the direction of its motion can be controlled (Fig. 1). We demonstrate the versatility of this platform by showing how the addition of a second degree of freedom allows the unconstrained and reversible pumping of liquid in both radial directions, the independent opening of burst valves relying on the chip position (rather than the architectural design or rotational speed) and the on-demand switching of flow between several different target chambers. During the preparation of this manuscript we noticed that Miao *et al.* and Geissler *et al.* have recently shown platforms where a turn table and a stepper motor were used to change the position of the centrifugal microfluidic device to allow localized heating³¹ and to accomplish basic inward pumping, respectively.³² However, in this work we show the full

potential and versatility of 2-DoF centrifugal microfluidic platforms to achieve complex fluid control, demonstrate for the first time their use to access independent burst valves and achieve targeted flow switching, and provide design rules to allow simple designs for challenging fluidic actions to be adapted to suit different applications.

Experimental methods

Two degrees of freedom centrifugal microfluidic platform

To create a 2-DoF centrifugal microfluidic platform (Fig. 1), two devices are installed on two digital servos (MX-12A, ROBOTIS, South Korea), which are fixed at the two ends of an arm driven by a motor (ASD-A2, Delta Electronics, Taiwan). Power supply and communication to the digital servos are realized through a custom designed slip-ring (Moflon Technology Shenzhen, China) fixed on the shaft of the motor. The motor rotates the arm to generate centrifugal force, and the digital servos change the rotational (not translational) position of each device relative to the centre of rotation of the motor. At each end of the arm, a small bar is used to trigger an optical sensor (FS-V11P, Kencycle Enterprise, China).




Fig. 1 Photograph of the two degrees of freedom centrifugal microfluidic platform showing the two microfluidic devices installed on each end of the arm that is rotated by the motor. The devices are installed on top of digital servos to provide precise control over the chip position relative to the centre of rotation. The scale bar is 1 cm. a) and b) Schematics of how the use of a digital servo affects the direction of flow in the centrifugal microfluidic platform. a) The digital servo aligns the position of the chip such that the force acting on the liquid (blue) in the chamber drives it radially outwards upon spinning the motor. b) The digital servo adjusts the position of the chip such that the force acting on the liquid (blue) in the chamber causes it to be pumped radially inwards upon spinning the motor. The direction of liquid flow (and of the force acting on the liquid) is shown by red arrows. Curved arrows show the direction of rotation of both the digital servo and the motor.



When the bar passes through the field of view of the sensor, a pulse signal triggers a high-speed camera (Dalsa HM1400, Stemmer Imaging, Switzerland). This requires that the motor rotates the arm at 200 rpm throughout the experiment to allow imaging. This spin speed does not cause liquid transport in our designs. Lighting is provided by an adjustable high-intensity fiber-coupled illuminator (OSL2, Thorlabs, Germany). An in-house control program was written using LabVIEW 2014, with position and speed commands to the motor and digital servo being sent through an RS-232 interface. It is important to note that the electromagnetic field from the motor interferes with the communication to the digital servo when the baud rate is set excessively high (such as $20\,000\text{ s}^{-1}$). Here the baud rate is set to 8000 s^{-1} .

Chip fabrication

For inward pumping and flow switching experiments, centrifugal microfluidic devices were made of PMMA (polymethylmethacrylate) and structured using a CNC milling machine (Optimum, Stadelmann Maschinen AG, Switzerland). This allowed the direct fabrication of channels with cross sectional dimensions of $500 \times 500\ \mu\text{m}$. The diameter and depth of the chambers used in all experiments were 4 mm and 1.5 mm, respectively. PMMA devices are covered with transparent tape (Scotch, 3M, Switzerland) to provide fluidic integrity and ensure that the devices could be reused after cleaning.¹³ For the experiments involving the assessment of independent burst valves, microfluidic devices were made of polydimethylsiloxane (PDMS) using standard soft lithographic techniques.³³ This allowed the facile creation of structures with feature sizes as small as $30\ \mu\text{m}$. AutoCAD (Autodesk, 2016) files of the designs used for burst valves and 3D models (step format) for inward pumping and flow switching are provided in the ESI.†

Results and discussion

Inward pumping

The basic design required to achieve inward pumping between different chambers in the 2-DoF centrifugal microfluidic platform involves aligning the channel exiting the chamber containing the liquid to be pumped with the centre of the motor. Such a design, fabricated using PMMA, is shown in Fig. 2, where five densely packed chambers are connected in series, with alternate chambers being located at the edge and centre of the microfluidic device respectively.

Air vents are only required on the chambers at the start and end of a chain, with each chamber being connected to its neighbours by a channel containing two segments. The channel design depends on whether the chamber is at the end or in the middle of the chain. For chambers between the initial and final chambers, the angle, β , between the two channels connected to a given chamber is designed to be at least 90° , so as to avoid driving the fluid into the opposite channel (channel segments m and n in Fig. 2, for example). The angle between channel segments m and t (which connect




Fig. 2 Scale drawing of a design used to pump fluid radially inwards and outwards between a set of 5 chambers within a 2-DoF centrifugal microfluidic platform. Uppercase letters denote chambers and lower-case letters denote channel segments highlighted by dashed boxes. Air vents are included in the initial and final chambers (A and E), and all other chambers are connected by two channels. The angle, β , between the two channels connected to the same chamber was designed to be 90° , as shown for example in the case of channels n and m. The scale bar is 5 mm.

chamber A to chamber B) was also designed to be greater than 90° to avoid residual liquid collecting at the junction of the two channels.

The short channel segments exiting chambers A and E (the initial and final chambers) are designed so that the fluid cannot be “accidentally” pumped out of the air vents. To ensure this feature, a line drawn from channel segment p, the exit channel of chamber A, for example, should be co-linear with the motor, as should the entrance channel for the next chamber, in this case channel segment m leading to chamber B. This means that lines extending from segments p and m must intersect at a point on a circle with a radius corresponding to the distance between the centres of the digital servo and the motor. Accordingly, when the fluid is pumped from chamber B to chamber A (or from chamber D to chamber E), it will not be driven out through the air vents.

The two steps required to pump liquid between chambers (radially inwards and radially outwards) are *aligning* and *spinning*. First, the device is positioned using the digital servo so that the short channel at the exit of the chamber initially holding the fluid is collinear with the centre of the motor. Then, the device is rotated (using the motor) to cause liquid transfer into the target chamber. This process is shown in detail in Fig. 3 and in Video S1 in the ESI.† It is important to note that although five chambers are used in the current example, there is no limit on the number of chambers that can be used as long as the design parameters described above are obeyed. It is interesting to note that previous studies only pump fluids between a maximum of 3 chambers. For example, Salin *et al.* managed to pump liquid radially inwards and outwards using an external gas cylinder between multiple chambers but in an irreversible fashion.²

Since pumping between chambers requires two operations with device rotation occurring in both, the optimum spin






Fig. 3 Schematics (top) and images (middle) showing radial inward and outward pumping in a 2-DoF centrifugal microfluidic platform. In each schematic, a curved arrow shows the direction of rotation of the motor and a straight arrow shows the direction of liquid flow due to the alignment of the channel exiting the liquid-containing chamber with the motor. In c), e) and g), an additional curved arrow shows the direction of rotation of the digital servo. There are two key steps involved in the pumping process: *aligning* and *spinning*. a) Original position of the device with the fluid to be pumped injected into chamber A. The short channel that exits chamber A is collinear (aligned) with the motor to ensure that b) upon spinning the device at 1300 rpm the fluid from chamber A is pumped into chamber B. c) To pump the fluid from chamber B to chamber C, the digital servo spins the device at 200 rpm to align the short channel that exits chamber B in the direction of chamber C so that it is collinear with the motor and hence d) upon spinning the centrifugal microfluidic device at 1300 rpm the fluid is pumped from chamber B to chamber C. The steps shown in c) and d) are repeated in e) and f) and in g) and h) to pump the fluid from chamber C to chamber D and then to chamber E respectively. Chambers A and E have air vents. The scale bars are 1 cm. The graph (bottom) shows the motor spin speeds (black line) and digital servo angular positions (blue line) required to achieve inward pumping. Time points a to h on the x-axis refer to images a) to h) above. Low spin speeds of the motor (200 rpm) are required when the digital servo is being adjusted to the desired position for the next fluidic action to ensure that no fluid is pumped between steps. High spin speeds (over 1300 rpm) are required to pump the fluid into target chambers. The angle to which the digital servo is set to ensure that the correct channel is aligned to the motor is shown for each step (blue line). It is important to note that spin speeds depend on a variety of properties such as liquid viscosity, liquid density, surface tension, device surface characteristics and channel geometry.

speeds for each step were determined to ensure full control over the fluid position and to avoid unwanted leakage. As shown in Fig. 3, a rotational speed of 1300 rpm ensures that the fluid is driven into the target chamber. During adjustment of the chip position, the spin speed of the motor is decreased until the centrifugal force is insufficient to drive the fluid from the chamber (200 rpm in these experiments to allow continuous imaging of the chip) and during alignment the digital servo spins at 200 rpm. Video S1 in the ESI† shows the process of inward and outward pumping from the initial (A) to the final (E) chamber and back. The data presented herein shows controllable, reproducible and reversible pumping between 5 chambers, both radially inwards and radially outwards using a 2-DoF centrifugal microfluidic platform. In all cases, the liquid is transferred efficiently between the chambers.

Independent burst valves

The second degree of freedom added to a centrifugal microfluidic platform by the addition of a digital servo can also be used to access identical burst valves independently. To demonstrate this feature, three identical burst valves were placed on a circular path in a centrifugal microfluidic device fabricated using PDMS, separated by the same angle, θ (Fig. 4). Using a uniform rotational speed of the motor, the burst valve that is co-linear with the centre of the motor experiences the highest pressure and hence bursts open, whilst all other (identical) valves in the microfluidic platform remain closed. Accordingly, using the digital servo to adjust the position of the chip allows each valve to be opened independently when the applied pressure is larger than the threshold value for the valve.

The burst valves consist of a narrow channel with a height and width of 30 μm accessed by a rectangular expanding structure (see the inset in Fig. 4). The pressure, P , applied to the fluid held in this rectangular structure by the unopened valve is given by,

$$P = \rho\omega^2[R + r + 2L \cos(\theta)](R - r)/2 \quad (1)$$

where ρ is the density of liquid, ω is the spin speed, R is the distance from the start of the valve to the centre of the digital servo (in this case 15 mm), r is the distance from the liquid surface in the injection chamber to the centre of the digital servo (in this case 5 mm), L is the distance between the centre of the digital servo and that of the motor (in this case 36.5 mm) and θ is the angle between the channel and the line between the centres of the motor and the digital servo (in this case 30°).

Eqn (1) shows that the pressure decreases with the value of θ , and therefore when θ is 0 the pressure reaches its highest value. This means that when the channel leading to a burst valve is co-linear with the centre of the motor, that burst valve is subjected to the highest pressure upon rotation. Hence, to independently operate the identical burst






Fig. 4 Schematic of the chip design required to independently access identical burst valves using a 2-DoF centrifugal microfluidic platform (design 1). A, B and C denote the three independent burst valves in this chip, which are designed around the centre of the chip and separated by an angle, θ . The inner dashed circle denotes the level of the liquid filling the chamber leading to the burst valve that is collinear with the motor, in this case B, and has a radius r . Each burst valve is composed of a dosing chamber (filled with a blue liquid in the figure), a wide channel ($200\ \mu\text{m}$, as shown in the inset) and a narrow channel ($30\ \mu\text{m}$, as shown in the inset). The $30\ \mu\text{m}$ section of the valve has a length of $50\ \mu\text{m}$ (as shown in the inset). The outer dashed circle denotes the starting point of the $30\ \mu\text{m}$ section of the valve, and has a radius R . L denotes the distance between the centre of the motor and the centre of the digital servo (L is not shown to scale here). The height of all channels in the device is $30\ \mu\text{m}$. All chambers are equipped with air vents, which in the dosing chambers double as inlets. All target chambers are equipped with a dividing wall to allow the liquid to fill the chamber efficiently. The scale bar is $5\ \text{mm}$.




Fig. 5 Schematics (top) and images (bottom) showing independent burst valves (design 1) in a 2-DoF centrifugal microfluidic platform. In each schematic, a curved arrow shows the direction of rotation of the motor, and in c) and e) an additional curved arrow shows the direction of rotation of the digital servo. Overall, there are two steps required to open a specified burst valve: aligning and spinning. a) Original position of the device where valve B is co-linear with the motor and is hence the valve targeted to be opened. b) The 2-DoF centrifugal microfluidic platform is spun at $850\ \text{rpm}$ and burst valve B opens to allow fluid flow. c) The digital servo spins the chip at $20\ \text{rpm}$ such that valve C is co-linear with the motor but liquid flow is not caused and hence d) when spinning the motor at $850\ \text{rpm}$ valve C opens. e) and f) Show the same steps used to open valve A. The scale bars are $1\ \text{cm}$.

valves, in a fashion analogous to the steps required for inward pumping described above, two steps are required. First, the digital servo is used to align the target valve such that it is co-linear with the motor, and then the motor rotates the chip until the valve is opened (Fig. 5 and Video S2 in the ESI†).

The opening pressure threshold of the burst valves with the same dimensions lies over a range of values (P_{\min} to P_{\max}). When valve B, for example, is collinear with the centre of the motor, the pressure in valve B should be higher the highest threshold (P_{\max}) and the pressure in valves A and C should be lower than the lowest threshold (P_{\min}), as shown in eqn (2):

$$\begin{cases} P_{\max} < \rho\omega^2(R-r)(R+r+2L)/2 \\ P_{\min} > \rho\omega^2(R-r)[R+r+2L\cos(\theta)]/2 \end{cases} \quad (2)$$

Therefore the range of operational spin speeds can be defined as:

$$\sqrt{\frac{2P_{\max}}{\rho(R+r+2L)(R-r)}} < \omega < \sqrt{\frac{2P_{\min}}{\rho[R+r+2L\cos(\theta)](R-r)}} \quad (3)$$

In the current experiments, the threshold pressure of the burst valves is between 2797 and $3054\ \text{Pa}$, and according to eqn (3) the range of operational spin speeds is between 843 and $855\ \text{rpm}$. Accordingly, the spin speed was set to $850\ \text{rpm}$.

The minimum angle between adjacent burst valves for design 1, $\theta_{1,\min}$, determines the density of valves that can be integrated into a single device. From eqn (2) we find that:

$$\theta > \arccos\left\{\left[\frac{2P_{\min}}{(R-r)\rho\omega^2} - (R+r)\right]/2L\right\} \quad (4)$$



$$\begin{aligned}\theta_{1_min} &= \arccos \left\{ \left[\frac{2P_{\min}}{(R-r)\rho\omega_{\min}^2} - (R+r) \right] / 2L \right\} \\ &= \arccos \left\{ \left[\frac{P_{\min}}{P_{\max}} (R+r+2L) - (R+r) \right] / 2L \right\} \\ &= \arccos \left[\frac{P_{\min}}{P_{\max}} - \left(1 - \frac{P_{\min}}{P_{\max}} \right) \frac{r+R}{2L} \right] \\ &> \arccos(P_{\min}/P_{\max})\end{aligned}\quad (5)$$

Therefore, the highest density of identical burst valves that can be designed in a single centrifugal microfluidic platform and still be accessed independently can be predicted. In our experiments, θ_{1_min} is calculated as 26.25° , and we therefore designed θ to be 30° .

In the design shown in Fig. 5 (design 1), the working ranges of the spin speed and the valve density are both relatively narrow. An alternate design is shown in Fig. 6 (design 2), where the burst valves are designed such that they sit between the centres of the digital servo and the motor rather than on the edge of the chip as in design 1. The working principles are the same as in design 1, and hence the pressure applied on the valve is:

$$P = \rho\omega^2(R-r)[2L\cos(\theta) - R - r]/2 \quad (6)$$

This pressure also decreases with the angle, θ , which means that the burst valve is subjected to the highest pressure when the channel connected to the burst valve is co-linear with the centre of the motor. Hence, aligning the channel of the target valve to ensure that it is co-linear with the centre of the motor and application of the required motor spin speed enables independent operation of the burst valves as shown in Fig. 7 and Video S3 in the ESI.†

In a similar manner to design 1, the working range of spin speeds (eqn (7) and (8)) and the minimum angle between the valves (eqn (9) and (10)) can be calculated, *i.e.*

$$\begin{cases} P_{\max} < p\omega^2(R-r)(2L-R-r)/2 \\ P_{\min} > p\omega^2(R-r)[2L\cos(\theta) - R - r]/2 \end{cases} \quad (7)$$

$$\sqrt{\frac{2P_{\max}}{\rho(2L-R-r)(R-r)}} < \omega < \sqrt{\frac{2P_{\min}}{\rho[2L\cos(\theta) - R - r](R-r)}} \quad (8)$$

$$\theta > \arccos \left\{ \left[\frac{2P_{\min}}{(R-r)\rho\omega^2} + (R+r) \right] / 2L \right\} \quad (9)$$

$$\begin{aligned}\theta_{2_min} &= \arccos \left\{ \left[\frac{2P_{\min}}{(R-r)\rho\omega_{\min}^2} + (R+r) \right] / 2L \right\} \\ &= \arccos \left\{ \left[\frac{P_{\min}}{P_{\max}} (2L - R - r) + (R+r) \right] / 2L \right\} \\ &= \arccos \left[\frac{P_{\min}}{P_{\max}} + \left(1 - \frac{P_{\min}}{P_{\max}} \right) \frac{r+R}{2L} \right] \\ &< \arccos(P_{\min}/P_{\max})\end{aligned}\quad (10)$$




Fig. 6 Schematic of the chip design required to independently access identical burst valves using a 2-DoF centrifugal microfluidic platform (design 2). It is important to note that the collection chambers can be placed closer to the dosing chambers (shown filled with a blue liquid in the figure) if required. A, B and C denote the three identical independent burst valves in this chip, which are designed around the centre of the chip and separated by the same angle, θ . The outer dashed circle denotes the level of the liquid filling the chamber leading to the burst valve that is co-linear with the motor, in this case B, and has a radius R . Each burst valve is composed of a dosing chamber (filled with a blue liquid in the figure), a wide channel ($200\ \mu\text{m}$, as shown in the inset) and a narrow channel ($30\ \mu\text{m}$, as shown in the inset). The $30\ \mu\text{m}$ section of the valve has a length of $50\ \mu\text{m}$ (as shown in the inset). The inner dashed circle denotes the starting point of the $30\ \mu\text{m}$ section of the valve, and has a radius r . L denotes the distance between the centre of the motor and the centre of the digital servo. The height of all the channels in the device is $30\ \mu\text{m}$. All chambers are equipped with air vents. The scale bar is $5\ \text{mm}$.

In this design, the working range is increased to between $1512\ \text{rpm}$ and $1909\ \text{rpm}$, and θ_{2_min} (the minimum angle between adjacent burst valves for design 2) decreases to 13.2° , allowing more efficient packing of the burst valves in the centrifugal microfluidic platform.

This is calculated using eqn (3) and (8), so that we can calculate the ratio of maximum and minimum spin speeds for both designs:

$$\frac{\omega_{1_max}}{\omega_{1_min}} = \sqrt{\frac{2L+R+r}{2L\cos(\theta)+R+r}} = \sqrt{1 + \frac{2L[1-\cos(\theta)]}{2L\cos(\theta)+R+r}} \quad (11)$$






Fig. 7 Schematics (top) and images (bottom) showing independent burst valves in the 2-DoF centrifugal microfluidic platform (design 2). In each schematic, a curved arrow shows the direction of the motor, and in c) and e) an additional curved arrow shows the direction of rotation of the digital servo. Overall, there are two steps required to open a specified burst valve: aligning and spinning. a) Original position of the device with valve B aligned to be opened. The channel connecting valve B is collinear with the motor to ensure that only valve B is opened when the centrifugal microfluidic platform is spun. b) The 2-DoF centrifugal microfluidic platform is spun at 1700 rpm and burst valve B opens to allow fluid flow. These steps are repeated, as shown in c) and d) and in e) and f), to open valves A and C respectively. In all cases the alignment step takes place using the digital servo at 15 rpm. The scale bars are 1 cm.

$$\frac{\omega_{2_max}}{\omega_{2_min}} = \sqrt{\frac{2L - R - r}{2L \cos(\theta) - R - r}} = \sqrt{1 + \frac{2L[1 - \cos(\theta)]}{2L \cos(\theta) - R - r}} \quad (12)$$

From (eqn 11) and (12) it follows that

$$\frac{\omega_{2_max}}{\omega_{2_min}} > \frac{\omega_{1_max}}{\omega_{1_min}} \quad (13)$$

Thus in design 2, the working range of spin speeds is wider than that in design 1. From eqn (5) and (10), we can

show that design 2 can operate with a higher density of burst valves than design 1:

$$\theta_{2_min} < \arccos(P_{min}/P_{max}) < \theta_{1_min} \quad (14)$$

Flow switching

A final example of the enhanced control over the fluid position in 2-DoF centrifugal microfluidic platforms is flow switching. Here, flow switching means choosing the chamber into which fluid will be pumped from a given starting chamber. In the design shown in Fig. 8 there are three target chambers (B, C and D) on the outside edge of the device and one original chamber (A) near the centre of the chip. The steps required to achieve pumping of the fluid into the targeted chamber are again *aligning* and *spinning*. When channels m, n or t are co-linear with the motor the fluid will be pumped into chambers B, C and D respectively (as shown in Fig. 9). Compared with previously published work on traditional centrifugal microfluidic platforms,^{28–30} flow switching in a 2-DoF centrifugal microfluidic platform is performed at lower spin speeds and in a configurable manner.

The design parameters required for flow switching to work in this 2-DoF centrifugal microfluidic platform are simple. The angles between all the channels exiting the input chamber (chamber A) are set to 90°. These are shown as the angles between channels m and n, and between channels n and t in Fig. 8. There is an air vent in each of the target chambers (chambers B, C and D) with each designed to be parallel with




Fig. 8 Schematic of a design that uses a 2-DoF centrifugal microfluidic platform to achieve targeted flow switching. The flow switching device is designed to enable fluid to be pumped from an original chamber (A) to one of the target chambers (B, C or D) on demand. All target chambers are equipped with air vents. When channels m, n or t are collinear with the centre of the motor, the liquid will be pumped into chambers B, C and D respectively. The scale bar is 5 mm.






Fig. 9 Schematics (top) and images (middle) showing targeted flow switching in a PMMA 2-DoF centrifugal microfluidic platform. In each schematic, a curved arrow shows the direction of rotation of the motor, a straight dashed line shows the alignment of the channel exiting chamber A with the motor, and in c) and e) an additional curved arrow shows the direction of rotation of the digital servo. Pumping of fluid into the targeted chamber is a two step process. a) Firstly, the digital servo is used to align the channel exiting chamber A towards the target chamber to be collinear with the motor at 50 rpm to ensure that no fluid movement occurs; b) secondly, at high (1500 rpm) motor spin speeds, the liquid in chamber A is pumped into chamber C. c) To perform the same action with chamber B as the target chamber, more liquid is injected into chamber A and the exit channel from chamber A towards chamber B is aligned to be collinear to the motor using the digital servo operating at 50 rpm. d) At high motor spin speeds, the liquid is pumped from chamber A to chamber D. These steps are repeated in e) and f) to pump the liquid from chamber A to chamber B. The scale bars are 1 cm. The graph (bottom) shows the motor spin speeds (black line) and digital servo angular positions (blue line) required to achieve flow switching. Time points a to f on the x-axis refer to images a) to f) above. Low spin speeds (50 rpm) are required when the digital servo is being adjusted to the desired position for the next fluidic action to ensure that no fluid is pumped between steps. High spin speeds of the motor (over 1500 rpm) are required to pump fluid into the target chambers. The angle to which the digital servo is set to ensure that the correct channel is aligned to the motor is shown for each step (blue line). In contrast to previous examples, in this experiment the motor spin speed is set to 0 rpm between each step to allow a new liquid to be dosed into chamber A.

the channel that functions as the inlet to the target chamber, to ensure that no fluid exits through the air vents. At every junction between different segments of a single channel, the angles are designed to be larger than 90° to avoid residual fluid collecting at the junction of the two channels (such as the junction of channel segments p and q in Fig. 8). The targeted dosing of selected chambers from a common input chamber is shown in detail in Fig. 9 and in Video S4 in the ESI.†

Conclusions

Herein we have shown a novel centrifugal microfluidic platform with two degrees of freedom, instead of the single degree of freedom common in traditional centrifugal platforms. This additional degree of freedom allows fluidic operations that were previously deemed either excessively complex or inaccessible to be easily and reproducibly performed in a configurable manner. We demonstrate efficacy by performing three basic fluidic operations, namely controllable inward pumping, opening of independent burst valves and targeted flow switching. We demonstrate the ability to pump fluids efficiently in a fully reversible fashion between multiple chambers using no external equipment. The improved fluidic control enables burst valves to be operated independently from each other, even when they have an identical structure. Two designs for burst valves were tested to show the validity of the mathematical model used in the design process. This model allows the valve design to be adjusted such that the valve density and the range of spin speeds can be targeted towards a specific application. Finally, we show how the addition of a second degree of freedom allows flow switching between several target chambers. Since the addition of a second degree of freedom is simple, inexpensive, can be accomplished by minimal modifications to traditional centrifugal microfluidic platforms and provides significant advantages with regard to fluid control, we envision that 2-DoF centrifugal microfluidic platforms will become the norm for studies performed on centrifugal microfluidic platforms in the near future.

Notes and references

- 1 D. Mark, S. Haeberle, G. Roth, F. von Stetten and R. Zengerle, *Chem. Soc. Rev.*, 2010, **39**, 1153–1182.
- 2 M. C. R. Kong and E. D. Salin, *Anal. Chem.*, 2010, **82**, 8039–8041.
- 3 J. Steigert, M. Grumann, T. Brenner, L. Riegger, J. Harter, R. Zengerle and J. Ducree, *Lab Chip*, 2006, **6**, 1040–1044.
- 4 D. Mark, F. von Stetten and R. Zengerle, *Lab Chip*, 2012, **12**, 2464–2468.
- 5 S. Haeberle and R. Zengerle, *Lab Chip*, 2007, **7**, 1094–1110.
- 6 R. Gorkin, J. Park, J. Siegrist, M. Amasia, B. S. Lee, J. M. Park, J. Kim, H. Kim, M. Madou and Y. K. Cho, *Lab Chip*, 2010, **10**, 1758–1773.



- 7 N. Honda, U. Lindberg, P. Andersson, S. Hoffmann and H. Takei, *Clin. Chem.*, 2005, **51**, 1955–1961.
- 8 Y.-K. Cho, J.-G. Lee, J.-M. Park, B.-S. Lee, Y. Lee and C. Ko, *Lab Chip*, 2007, **7**, 565–573.
- 9 M. Focke, F. Stumpf, B. Faltin, P. Reith, D. Bamarni, S. Wadle, C. Müller, H. Reinecke, J. Schrenzel and P. Francois, *Lab Chip*, 2010, **10**, 2519–2526.
- 10 W. Espulgar, W. Aoki, T. Ikeuchi, D. Mita, M. Saito, J.-K. Lee and E. Tamiya, *Lab Chip*, 2015, **15**, 3572–3580.
- 11 R. Gorkin, J. Park, J. Siegrist, M. Amasia, B. S. Lee, J.-M. Park, J. Kim, H. Kim, M. Madou and Y.-K. Cho, *Lab Chip*, 2010, **10**, 1758–1773.
- 12 A. H. Ng, U. Uddayasankar and A. R. Wheeler, *Anal. Bioanal. Chem.*, 2010, **397**, 991–1007.
- 13 S. Zehnle, F. Schwemmer, G. Roth, F. von Stetten, R. Zengerle and N. Paust, *Lab Chip*, 2012, **12**, 5142–5145.
- 14 R. Gorkin, L. Clime, M. Madou and H. Kido, *Microfluid. Nanofluid.*, 2010, **9**, 541–549.
- 15 K. Abi-Samra, L. Clime, L. Kong, R. Gorkin, T. H. Kim, Y. K. Cho and M. Madou, *Microfluid. Nanofluid.*, 2011, **11**, 643–652.
- 16 T. H. G. Thio, F. Ibrahim, W. Al-Faqheri, J. Moebius, N. S. Khalid, N. Soin, M. K. B. A. Kahar and M. Madou, *Lab Chip*, 2013, **13**, 3199–3209.
- 17 S. Soroori, L. Kulinsky, H. Kido and M. Madou, *Microfluid. Nanofluid.*, 2013, **1**–13.
- 18 D. C. Duffy, H. L. Gillis, J. Lin, N. F. Sheppard and G. J. Kellogg, *Anal. Chem.*, 1999, **71**, 4669–4678.
- 19 M. J. Madou, L. J. Lee, S. Daunert, S. Lai and C.-H. Shih, *Biomed. Microdevices*, 2001, **3**, 245–254.
- 20 J.-M. Park, Y.-K. Cho, B.-S. Lee, J.-G. Lee and C. Ko, *Lab Chip*, 2007, **7**, 557–564.
- 21 J. Siegrist, R. Gorkin, L. Clime, E. Roy, R. Peytavi, H. Kido, M. Bergeron, T. Veres and M. Madou, *Microfluid. Nanofluid.*, 2010, **9**, 55–63.
- 22 J. Ducrée, S. Haeberle, S. Lutz, S. Pausch, F. Von Stetten and R. Zengerle, *J. Micromech. Microeng.*, 2007, **17**, 103–115.
- 23 H. Cho, H.-Y. Kim, J. Y. Kang and T. S. Kim, *J. Colloid Interface Sci.*, 2007, **306**, 379–385.
- 24 P. Andersson, G. Jesson, G. Kylberg, G. Ekstrand and G. Thorsén, *Anal. Chem.*, 2007, **79**, 4022–4030.
- 25 L. G. Puckett, E. Dikici, S. Lai, M. Madou, L. G. Bachas and S. Daunert, *Anal. Chem.*, 2004, **76**, 7263–7268.
- 26 S. Lutz, P. Weber, M. Focke, B. Faltin, J. Hoffmann, C. Müller, D. Mark, G. Roth, P. Munday and N. Armes, *Lab Chip*, 2010, **10**, 887–893.
- 27 T. Kawai, N. Naruishi, H. Nagai, Y. Tanaka, Y. Hagihara and Y. Yoshida, *Anal. Chem.*, 2013, **85**, 6587–6592.
- 28 T. Brenner, T. Glatzel, R. Zengerle and J. Ducrée, *Lab Chip*, 2005, **5**, 146–150.
- 29 J. Kim, H. Kido, R. H. Rangel and M. J. Madou, *Sens. Actuators, B*, 2008, **128**, 613–621.
- 30 M. C. Kong and E. D. Salin, *Anal. Chem.*, 2011, **83**, 1148–1151.
- 31 B. Miao, N. Peng, L. Li, Z. Li, F. Hu, Z. Zhang and C. Wang, *Sensors*, 2015, **15**, 27954–27968.
- 32 M. Geissler, L. Clime, X. D. Hoa, K. J. Morton, H. Hébert, L. Poncelet, M. Mounier, M. Deschênes, M. E. Gauthier and G. Huszczyński, *Anal. Chem.*, 2015, **87**, 10565–10572.
- 33 Y. Xia and G. M. Whitesides, *Annu. Rev. Mater. Sci.*, 1998, **28**, 153–184.

