Lab on a Chip

TUTORIAL REVIEW

Cite this: Lab Chip, 2022, 22, 859

Received 16th September 2021, Accepted 21st January 2022

DOI: 10.1039/d1lc00836f

rsc.li/loc

1. Introduction

Droplet microfluidic devices are used for the generation, manipulation, and analysis of discrete liquid droplets within a secondary immiscible liquid phase flowing through channels with dimensions preferentially below 500 μ m.^{1,2} Compared to standard single-phase flow, flowing a liquid as

^a Department of Chemistry, Faculty of Science, University of Victoria, BC, Canada b Living Systems Institute, College of Engineering, Physics and Mathematics,</sup> University of Exeter, Exeter, EX4 4QD, UK

^c Department of Mechanical and Industrial Engineering, Ryerson University, ON, Canada

 d Institute for Biomedical Engineering, Science, and Technology (iBEST)—a partnership between Ryerson University and St. Michael's Hospital, ON, Canada

^e Keenan Research Centre for Biomedical Science, St. Michael's Hospital, ON, Canada

Materials and methods for droplet microfluidic device fabrication

Katherine S. Elv[ira](http://orcid.org/0000-0001-6607-8191), ^D^a Fabrice Gielen, D^b Scott S. H. Tsai ^{D cde} and Adrian M. Nightingale ^{D *fg}

Since the first reports two decades ago, droplet-based systems have emerged as a compelling tool for microbiological and (bio)chemical science, with droplet flow providing multiple advantages over standard single-phase microfluidics such as removal of Taylor dispersion, enhanced mixing, isolation of droplet contents from surfaces, and the ability to contain and address individual cells or biomolecules. Typically, a droplet microfluidic device is designed to produce droplets with well-defined sizes and compositions that flow through the device without interacting with channel walls. Successful droplet flow is fundamentally dependent on the microfluidic device – not only its geometry but moreover how the channel surfaces interact with the fluids. Here we summarise the materials and fabrication techniques required to make microfluidic devices that deliver controlled uniform droplet flow, looking not just at physical fabrication methods, but moreover how to select and modify surfaces to yield the required surface/fluid interactions. We describe the various materials, surface modification techniques, and channel geometry approaches that can be used, and give examples of the decision process when determining which material or method to use by describing the design process for five different devices with applications ranging from fielddeployable chemical analysers to water-in-water droplet creation. Finally we consider how droplet microfluidic device fabrication is changing and will change in the future, and what challenges remain to be addressed in the field. TUTORIAL REVIEW Ward (Materials and methods for droplet microfluid change

Checkforupdates **Checkforon and the controlling controlling controlling and the controlling controlling to the term of the controlling set of the**

a sequence of sub-μL droplets has several practical advantages, such as the removal of Taylor dispersion, 3 the encapsulation of viscous or fouling species away from channel walls, $4,5$ and the segregation of single cells or molecules so that they can be assayed or analysed individually in high throughput.⁶ Because of these advantages droplet microfluidics is becoming increasingly important within the microfluidic field as a whole, as shown in the bibliographic record: while the total number of both microfluidic and droplet microfluidic publications have steadily increased over time, the proportion of microfluidic publications concerning droplets has significantly increased, with droplet microfluidics currently making up ∼15% of all microfluidic papers, up from ∼5% fifteen years ago (shown in more detail later). This reflects the increasing interest in droplet microfluidics and its importance within the microfluidics community.

Droplet flow is typically generated by bringing two immiscible liquids together at a microfluidic junction. Where the two flows meet, the balance of interfacial tension and shear forces (determined by flow rates, channel geometry, fluid composition and viscosity) causes the fluids to break $up⁷$ with the resulting droplet size and generation frequency determined by the fluid mechanics of the system.⁸ Which

 f Mechanical Engineering, Faculty of Engineering and Physical Sciences, University of Southampton, Southampton, SO17 1BJ, UK

 g Centre of Excellence for Continuous Digital Chemical Engineering Science, Faculty of Engineering and Physical Sciences, University of Southampton, Southampton, SO17 1BJ, UK. E-mail: a.nightingale@southampton.ac.uk

Tutorial review Lab on a Chip

Dr Fabrice Gielen is a Lecturer in Physics at the University of Exeter. He holds an MEng. degree in Electrical Engineering from Phelma (Grenoble, France), Politecnico di Torino (Turin, Italy) and EPFL (Lausanne, Switzerland), an MRes. in Protein and Membrane Chemical Biology and a PhD. in Chemistry both from Imperial College London. He conducted postdoctoral research at the University of Cambridge with

Dr Adrian Nightingale is a Lecturer in Microfluidics and Sensor Design in the Mechanical Engineering department at the University of Southampton. He received his undergraduate degree in chemistry from the University of Oxford and postgraduate masters degree and PhD from Imperial College London. He was awarded an Industrial Innovation Fellowship by the UK's Natural Environment Research Council in 2018. His

fluid becomes the "disperse" phase (droplets) and which the "continuous" or "carrier" phase (encapsulating the droplets) is chiefly determined by the relative affinity of each fluid for the channel wall; for example a hydrophobic fluid will preferentially wet a hydrophobic surface. Hence an oil/water fluid pair flowing within hydrophobic channels will flow as a succession of water droplets carried within the continuous oil phase. This is, however, dependent on the channels being uniformly hydrophobic over both space and time. If the surface changes over the length of the channel, or over time, then droplets will stick to the walls, causing a range of problems such as inter-droplet transfer of contents, increase Tuttorial review

Tuttorial becomes the "carrier published on 24 January 2022. The contribution of the common cont

in droplet polydispersity, and analyte adsorption to the channel walls.^{9,10} Consequently the surface properties of the channels, which determine how the fluids interact with the channel walls, are paramount to ensuring reliable droplet flow – not only during generation, but also through all subsequent operations such as merging, separation, storage, and analysis.

This review summarises how microfluidic devices can be fabricated to control those interactions and hence deliver reliable stable droplet flow. There are several comprehensive reviews that describe materials and fabrication techniques for microfluidic devices in general, $11-13$ focusing on the range

research on Twitter (@TheElviraLab).

Katherine Elvira The Elvira Lab develops microfluidic technologies to build bespoke artificial cells and tissues for drug discovery applications. In 2020, Dr Elvira was named a Michael Smith Foundation for Health Research Scholar in partnership with the Pacific Alzheimer Research Foundation. Find out more about her

Fabrice Gielen

Professor Hollfelder between 2011 and 2016. His laboratory, hosted at the Living Systems Institute at the University of Exeter, focusses on advancing droplet microfluidic platforms for single cell research, especially in the fields of drug screening and directed evolution.

Scott Tsai

Dr Scott Tsai is the Director of the Graduate Program in Biomedical Engineering and an Associate Professor at Ryerson University. His undergraduate training in Mechanical Engineering is from the University of Toronto, and his masters and PhD degrees in Engineering Sciences are from Harvard University. Dr Tsai's laboratory specializes in droplet and bubble microfluidics. His group collaborates with hospital

Dr Katherine Elvira received her undergraduate Master's degree and PhD from Imperial College London. She then moved to ETH Zürich for her postdoctoral work. Since 2017, Dr Elvira is a Canada Research Chair and an Assistant Professor in the Department of Chemistry at the University of Victoria, Canada.

researchers to implement these technologies in applications related to kidney disease and prostate cancer. Dr Tsai is a recipient of the United States' Fulbright Visiting Research Chair Award, the Government of Ontario's Early Researcher Award, and Ryerson University's Deans' Teaching Award.

Adrian Nightingale

research specialises in microfluidic-based chemical sensors and other chemical applications of microfluidic technology, working at the interface with medicine, chemistry, and environmental science.

of available materials, their properties, and how they can be physically micropatterned. They pay little attention, however, to the surface chemistry, fluid wetting and other considerations that are fundamental to the successful operation of a droplet microfluidic device. This review aims to address this gap in the literature by providing readers with a holistic guide to material choice and fabrication techniques for droplet microfluidic devices. Our focus will specifically be on channel-based microfluidic devices for flowing droplets rather than digital microfluidic (traditionally electrowettingon-dielectric) devices, or indeed devices for generating free droplets in gaseous environment (e.g. inkjet printing). Readers interested in these areas are directed to one of the many authoritative reviews.¹⁴⁻¹⁷

This review will be especially useful to those new to the field but may also be of use to established researchers considering materials they have not used before. It will cover what materials can be used to make droplet microfluidic devices, describe the range of ways that the surface/fluid interactions can be controlled by surface functionalisation or spatial control of fluids, and then provide concrete examples of the thought process used when choosing a material and fabrication method by discussing five examples from our own research groups. We end the review by highlighting areas where we consider innovations in materials and fabrication methods will significantly impact droplet microfluidics in the future.

2. Device materials and physical fabrication

To begin we will summarise what materials can be used to make microfluidic devices in general, and what techniques can be used to physically fabricate them (including patterning and bonding) before paying more attention in the next section to surface/fluid interactions and methods to chemically modify the device, a common part of the fabrication process for droplet microfluidic devices. Various fabrication methods are available $18-20$ (summarised in Table 1), with a general trade off between ease/cost of manufacture and the minimum attainable feature sizes. A range of different materials can be used for microfluidic devices, each with different properties and possible physical fabrication methods, as summarised in Table 2. These are described in detail in several good reviews $11-13$ hence here we will provide a brief summary of the most common material options within the three main classes of materials: inorganic materials (chiefly silicon or glass, but also including ceramics), elastomers, and thermoplastics.¹³

Inorganic materials have the advantage of broad solvent compatibility, mechanical rigidity and, for glass, exceptional optical clarity at ultraviolet/visible wavelengths. They are expensive and difficult to fabricate, however, with the manufacturing process difficult to scale up. Monolithic microfluidic devices (*i.e.* those made exclusively from a single material with no observable joins once fabricated) made from glass or silicon are typically patterned by a combination of photolithography and wet-etching techniques followed by hot pressing above the glass transition temperature. While this is an expensive and manually intensive fabrication method, glass devices can be washed and reused, which is highly useful if device geometries are already established. As a cheaper alternative, off-the-shelf components can also be used; for example glass capillaries are often used as microfluidic devices with their tips tapered to small diameters using capillary pullers.²¹ Cab on a Chip of evaliable materials, their properties, and have they can be the search of search and be available in the common co

Elastomers, such as the ubiquitous poly(dimethylsiloxane) (PDMS), are a low cost and easy-to-manufacture alternative to silicon and glass. These are typically patterned by moulding to masters created using other fabrication methods.²² While the techniques used to make the masters (most usually photolithography) can be time-consuming, the masters can be used repeatedly to mould many devices, with excellent reproducibility and sufficient scalability for academic requirements. Sealed channels are typically formed by covalent bonding of the patterned elastomer substrate to a glass surface via surface activation by a plasma. PDMS devices can also be reversibly sealed to another piece of PDMS, glass, or other

 a Feature size dependent on feature resolution on mould. b Does not include the time, cost, and effort for mould manufacture. c Feature size given for common commercially available systems (e.g. fused deposition modelling, stereolithographic addition printers). Much higher
resolutions are possible using more advanced systems (e.g. two-photon polymerisation^{34–3}

Table 2 A summary of common properties and fabrication methods for the three main classes of microfluidic device materials

substrates by simple contact between the surfaces, creating hybrid devices with hybrid surface properties, 23 though this necessitates the use of low fluid pressures and hence low flow rates.

Thermoplastics include polymethylmethacrylate (PMMA), polycarbonate (PC), polystyrene (PS), polyvinylchloride (PVC), and cyclic olefin co-polymer (COC) as well as most common fluoropolymers. $37-39$ They have the major advantage that they can be large-scale manufactured using injection moulding or hot embossing, however smaller scale manufacture is more difficult, relying on micromachining (i.e. micromilling and other mechanical fabrication methods) which involves costly machinery and tooling and moreover has much lower feature resolution (hundreds of microns) compared to most lithography methods. Bonding is typically achieved by either thermal bonding of the substrates or by using adhesive tapes. Various thermoplastics and elastomers can also be 3D printed, but typically at lower resolutions. While high end two photon polymerisation printers can give resolutions in the order of 100 nm, $34-36$ most commercially available printing methods (fused deposition modelling, stereolithographic addition) produce channels 100 μm or larger. 31

When considering how material choice impacts on droplet microfluidic devices in particular it is useful to examine what materials have been historically used. As previously mentioned, droplet microfluidics publications make up an increasing proportion of the microfluidics publications in general (Fig. 1a and b). If we look at the trends seen for several common

Fig. 1 Bibliographic analysis of droplet microfluidics publications recorded in Web of Science. a) Comparison of microfluidics (blue circles) and droplet microfluidics (red squares) publications by year since 1990. b) Graph showing that the proportion of droplet microfluidics papers compared to microfluidics papers has increased steadily over time. c) and d) Bar charts showing the number of publications by material for "microfluidic" and "droplet microfluidic" search terms respectively. e) Bar chart showing droplet microfluidics publications for selected materials as a proportion of total microfluidics publications. Error bars correspond to an absolute error of ± 10 publications for each bibliometric search. All searches were conducted via Web of Science on the 10th and 12th of March 2021 and looked at all possible search fields. Searches combined the following terms: 1) "droplet microfluidic" or "microfluidic", 2) "NOT electrowet*" to exclude digital microfluidic devices, and 3) for c)-e), a material. For fluorous materials, "Teflon" or "PTFE" or "PFA" or "FEP" or "fluoropolymer" were used as search terms. For 3D printed materials, "3d print" or "3d-print" or "3d printed" or "3d-printed" were used as search terms.

device materials (Fig. 1c–e), we see that PDMS is associated with the greatest number of publications for both microfluidics in general (Fig. 1c) and droplet microfluidics in particular (Fig. 1d), consistent with its ease of use for small volume manufacturing and suitability for academic research. Glass and silicon also score highly, in part because they have been used from the very beginning of the field of microfluidics. While material popularity shows the same overall trend for droplet microfluidics (Fig. 1d) and microfluidics in general (Fig. 1c), if we look at the droplet microfluidics results as a proportion of the corresponding microfluidics publications (Fig. 1e), there are a few materials that appear to be disproportionately favoured for droplet microfluidics. Most materials comprise 6–9% of the droplet publications, but there are outliers with fluoropolymer materials (13%) and, to a lesser extent, 3D printed materials (11%) being particularly favoured for droplet microfluidic devices. Fluoropolymers are known for their superhydrophobic surface properties which, as later discussed, means that the hydrophobic continuous phases typically used in droplet flow will easily wet the surfaces without need of any surface modification procedures. 3D printed materials also score slightly higher than other materials but this may not be due to any inherent advantage that makes them better suited to droplet microfluidics, but rather due to trends in research focus; the recent use of 3D printing for microfluidics (since 2012 – fourteen years later than the first PDMS and fluoropolymer reports for example) has coincided with the increasing emphasis on droplet microfluidics publications (Fig. 1b), meaning we would expect a higher baseline compared to longstanding materials with similar suitability for droplet flow. Lab on a Chip Coce materials (righ at c-1, we see that PDMS in a
specialization in or campating, to be another commonline, the material
specialization in the campating of the material on the campating state (right in the

While this bibliographic analysis should be treated as indicative, it shows how a wide range of materials have been used for droplet microfluidic devices, and that there is no "right" material for droplet-based devices with ease of fabrication, access to facilities, cost, as well as the application requirements themselves, playing significant roles in material choice. Nonetheless, the relatively disproportionate prevalence of fluoropolymers, illustrates how droplet flow places additional considerations on surface/fluid interactions and hence device material choices. In the next section we look in more detail at these interactions and how they can be controlled.

3. Ensuring channel surfaces are preferentially wetted by the continuous phase

The interactions between fluids and the channel surface are key to determining which fluid becomes the dispersed phase and which the continuous. With the small channel sizes in microfluidic devices, and the accompanying high surface area to volume ratios, the channel/fluid interface dominates fluid behaviour. There are several ways to control the surface/fluid interactions, either by choosing a material with the correct surface properties, modifying a surface (either permanently or temporarily), or by careful spatial control at the point of droplet generation. Here we will examine each in turn.

3a. Native material surfaces

The simplest way to control which fluid becomes the continuous phase is to make sure the device is fabricated from a material with similar chemical properties to the desired continuous phase, which will lead to that fluid preferentially wetting the channel surface. "Wetting" refers to the preference of a material to be in contact with one fluid rather than another. For instance, in a competition between an aqueous fluid and a hydrocarbon oil, a hydrophilic surface will be preferentially wetted by the aqueous fluid. A key parameter that describes this effect and can be used to predict good droplet formation is the advancing (maximal) contact angle – the angle between the fluid/fluid interface and the wall. For the example of a simple water/oil flow, if the contact angle for water exceeds a critical value (92° in the example shown in Fig. 2) water-in-oil droplets will be generated. Below that value oil-in-water droplets will be

Fig. 2 Generation of droplets by a flow-focusing device (FFD), with varying incoming fluid orientations and device surface characteristics. Fluids enter with either a water-in-oil (a–d, left) or oil-in-water (a′–d′, right) setup, and surfaces varying from relatively hydrophilic (a and a′) to relatively hydrophobic (d and d′) as shown by the increasing contact angle, θ . Water-in-oil droplets can be formed when the contact angle exceeds 92°. Phase inversion is visible in c′ and d′ when the oil phase wets the channels even though it is intended to be used as a dispersed phase. The scale bar is 100 μ m in all cases.⁴⁰ Reprinted (adapted) with permission from Li et al.⁴⁰ Copyright 2007 American Chemical Society.

Tutorial review Lab on a Chip

generated.40 It is important to note that droplet generation dynamics (droplet size, generation frequency) are independent of wetting assuming the contact angle is above/ below the critical angle 40 and also that for long term operation it is essential that the contact angle is maintained over time and space. If the angle crosses the critical value at a specific time and position in the channel, the disperse phase will then wet the channel walls leading to droplet pinning, cross contamination and other failure modes.¹⁰ Stable channel surfaces, reliably preferentially wetted by the continuous phase, are therefore an essential consideration when designing a droplet microfluidic device. It is preferable to make the device from a material with the required surface characteristics but this is not always possible, hence surface modification is often required as an additional fabrication step. We now describe in more detail the native surface chemistry of different device materials and the implications for fluid wetting. Tutorial review

generated." its important to note that droplet generation and chiral generation frequencies of the
advantation of the generation of the main interaction of the main the second terms of the
degree in the s

Glass is naturally hydrophilic making it typically suitable for generating oil-in-water droplets, however its natural wettability by water can vary depending on several parameters including cleaning and drying protocols, and atmospheric conditions.⁴¹ Surface modifications for glass that are compatible with both water-in-oil and oil-in-water droplet generation are well established, as described below. The most commonly used elastomer, PDMS, features a contact angle for water of $112-120^{\circ}$ when pristine, 42 signifying a hydrophobic surface suitable for generating water-in-oil droplets without modification. Contact angles vary significantly however, depending on the preparation method and surface treatment, contact time with water, and velocity of the advancing contact line.⁴³ As a result, pristine PDMS is commonly surface-treated to maintain surface properties and hence promote device longevity.

Most thermoplastics used to fabricate microfluidic devices are hydrophobic in nature, although the contact angles of water on their surface ranges from 80° to over 100°.⁴⁴ Native PMMA, for example, has been used to create devices for stable monodisperse water-in-oil droplets with mineral oil as continuous phase and Span 80/Abil Em90 as surfactants.⁴⁵ Surface modification is often needed for robust operation however,⁴⁵ or for the generation of oil-in-water droplets. Fluoropolymers are special thermoplastics containing a large proportion of fluorine atoms and characteristically exhibiting highly useful properties such as high chemical resistance, good solvent compatibility compared to other thermoplastics, and low absorption of small molecules. It is their superhydrophobic surfaces that are of most interest for droplet microfluidics. Water contact angle for native smooth polytetrafluoroethylene (PTFE) is ∼125° and therefore does not usually need to be functionalized for the generation of water-in-oil droplets. Common fluoropolymers such as $\text{PTFE},^{46}$ perfluoroalkoxy alkane (PFA), 47,48 and PTFE,⁴⁶ perfluoroalkoxy alkane (PFA) ,^{47,48} and fluorinated ethylene-propylene (FEP), 48,49 have been used to make droplet devices. They are typically difficult to fabricate as they have high glass transition temperatures

and their softness makes them poorly suited to direct machining. Hence terpolymers of tetrafluoroethylene, hexafluoropropylene and vinylidene fluoride (THV) have recently attracted attention as they offer similar properties but are easier to fabricate as the lower melting points $(<$ 200 °C) are highly suitable for melt-processing. $50,51$ Speciality fluoroelastomers $52,53$ are also available but at higher cost than standard fluoropolymers.

3b. Surface modification of channel surfaces

If the material cannot be chosen to match the required continuous phase, surfaces can be altered after the devices have been physically formed to obtain a desired surface chemistry. Chemical surface modification of glass and PDMS microfluidic devices has been routinely performed since the early days of the field. $54,55$ Compared to simply choosing a material with appropriate surface chemistry, surface modification not only allows researchers to almost arbitrarily specify the nature of the surface, but also means a device fabricated from a single material can have separate sections with different surface types. This can be exploited, for example, to make devices for generating complex dropletswithin-droplets.⁵⁶ Surface modification does, however, come at the expense of additional fabrication steps which increase fabrication time, cost, and introduces additional potential failure modes. Here we describe some of the most common techniques for surface treatment, from the simplest to the most complex.

Plasma treatment is used to activate PDMS surfaces for device bonding but, as it creates Si–OH groups on the surface of PDMS, can also be used as a method to render the surface hydrophilic. The hydrophilic surface is transient, however, and plasma treating can form cracks on the surface⁵⁷ that can exacerbate unwanted molecular diffusion into the PDMS.58 Hence, plasma treatment is typically used as a method of enhancing capillary action to fill microfluidic channels with aqueous fluids,⁵⁹ or as the first step for further surface modification. Similar treatments include corona discharge and UV light.⁶⁰

Silanisation is a common method to modify PDMS, glass or silicon surfaces. $61,62$ Silanisation is usually performed in two steps, firstly the activation of the surface by oxygen plasma treatment to yield a hydroxy-rich surface, and then immediate introduction of a silane molecule which spontaneously covalently bonds to the device surface. The choice of silane determines the resulting surface characteristics, for example 1H,1H,2H,2H-perfluorooctyltrichlorosilane (PFOS) for hydrophobic surface modification and 3-aminopropyltriethoxysilane (APTES) for hydrophilic surface modification.63 Both silanes can be used in the same microfluidic device to create both hydrophobic and hydrophilic regions which can be used, for example, for forming multiple emulsions.56 If hydrophobic surfaces are required, a similar effect can be achieved at lower cost by flowing fluorosilane-based automotive screen rain repellent treatments

through the channels.64,65 While silanisation is the most common method of surface treatment, it should not be considered a permanent change in surface properties (especially for PDMS), but rather one with a finite life span, 42 and we note there is a lack of fundamental research on the longevity of chemical surface treatments and behaviour under real-use conditions.

Polymer coatings can also be used to modify the surfaces of microfluidic devices. The most common example is the use of fluoropolymers^{66,67} to make PDMS channels superhydrophobic. In this case, the fluoropolymer forms a layer on the surface of the PDMS, though, again, the longevity of the coating is affected by the nature of the underlying material. Nanostructuring is a more complicated method of surface modification. Nature provides numerous examples of surface properties being modified by surface structure, such as the superhydrophobic surfaces of the leaves of certain plants which allow water droplets to easily roll off, cleaning the leaves in the process (the so-called "lotus effect").⁶⁸ The superhydrophobicity of these leaves directly results from the nanostructured surface which reduces the contact area between the droplet and the leaf surface. Microfluidic researchers have used bioinspired nanostructuring approaches to make both hydrophobic and hydrophilic surfaces with recent reviews summarising the different applications and fabrication methods.^{69,70} While this approach has not been widely applied to droplet flow, likely due to the extra fabrication steps involved, one group in particular has used it to render PMMA microchips superhydrophobic, 71 with this method chosen as PMMA is difficult to functionalise using other techniques. In this case, channel surfaces were modified by depositing silica nanoparticles (generating a nanotextured hydrophilic surface) which were subsequently rendered hydrophobic using n-dodecyltrichlorosilane to yield the final superhydrophobic surface. This technique has been utilised in several different devices for droplet-based microbial toxicity assays.⁷¹⁻⁷³ Lab on a Chip through the channels.⁶²⁶ While silination is lied not be prosible to use common changes are in biological common changes are in the common changes are in the simulation of the simulation-of the simulatio

3c. Use of surfactants

As an alternative to permanent functionalisation of the channel surface, channel surfaces can be non-covalently altered by utilising a continuous phase containing a surfactant. Surfactants (also referred to as emulsifiers or stabilisers) are amphiphilic molecules that are primarily used to stabilise the fluid/fluid interface, however they can also interact with channel surfaces⁷⁴ and as such be used as a temporary form of surface modification. The ability of surfactants to radically change the surface chemistry of the channels has been shown in previous studies where both water-in-oil or oil-in-water droplets could be formed in the same device by simply changing the surfactant, without any further modification of the channel surfaces.⁷⁵

There are several commercial surfactants available that are made specifically for droplet microfluidics such as QX100 by Bio Rad, PicoSurf by Sphere Fluidics, and the more

recently available FluoSurf by Emulseo. However it is also possible to use common detergents used in biological research such as sodium dodecyl sulfate (SDS), Span80 or polyethylene glycol (PEG).⁷⁴ When using a surfactant, one must decide whether to introduce it via the disperse or continuous phase. If the surfactant is dosed in the disperse phase, it is contained away from the channel walls, however if dosed in the continuous phase, surfactant molecules are free to migrate to the channel/fluid interface.^{75,76} In this case an equilibrium exists between the surfactant molecules in solution in the continuous phase, those that self-assemble at the droplet surface, and those that reversibly adhere to the channel walls. To ensure that the surface of the channels is coated with the surfactant, in practice devices are often first "primed", whereby the continuous phase is flowed through the device for several minutes before the disperse phase is introduced.

Prior work by Elvira and co-workers shows how, when using surfactants as a temporary surface modification, stable droplet formation is dependent on a certain proportion of the surfactants being present on the channel wall.¹⁰ They showed both through modelling and experimental work how addition of droplets to an continuous phase disrupts this equilibrium, with each additional droplet effectively being a "surfactant sink" that draws surfactant away from the walls of the device. This can in certain circumstances lead to droplet failure modes such as dripping, where the droplet does not form cleanly at a T-junction due to wetting of the junction walls. For a guide in choosing surfactants for each aqueous/oil phase combination and the droplet failure modes that may occur in PDMS devices, a flow chart is provided in the ESI of their 2015 paper.¹⁰

3d. Geometries to control wall interactions during droplet generation

As well as the interfacial tensions at the surface/fluid interface, the spatial relation between the fluids and the surface can also have an effect on obtaining reliable droplet flow. Droplets are generated at a junction where the dispersed and continuous fluid phases meet and the dispersed phase is broken up into discrete droplets. The shape of the microfluidic geometry dictates the spatial arrangement by which the two phases meet, which in turn, influences the mode of droplet generation as well as whether and what surface treatments are necessary. Here we briefly describe the most commonly used microfluidic designs for making droplets and how careful design, used in conjunction with the surface modifications described previously, can ensure that only the continuous phase wets the channel walls.

Flow-focusing and T-junction geometries. The most common type of microfluidic geometry used for droplet generation is planar, including both flow-focusing and T-junction geometries. In flow-focusing (Fig. 3a) and T-junction (Fig. 3b) geometries the disperse phase enters the junction via a microchannel and meets the continuous phase entering

through one (T-junction) or two (flow-focusing) adjacent microchannels. Once the two phases meet, the disperse phase spontaneously breaks up into droplets, and both the droplets and the continuous phase exit the junction via the downstream microchannel.79

In both flow-focusing and T-junction setups, whether droplets form and via what mechanism depends on the ratio of the dispersed and continuous phase volumetric flow rates, as well as the dimensionless capillary number, which is the ratio of continuous phase viscosity and velocity to the liquid– liquid interfacial tension between the two phases. Droplet generation regimes transition between the well-studied squeezing, dripping, and jetting regimes, with changes to the capillary number. $8,80$ The popularity of these geometries is likely due to their ease-of-manufacture, featuring planar designs with uniform channel heights, and are typically made from PDMS following classical soft lithography protocols.²² Consequently flow-focusing and T-junction geometries have been used in a wide range of microfluidic applications and the fluid mechanics behind their droplet generation regimes have been well studied and are well understood.⁸

One consequence of using planar geometries is that both the dispersed and continuous phase fluids are in contact with the "ceiling" and "floor" of the channels when the fluids first meet. This presents a challenge to droplet generation. As the disperse phase is already in contact with the channel walls, there is a strict requirement that the continuous phase must preferentially wet the channel walls. This is the primary reason why, in devices that generate water-in-oil droplets using flow-focusing or T-junctions, the microchannels must be made using hydrophobic materials or treated with hydrophobic coatings, as described earlier.

Co-axial geometry. The issue of the disperse phase wetting channel walls is somewhat avoided in co-axial geometry droplet generators, where the disperse phase enters into the microfluidic junction without making any contact with the outer channel (Fig. 3c). Commonly in this geometry, a tapered inner glass capillary is inserted into an outer glass capillary, 81 with the inner capillary carrying the disperse phase, and the outer capillary carrying the continuous phase. An alternative method to creating a coaxial geometry is to make a hybrid device that combines a glass capillary or needle for the dispersed phase, with a conventional PDMSbased rectangular cross section microchannel for the continuous phase. Such a system has the advantage of coaxial geometries without the manufacturing complexity of tapering glass capillaries and fitting multiple capillaries together. This approach was used to achieve the generation of water-in-water droplets, with aqueous two phase system (ATPS) fluids, without needing to chemically treat either the dispersed phase or continuous phase channel surfaces.⁸²⁻⁸⁴ As an alternative to capillaries, similar geometries can be also generated by careful design of junctions in PDMS with different channel heights.⁸⁵ Tutorial review

the bon a Critication Cost ais one of the signes are the disperse plane when the consider a consider a consider a consider a consider a consider a creation of the signes are the disperse the signes of the

Where co-axial geometries are used functionalisation is often not required, $2^{1,86}$ however this is not true in all cases. 85 Even in cases where functionalisation has been necessary however, spatial separation of the dispersed phase from the channel walls means that surface chemistry requirements are less stringent, making the devices more robust and expanding the possible fluid/material options.⁸⁷

Step-based geometry. Another 3-dimensional approach is to use a step-based microfluidic geometry. These droplet

Fig. 3 Commonly used geometries for microfluidic droplet generation include a) flow-focusing, b) T-junction, and c) co-axial geometries. Each of these microfluidic designs enable the dispersed and continuous phases to meet at a junction and generate droplets of the dispersed phase downstream of the junction. Images provided by Kaitlyn Ramsay. d) Step emulsification and its subset, e) edge-based droplet generation (EDGE) devices enable controlled monodisperse droplet generation, and the potential for massive scale-up. Images reproduced from Z. Li et al.⁷⁷ with permission from the Royal Society of Chemistry and S. ten Klooster et al.⁷⁸ under a CC BY 4.0 licence.

generation junctions feature a co-laminar two-phase flow in a shallow microchannel that expands abruptly at a "step" into a deep and wide reservoir. The sudden expansion of the channel forces the disperse phase away from the channel ceiling and floor and causes droplets to form (Fig. 3d). Step-based geometries are particularly advantageous for high throughput production of monodisperse droplets as the structures are easily parallelised by use of a single shared reservoir. An example of such parallelisation of step emulsification is an edge-based droplet generation (EDGE) device (Fig. 3e). Where high throughput is not needed step-based systems are less common, in part due to fabrication complexity; to achieve the necessary high aspect ratio "step", two separate substrates (typically made of glass or silicon) have to be etched and bonded with careful alignment,⁸⁸ or alternatively multi-layer alignment and assembly of PDMS slabs is required.77 Additionally, compared to geometries that do not require an expansion in channel size (Fig. 3a–c), droplet sizes are only approximately controlled by the final channel geometry and the deep wide reservoir makes further control, processing or analysis of individual droplets difficult.⁸⁹

4. Examples of design rationale in five different applications

With so many possible routes to control surface/fluid interactions and deliver successful droplet devices, how does a researcher choose the best option when first deciding to make a droplet microfluidic device? In practice, this is done on a case-by-case basis driven by individual experimental requirements, available resources within the laboratory, and fabrication complexity – if there are multiple routes to a similarly performing device, the route that has fewer fabrication steps, and hence fewer potential failure points, should be chosen. To provide concrete practical examples of how these choices are made in practice, here we describe five separate examples of device fabrication. In each case we focus on the experimental requirements of the microfluidic device and how that led to the material and fabrication choice. For further descriptions of droplet microfluidics applications, interested readers are directed to several more application-focussed reviews.⁹⁰⁻⁹²

4a. Single-cell encapsulation for growing clonal stem cell colonies

Single cell assays are a historically important application of droplet microfluidics, allowing omics and phenotypic studies across thousands or more cells at a time.⁹³ Culturing individual cells long-term and understanding the fate of single cells is crucial to developmental biology. The Gielen Lab, in collaboration with others, has developed a microfluidic method that enables optical interrogation of single mouse embryonic stem cells cultured over days, enabling a better understanding of cellular heterogeneity and

differentiation processes.⁹⁴ Although cells can survive and stay functional for days within water-in-oil emulsions, an increasingly popular method is to encapsulate single cells into hydrogels acting as 3D scaffolds in which cells can proliferate and form cellular aggregates.⁹⁵ This approach enables complete removal of the oil phase following polymerization of the gel. Two distinct devices were used in this work: one for single-cell encapsulation into hydrogel (agarose) and a second one for hydrogel bead trapping. Key considerations were the need for high cell survival rates during encapsulation and incubation within microfluidic devices, and high optical transparency for transmitted light and fluorescence imaging. Hence both devices were fabricated in PDMS and covalently bonded onto thin borosilicate glass coverslips. PDMS was chosen because of its compatibility with cell culture conditions (especially good gas exchange and optical clarity), easy local access to facilities to fabricate master moulds, and overall low cost and fast turnaround times. The thin coverslip substrate allows for high-resolution imaging using inverted epifluorescence microscopes. The microfluidic chip was rendered superhydrophobic by treating with 1% (v/v) (PFOS) dissolved in HFE-7500 fluorocarbon oil directly after plasma bonding, making all surfaces fluorophilic. Excess PFOS molecules were thoroughly washed away with pure HFE oil before use to ensure high cell viability when transiting through the device and during the incubation phase in gels. Glass and PDMS both coated with the fluorosilane molecules provided for robust droplet generation required to form highly monodisperse gels. Overall, longterm cell viability relied on keeping surfaces sterile, careful selection of the gel polymerization conditions and cell handling protocols. Other biocompatible materials such as thermoplastics could have alternatively been used for the droplet generation device but would have required more expensive and longer fabrication.⁹⁶ Lab on a Chip constrained on a colarinat two-phase flow in a differentiation processe," although cells are article is a constrained under the simular interval during the simular commonline, and the simular commonline, and

4b. Robust field-deployable droplet microfluidics using PTFE capillary tubing

Measurement of chemical levels in rivers, lakes and oceans is important, both in the short term for monitoring pollutant levels, and more generally for learning more about the basic biogeochemical processes that govern life on earth. Recently Nightingale and co-workers reported a droplet-based sensor for in situ monitoring of nitrate and nitrite levels in rivers (Fig. 4a) and its field testing in a tidal river (Fig. 4b) over three weeks. 97 The system works by continuously taking water samples, performing a colorimetric assay in droplets and recording the result using onboard optics and electronics. The use of droplet flow is important for removing Taylor dispersion and hence increasing temporal resolution (seconds vs. minutes) and decreasing the consumption rate of assay reagents when compared to the existing state of the art single phase systems.⁹⁸

Fig. 4 a) Droplet based nitrite sensor which was deployed for 3 weeks in the River Itchen in Southampton (b). 97 c) PDMS chip for generating droplets and introducing them into PTFE tubing100 similar to that used in early sensor prototypes. d) 3D-printed device for droplet generation at the mouth of a PTFE tube as used in the final sensor. Images reproduced from A. M. Nightingale et al., ⁹⁷ copyright 2019 American Chemical Society, and A. M. Nightingale et al^{100} under a CC BY 4.0 licence.

One of the foremost requirements for a field-deployable droplet flow system is robustness – users need to be sure that despite changes in ambient conditions (most notably temperature) droplet generation is reproducible and nondrifting *(i.e.* constant generation rate, droplet volume and droplet composition), and that there will be no droplet pinning or other unwanted surface interactions that will compromise droplet integrity and hence measurement quality. To ensure reproducible droplet generation dynamics irrespective of ambient changes, an anti-phase pulsatile pumping method was chosen, with droplet size and frequency hard-coded into the pump design, 99 however, maintaining the droplet integrity was directly dependent on correct material choice.

In development, the team initially used PDMS T-junctions to generate the droplets which were then subsequently fed into PTFE capillary tubing (Fig. 4c) for droplet incubation and optical analysis.¹⁰¹ The use of a PDMS chip meant that droplet generation could be controlled by changing geometries if required and the PTFE tubing offered a simpler means to retain the droplets during incubation. The PDMS droplet generation junctions were formed from 3D printed moulds made using a Objet500 Connex3 polyjet printer. PDMS was chosen for its transparency and easy manufacture, with 3D printing used to generate the moulds as it allowed channels of the required size (∼300 μm in the smallest dimension) to be generated much quicker and easier compared to traditional cleanroom methods. A fluorocarbon continuous phase (Fluorinert FC-40) was used to encapsulate the aqueous droplets to ensure maximum interfacial tension and hence droplet integrity. While PTFE tubing is naturally wetted by the oil and hence supports good water-in-oil droplet flow, the PDMS needed to be functionalised to render it superhydrophobic. This was achieved using a commercially available fluoroalkylsilane normally marketed for automotive screens (Aquapel, PPG Industries) however in practical testing

the surface coating had a finite lifespan of days to weeks (exact time dependent on batch-to-batch variation) with surface deterioration leading to droplet pinning and polydisperse droplet sizes. Rather than working to improve the surface functionalisation of the PDMS chip, the team decided to remove the problem completely by generating droplets directly at the PTFE tubing entrance and thus removing the need for a PDMS device. An alternative would have been to make the chip out of a fluoropolymer, however this route was much simpler. To generate the droplets at the tubing mouth a 3D printed manifold was used to converge the oil and aqueous streams at the tubing mouth so that the droplets formed as the fluids entered the tubing (Fig. 4d). As the droplet flow did not contact any material except PTFE, which has a naturally superhydrophobic surface which will not deteriorate over time, there was minimal risk of droplets pinning or breaking up. In practice this was found to be the case with continuous droplet flow in a river over three weeks. Tuttorial review

On their states are the contribution of the states are the contribution of the Baracteristic article. The control of the states are the commons are the control of the states are the control of the states

It is worth noting that while tubing-based systems 49 such as this are advantageous for their simplicity and robustness and were the right choice here, they have some notable disadvantages compared to microfluidic chips – most notably that channels cannot be arbitrarily designed for specific applications. Hence the group have more recently looked towards exploring routes to bespoke fabricated fluoropolymer devices for cases where more complicated channel architectures are required.⁵¹

4c. Microfluidic geometry for water-in-water droplet generation without surface modification

Droplet microfluidics typically involves a water/oil fluid pair, however, there is an emerging class of droplet microfluidics that generates water-surrounded-by-water (water-in-water) droplets, which have advantages in terms of biocompatibility¹⁰² and a powerful selective partitioning ability to separate biological particles such as cells, proteins, and viruses.103 Water-in-water droplets are generated using a set of fluids called aqueous two phase systems (ATPS) of which the most studied uses dextran-rich (DEX) and PEG phases. While there is sufficient surface tension between the two aqueous phases to render them immiscible, the differences in the hydrophilicity of each phase are only slight. This means droplet breakup often needs external stimulus^{104,105} and while DEX-in-PEG droplets have been commonly reported it is particularly difficult to tune channel surfaces to generate PEG-in-DEX droplets.¹⁰⁴⁻¹⁰⁷

It is here that microfluidic geometry design is very important. The Tsai Group recently showed how flowing the PEG phase as the dispersed phase in a typical planar flowfocusing microchannel results in a long PEG thread that attaches to the "ceiling" and "floor" of the microchannel, but flowing the same PEG phase into a needle that is inserted into a rectangular microchannel, such that the dispersed phase enters the channel without contact with the main

Fig. 5 Microscopy images of microchannels a) with and b) without an inserted needle. c) The PEG-in-DEX water-in-water droplets are formed when the dispersed phase enters via the needle. d) Without the needle, the dispersed PEG phase enters the channel in contact with the "ceiling" and "floor" of the channel, and forms a long thread that does not break into monodisperse droplets. Scale bar represents 100 μm. Reprinted from M. Jeyhani et al.,⁸³ copyright 2019, with permission from Elsevier.

channel "ceiling" and "floor", enables robust PEG phase water-in-water droplet formation (Fig. 5).⁸³

Water-in-water droplet microfluidics is still an emerging topic in the microfluidics field, with only a few dozen papers in the literature, and this hybrid needle-PDMS approach reported in 2019. While there are currently no general design rules for the required distance between the needle and the "floor" or "ceiling" of the microchannel, the main principle is clear: successful droplet generation is enabled by the spatial organisation of the fluids as they enter the cross junction. The design enables the dispersed phase, which can be either the PEG or DEX phases, to be sufficiently separated from the "ceiling" and "floor" of the downstream microchannel, such that any interfacial interaction forces between the dispersed phase and the channel surface can be overcome by spatial separation. Flowing the PEG phase through a needle creates a coaxial-like flow, whereby the dispersed PEG phase is surrounded by the continuous DEX phase as soon as the PEG phase enters the microchannel. In the context of fluid pairs with similar wettability, where channel surface modifications have minimal impact, this design is essential to ensuring reliable droplet breakup. A similar approach, whereby a microneedle and glass capillaries are embedded into a PDMS microfluidic channel, can be also used to create ATPS waterin-water-in-water double emulsions.⁸²

4d. Democratising microfluidic technologies using 3D printing and off-the-shelf tubing

Microfluidic technologies are commonly promoted as tools to enable new scientific discoveries, however their use is mostly confined to academic laboratories with specialist microfluidic expertise. For microfluidic systems to make the most scientific impact, they need to be used widely, however the

infrastructure (cleanroom), instrumentation (high-speed cameras, pumps, microscopes), and knowhow (photolithography, soft-lithography, device design) typically required create a barrier to uptake of microfluidic technologies as a commonplace tool. While the development of new microfluidic techniques and devices is probably always going to be confined to specialist research laboratories, 108 there are many examples in the literature where overly complicated designs are used for simple on-chip operations. Devices tend to be custom-made for each new application and it is rare indeed that a single microfluidic platform is reused even within the same research group. The balance of innovation and utility needs to be equilibrated such that simple microfluidic devices are easily accessible for use in non-specialised laboratories. As described above, 3D printing can be used to make the microfluidic devices themselves. However, 3D printing can also be used to fabricate moulds for casting elastomeric devices, which is much simpler, cheaper and easier than traditional photolithographic mould fabrication. Cab on a Chip Case Article. Computer (denoted on 24 January 2022)

Case Article is a computer of the common access Article is a common access Article is licensed under a common access Article is a common access Article is

The Elvira Group has recently developed a plug-and-play microcapillary platform for the creation of multicompartmental double emulsions that simply requires an inexpensive consumer-grade bench-top 3D printer for mould fabrication and syringe pumps for operation.¹⁰⁹ This is the type of microfluidic device that can be mailed to collaborators so that they can make droplets in their own laboratory. There were several design parameters they considered when developing this microfluidic platform. Firstly, they wanted to limit the fabrication techniques required to those readily available. Hence, they used a 3D printer that can be purchased for under 200 USD to make the mould, rather than relying on access to a cleanroom. Secondly, they wanted to remove the need for surface treatment while not limiting the types of droplets that could be made. Hence, they used off-the-shelf PTFE tubing (for hydrophobic surfaces) and glass capillaries (for hydrophilic surfaces). And lastly, they wanted to ensure that no microfluidic expertise was required to fabricate this device. Hence, the tubing and capillaries are simply inserted into "junction boxes" made from 3D printed moulds using a flexible polymer that also prevents leakage (Fig. 6a–f). The 3D printed mould was made from the standard resin supplied by the printer manufacturer to keep costs low and ensure that printing was straightforward. The junction boxes themselves were cast from polyurethane resin because this flexible material creates a seal around the tubing and capillaries inserted into the junction boxes, removing the need for gaskets or other sealants.

To demonstrate the versatility of their platform, they showed water-in-oil-in-water, oil-in-water-in-oil and oil-in-oilin-water multicompartmental double emulsions with between 1 and 10 inner droplets. The junction boxes are designed to hold glass capillaries and PTFE tubing in place and hence there is no need to manually align or glue the capillaries as with other microcapillary platforms. $81,110$ In all cases,

Fig. 6 A microcapillary platform for the formation of multicompartmental double emulsions. a) Schematic showing the overall design of the junction boxes that hold the capillaries in the correct configuration for droplet formation. b) 3D printed mold to cast the junction boxes and c–e) images of the flexible junction boxes used to hold the capillaries in place and seal them. f) Image of the assembled platform. g) Formation of water-in-oil-in-water multicompartmental double emulsions using a glass capillary to make the inner aqueous droplets (water stabilised with SDS), PTFE tubing to encapsulate them in oil (FC-40), and a glass capillary to form the double emulsions in a surrounding aqueous phase (water stabilised with SDS). h) Formation of oil-in-water-in-oil multicompartmental double emulsions using a glass capillary to make the inner oil droplets (FC-40 stabilised with PFO), a glass capillary to encapsulate them in an aqueous phase (water stabilised with SDS), and a glass capillary to form the double emulsions in oil (FC-40 stabilised with PFO). i) Formation of oil-in-oil-in-water multicompartmental double emulsions using a glass capillary to make the inner oil droplets (FC-40), a second glass capillary to encapsulate them in another oil (mineral oil), and a third glass capillary to form the double emulsions in a surrounding aqueous phase (water stabilised with SDS). j) Formation of binary water-in-oil-in-water multicompartmental double emulsions using two pieces of PTFE tubing to make the inner aqueous droplets (water stabilised with SDS), a second PTFE tubing to encapsulate them in oil (FC-40 stabilised with PFO), and a glass capillary to form the double emulsions in a surrounding aqueous phase (water stabilised with SDS). Reproduced from S. Farley et al.¹⁰⁹ with permission from the Royal Society of Chemistry. Tuttorial review
 Public Research Commons Articles.

Public Research Commons Articles. Public Research Commons Articles.

Public Research Commons Articles. Public Research Commons Articles.

Public Research Commons Arti

inexpensive off-the-shelf surfactants such as SDS to stabilise the water phases, and 1H,1H,2H,2H-perfluoro-1-octanol (PFO) to stabilise the oil phases are used to create the multiple emulsions. They also show the formation of binary water-inoil-in-water multicompartmental double emulsions with predetermined combinations of two different types of inner droplets (Fig. 6g–j). This means that with this microcapillary platform complex multicompartmental droplet emulsions can be built using readily available components that do not require expertise to assemble and operate.

4e. Interfacing microwells with nanolitre droplets for library screening applications

A key advantage often cited for droplet microfluidics is the possibility to perform reactions in a massively parallel format. Traditional droplet formation such as flow-focusing devices allow the generation of very large numbers of droplets at high rates, however, such large numbers of droplets are less useful for experiments in which small libraries (e.g. drug compounds), typically stored in microtiter plates, are to be screened individually. In these instances, droplet-on-demand platforms have been developed to provide a low-throughput alternative whereby droplets can be sampled from multiple wells in sequence. The Gielen Lab is developing similar interfaces that permit rapid screening of small compound libraries (i.e. kept in 96 or 384 well plates), in an individual or combinatorial manner, combining the on-demand access of different samples with the dropletbased advantages of low reagent consumption and statistical averaging from multiple droplets.

Gielen and co-workers previously developed an unsupervised platform to screen enzyme substrates and inhibitors kept in microwells (∼20 μL) that yielded highquality dose–response curves from up to 24 individual compounds.¹¹¹ Their strategy was to compartmentalise enzymes, substrates and inhibitors in droplets kept in sequence, relying on spatial encoding for droplet identification. In practice this was achieved using a two-stage process comprised of a tubing-based platform to generate the droplets and a chip to process the droplets. Droplets were produced by aspiration (Fig. 7A) using a tubing inlet that

Fig. 7 A) Capillary-based droplet generation by aspiration. During all steps of operation, the PTFE tubing is aspirating liquid at a constant rate. (i) The tip of the tubing is aligned with a given sample. (ii) The tip is lifted so that it sits in the aqueous phase of sample 1 (red). (iii) The tip returns to the oil phase. The change from aqueous to oil phase creates a microcompartment containing a controlled quantity of sample 1 (red). (iv) The tip is aligned below a second sample. (v) The tip is lifted analogously to step (i), but now sample 2 (blue) is taken up. (vi) The tip comes back to the carrier fluid. As a result of this process, a sequence of microdroplets with defined contents (sample 1, red; sample 2, blue) emerges in the tubing in a pre-planned order. Reproduced from F. Gielen et al.⁴⁶ under a CC BY 4.0 licence. B) Interfacing with PDMS devices. A custom-made side channel allows capillary insertion and transitioning to a microchannel. The scalebar represents 200 μm.

moved alternately between oil and sample while connected to a negative pressure source. This is a convenient way to achieve controlled, stable production albeit at low throughputs $(<10 \text{ Hz}$)⁴⁶ and results in the generation of a confined drop every cycle.⁴⁶ There were several requirements for the tubing material: firstly the continuous phase (FC-40) had to preferentially wet the tubing to avoid any contamination between aqueous samples. Secondly, as a UVvis absorbance-based method was used to analyse the droplets, the tubing needed to be optically transparent. Thirdly it had to be mechanically resilient enough to allow being squeezed and pulled through a hook-shaped stainless steel guide tube that held the PTFE tube and moved it vertically. Consequently, they settled on a microbore PTFE tubing which had the required superhydrophobic surface, had walls thin enough to be effectively transparent, and was soft enough to be threaded through the stainless steel guide.

While production of arbitrary sequences of droplets is not easily done on-chip, chips are much better suited to complex, sequential droplet operations which require complex channel architectures. To enable one-to-one droplet fusion and serial droplet dilution, the droplet-containing tubing was therefore connected to specially designed PDMS microfluidic chips (Fig. 7B). The chips were fabricated using stereolithography, bonded to thin PDMS layers via oxygen plasma and then the channels were surface modified using a fluorosilane dissolved in fluorinated oil. PDMS was used as the chip material as it had the required deformability that allowed easy insertion and sealing of PTFE tubing. The chips were designed with a side-port in which the tubing could be inserted until contact with the end of a pre-designed channel. The side connection is essential to preserve the spatial arrangement of droplets and provides a convenient way to monitor transfer between tubing and the device (Fig. 7B). The PDMS–capillary interface was made permanent using silicone sealants which solidified to create a mechanically solid seal. Thanks to this connection, they could demonstrate added functionality such as droplet dilution and fusion, expanding the capabilities and analytical throughput of the platform.

5. Future perspectives

We end by highlighting several areas where changes in material usage and development of new techniques are anticipated to lead to changes in the way researchers fabricate droplet microfluidic devices in the future.

5a. 3D printed microfluidic devices

As noted above, 3D printed microfluidic devices feature highly in recent microfluidic publications. While resolution limits mean 3D printing is unlikely to become the go-to fabrication method for most researchers (at least not in the short to medium term), it is likely to continue to be a highly popular fabrication method. The maturity of printing technologies has led to decreasing costs and widespread adoption. This increasing popular uptake has a reciprocal effect in further developing the technology and the wider commercial industry behind it. Accordingly, it is likely that 3D printing will continue to be a popular fabrication method, driven by the ease and low cost of manufacture which, as highlighted earlier, has the potential to democratise microfluidics by allowing a wider pool of researchers to fabricate microfluidic devices. Common and the method on 24 January 2022. The state is licensed under the state of the state is licensed under the state of the state is licensed under the state of the s

For 3D printed fabrication to have maximum utility for droplet microfluidics, we would hope that in future cost improvements are also accompanied by technical improvements that allow more material choices with good feature sizes. Of the two most popular and accessible methods, fused deposition modelling (FDM) and stereolithography (SL), FDM offers a broad range of commercially available materials, including fluoropolymers, but most standard FDM printers struggle to reliably produce channels below 500 μm. SL conversely offers channel sizes down to ~100 $μm₁₁₂$ but suffers from a much narrower range of potential materials. As reliably defined channel sizes and channel surface chemistries are both paramount to droplet microfluidics, the use of 3D printing is likely to continue to increase, but will become truly valuable when low feature sizes and a wide range of materials can be combined within an affordable printer.

5b. Restriction of PFAS (per/poly-fluoroalkyl substances)

Droplet microfluidics makes routine use of fluorinated substances, be it in fluorocarbon carrier fluids, fluoroalkylsilane-derived surface coatings, surfactants, and/or fluoropolymer device materials. The environmental persistence of PFAS has become increasingly

Tutorial review Lab on a Chip

apparent over recent years. Consequently there has been a legislative push to restrict their use $113,114$ with legislation already addressing PFAS in fire extinguishing foams, and food contact paper and cardboard, for example.^{115,116} While legal moves to restrict PFAS will focus on applications with the greatest usage and highest environmental impact, it seems unlikely that microfluidics will be immediately affected by legislation. However the long-term direction of travel is clear and should be a consideration for those wishing to commercialise microfluidic technology. It also raises the question whether the microfluidic community should be devoting more effort to investigating alternative materials that provide similar performance with less environmental impact. Tutorial review the space of recent years. Consequently there has a disturbation interactive point in the star are the carry interactive interactive interactive commons are the star and the star are the star are the star

5c. Standard microfluidic modules

Microfluidic devices should ideally be tools that any laboratory could use without needing to have access to specialist fabrication techniques or knowledge, so that more scientists can make use of the technique. This would be aided if standard microfluidic modules for set operations (such as droplet generation, incubation, dosing, optical analysis etc.) were easily available and could be combined as required for a given application. Standardisation would promote availability as it would aid mass production 117 however for this to happen the microfluidic devices would also need to be made from materials with the required material and surface properties for the targeted application and suitable for simple large scale production.

A recent example of an approach to address standardisation is the work of Owens and Hart,¹¹⁸ who used micromilling to pattern store-bought LEGO bricks (made by standard injection moulding) to create LEGO-like blocks that contained microchannels. Each type of block could achieve different functions, such as fluid mixing and droplet generation, and could be reconfigurably fitted together for different sequential fluid operations. Such an approach to standardisation is innovative with injection moulding as a fabrication technique having the advantage that it can be used to pattern the microfluidic channels, works with a wide variety of polymers (such as PS and acrylonitrile butadiene styrene), is suitable for mass production, and results in smooth surfaces and small tolerances. One potential disadvantage is that these materials, like other thermoplastics, are generally incompatible with organic solvents but this could be rectified by coating with a resistant material like parylene-C, as the authors demonstrated.

3D printing (as described in the previous section) offers a different potential approach to achieving standardisation, whereby set designs can be shared easily, 3D printed and combined as required. Other approaches to standardisation are also being proposed by researchers, however more innovations from the microfluidics community will be needed to truly achieve useful standardisation.

5d. Surfactant innovation

In one of the example applications above we touched on how droplet microfluidics would benefit by being available to a wider range of researchers. One such area where this is an issue is in the surfactants which are typically used. Currently, the most reliable surfactants are commercially produced, but they are expensive, and suppliers do not provide detailed information on what exactly is in the bottle. This limits how easily researchers in resource-limited settings can use them and provides a barrier to the development of new dropletbased assays. A significant advance in this field would be the development of a range of inexpensive surfactants designed for specific applications, from cell culture chemical synthesis.

Surfactants also have potential in terms of providing extra functionality in a droplet-based system, if surfactants could be used as active surfaces to enhance the application rather than just to stabilise the droplets. For example, surfactants could be synthesised to include catalysts or reporter molecules for reactions taking place within the droplet, or to immobilise cells on the droplet surface.

5e. Hybrid material devices

Incorporation of functional materials within the microfluidic device allows fabrication of hybrid devices that can perform complex functions. For example, indium tin oxide coated glass is frequently used for patterning planar electrodes inducing dielectrophoretic forces,¹¹⁹ while piezoelectric substrates¹²⁰ (e.g. $LiNbO₃$) are used for generating surface acoustic waves. As other functional materials are developed there is significant scope to create new and innovative devices. Light-sensitive polymers appear especially promising as they can display reversible hydrophobicity/hydrophilicity 121 so that one could imagine ondemand patterning of chip areas with precisely controlled surface energy to unlock novel applications such as the creation of multiple emulsions (e.g. more than three) in a single device, generation of hydrophilic spots for creating detachable sessile droplets, or configurable droplet extraction to liquid phase without the need for electrodes. Likewise, the recent trend in liquid-metal based microfluidics using low-melting point metals¹²² is likely to apply to the droplet field to create electro-fluidic devices. These allow the creation of devices made entirely with flexible materials but also can be used to design components such as pumps, heaters, or valves, adding a range of low power functions to create fully embedded systems.

6. Conclusion

With various different potential native surfaces, surface modification techniques, and channel geometry options, there are a range of strategies to deliver microfluidic devices that provide reliable droplet flow. While there are often several potential different fabrication routes to a device that fulfils the required performance criteria, it is important to think holistically; ultimately the fabrication route chosen

should also take account of the complexity and reproducibility of the fabrication process. Indeed, a consistent theme of the example devices given above is that devices should only be as complex as they need to be, with fewer and simpler fabrication steps reducing failure modes, time, and cost. The range of possible fabrication options will continue to increase over time. New techniques, such as the growth of 3D printing offer new routes to successful devices and mean that microfluidic devices are becoming, and will hopefully continue to become, more accessible to a wider range of researchers. As a consequence, we expect the popularity of droplet microfluidics to be sustained into the future and newcomers to the field to catalyse droplet-based research in new and unexpected directions. Lab on a Chip stock are access article of the complexity on 24 January 2022, a set are access are the stock and the stock article is licensed at the stock article is licensed on 6. Exerce and the stock article is licensed

Conflicts of interest

There are no conflicts to declare.

Acknowledgements

KSE's position is funded by the Canada Research Chairs program and the Michael Smith Foundation for Health Research in partnership with the Pacific Alzheimer Research Foundation. FG has received funding from the Biotechnology and Biological Sciences Research Council (grant BB/T011777/ 1) and the European Union's Horizon 2020 research and innovation programme (grant agreement No. 101000560). SSHT is thankful for support from the Government of Canada's Natural Sciences and Engineering Research Council (NSERC), Discovery Grants program (RGPIN-2019-04618). AMN is supported by the Natural Environment Research Council via an Industrial Innovation Fellowship (NE/R013578/1) and the Signals in the Soil program (NE/T010584/1).

References

- 1 A. J. deMello, Nature, 2006, 442, 394–402.
- 2 K. S. Elvira, X. Casadevalli i Solvas, R. C. R. Wootton and A. J. deMello, Nat. Chem., 2013, 5, 905–915.
- 3 H. Song and R. F. Ismagilov, J. Am. Chem. Soc., 2003, 125, 14613–14619.
- 4 J. H. Bannock, S. H. Krishnadasan, A. M. Nightingale, C. P. Yau, K. Khaw, D. Burkitt, J. J. M. Halls, M. Heeney and J. C. de Mello, Adv. Funct. Mater., 2013, 23, 2123–2129.
- 5 I. Shestopalov, J. D. Tice and R. F. Ismagilov, Lab Chip, 2004, 4, 316–321.
- 6 J. J. Agresti, E. Antipov, A. R. Abate, K. Ahn, A. C. Rowat, J.-C. Baret, M. Marquez, A. M. Klibanov, A. D. Griffiths and D. A. Weitz, Proc. Natl. Acad. Sci. U. S. A., 2010, 107, 4004–4009.
- 7 C. N. Baroud, F. Gallaire and R. Dangla, Lab Chip, 2010, 10, 2032–2045.
- 8 G. F. Christopher and S. L. Anna, J. Phys. D: Appl. Phys., 2007, 40, R319–R336.
- 9 S. W. Hu, X. Q. Ren, M. Bachman, C. E. Sims, G. P. Li and N. Allbritton, Anal. Chem., 2002, 74, 4117–4123.
- 10 A. P. Debon, R. C. R. Wootton and K. S. Elvira, Biomicrofluidics, 2015, 9, 024119.
- 11 P. N. Nge, C. I. Rogers and A. T. Woolley, Chem. Rev., 2013, 113, 2550–2583.
- 12 J. B. Nielsen, R. L. Hanson, H. M. Almughamsi, C. Pang, T. R. Fish and A. T. Woolley, Anal. Chem., 2020, 92, 150–168.
- 13 K. Ren, J. Zhou and H. Wu, Acc. Chem. Res., 2013, 46, 2396–2406.
- 14 S. Bammesberger, A. Ernst, N. Losleben, L. Tanguy, R. Zengerle and P. Koltay, Drug Discovery Today, 2013, 18, 435–446.
- 15 P. Ben-Tzvi and W. Rone, Microsyst. Technol., 2010, 16, 333–356.
- 16 K. Choi, A. H. C. Ng, R. Fobel and A. R. Wheeler, Annu. Rev. Anal. Chem., 2012, 5, 413–440.
- 17 E. Samiei, M. Tabrizian and M. Hoorfar, Lab Chip, 2016, 16, 2376–2396.
- 18 A. Waldbaur, H. Rapp, K. Länge and B. E. Rapp, Anal. Methods, 2011, 3, 2681–2716.
- 19 A.-G. Niculescu, C. Chircov, A. C. Bîrcă and A. M. Grumezescu, Int. J. Mol. Sci., 2021, 22, 2011.
- 20 S. M. Scott and Z. Ali, Micromachines, 2021, 12, 319.
- 21 A. S. Utada, E. Lorenceau, D. R. Link, P. D. Kaplan, H. A. Stone and D. A. Weitz, Science, 2005, 308, 537–541.
- 22 Y. Xia and G. M. Whitesides, Annu. Rev. Mater. Sci., 1998, 28, 153–184.
- 23 V. Sunkara, D.-K. Park, H. Hwang, R. Chantiwas, S. A. Soper and Y.-K. Cho, Lab Chip, 2011, 11, 962–965.
- 24 H. Becker and C. Gärtner, Anal. Bioanal. Chem., 2008, 390, 89–111.
- 25 D. J. Guckenberger, T. E. de Groot, A. M. D. Wan, D. J. Beebe and E. W. K. Young, Lab Chip, 2015, 15, 2364–2378.
- 26 J. C. McDonald, D. C. Duffy, J. R. Anderson, D. T. Chiu, H. K. Wu, O. J. A. Schueller and G. M. Whitesides, Electrophoresis, 2000, 21, 27–40.
- 27 S. S. Deshmukh and A. Goswami, Mater. Manuf. Processes, 2021, 36, 501–543.
- 28 U. M. Attia, S. Marson and J. R. Alcock, Microfluid. Nanofluid., 2009, 7, 1.
- 29 K. Sugioka, J. Xu, D. Wu, Y. Hanada, Z. Wang, Y. Cheng and K. Midorikawa, Lab Chip, 2014, 14, 3447–3458.
- 30 C. G. Khan Malek, Anal. Bioanal. Chem., 2006, 385, 1351–1361.
- 31 S. Waheed, J. M. Cabot, N. P. Macdonald, T. Lewis, R. M. Guijt, B. Paull and M. C. Breadmore, Lab Chip, 2016, 16, 1993–2013.
- 32 F. Li, N. P. Macdonald, R. M. Guijt and M. C. Breadmore, Lab Chip, 2019, 19, 35–49.
- 33 J. Hwang, Y. H. Cho, M. S. Park and B. H. Kim, Int. J. Precis. Eng. Manuf., 2019, 20, 479–495.
- 34 A. J. G. Otuka, N. B. Tomazio, K. T. Paula and C. R. Mendonça, Polymer, 2021, 13, 1994.
- 35 T. W. Lim, Y. Son, Y. J. Jeong, D.-Y. Yang, H.-J. Kong, K.-S. Lee and D.-P. Kim, Lab Chip, 2011, 11, 100–103.
- 36 L. Amato, Y. Gu, N. Bellini, S. M. Eaton, G. Cerullo and R. Osellame, Lab Chip, 2012, 12, 1135–1142.
- 37 I. Bilican and M. Tahsin Guler, Appl. Surf. Sci., 2020, 534, 147642.
- 38 S. Su, G. Jing, M. Zhang, B. Liu, X. Zhu, B. Wang, M. Fu, L. Zhu, J. Cheng and Y. Guo, Sens. Actuators, B, 2019, 282, 60–68.
- 39 S. A. Aghvami, A. Opathalage, Z. K. Zhang, M. Ludwig, M. Heymann, M. Norton, N. Wilkins and S. Fraden, Sens. Actuators, B, 2017, 247, 940–949.
- 40 W. Li, Z. Nie, H. Zhang, C. Paquet, M. Seo, P. Garstecki and E. Kumacheva, Langmuir, 2007, 23, 8010–8014.
- 41 I. R. Durán and G. Laroche, Prog. Mater. Sci., 2019, 99, 106–186.
- 42 D. Bodas and C. Khan-Malek, Sens. Actuators, B, 2007, 123, 368–373.
- 43 W. S. Y. Wong, L. Hauer, A. Naga, A. Kaltbeitzel, P. Baumli, R. Berger, M. D'Acunzi, D. Vollmer and H.-J. Butt, Langmuir, 2020, 36, 7236–7245.
- 44 C. Zilio, L. Sola, F. Damin, L. Faggioni and M. Chiari, Biomed. Microdevices, 2014, 16, 107–114.
- 45 V. Sahore, S. R. Doonan and R. C. Bailey, Anal. Methods, 2018, 10, 4264–4274.
- 46 F. Gielen, L. van Vliet, B. T. Koprowski, S. R. A. Devenish, M. Fischlechner, J. B. Edel, X. Niu, A. J. deMello and F. Hollfelder, Anal. Chem., 2013, 85, 4761–4769.
- 47 A. C. Sun, D. J. Steyer, A. R. Allen, E. M. Payne, R. T. Kennedy and C. R. J. Stephenson, Nat. Commun., 2020, 11, 6202.
- 48 K. Ren, W. Dai, J. Zhou, J. Su and H. Wu, Proc. Natl. Acad. Sci. U. S. A., 2011, 108, 8162–8166.
- 49 M. Horka, S. Sun, A. Ruszczak, P. Garstecki and T. Mayr, Anal. Chem., 2016, 88, 12006–12012.
- 50 N. Aboud, D. Ferraro, M. Taverna, S. Descroix, C. Smadja and N. T. Tran, Analyst, 2016, 141, 5776–5783.
- 51 A. M. Nightingale, S.-u. Hassan, K. Makris, W. T. Bhuiyan, T. J. Harvey and X. Niu, RSC Adv., 2020, 10, 30975–30981.
- 52 A. H. McMillan, J. Mora-Macías, J. Teyssandier, R. Thür, E. Roy, I. Ochoa, S. De Feyter, I. F. J. Vankelecom, M. B. J. Roeffaers and S. C. Lesher-Pérez, Nano Sel., 2021, 2, 1385–1402.
- 53 I. Morita, Y. Ando and Y. J. Heo, J. Adv. Mech. Des. Syst. Manuf., 2017, 11, JAMDSM0031.
- 54 I. Wong and C.-M. Ho, Microfluid. Nanofluid., 2009, 7, 291.
- 55 H. Makamba, J. H. Kim, K. Lim, N. Park and J. H. Hahn, Electrophoresis, 2003, 24, 3607–3619.
- 56 T. Trantidou, Y. Elani, E. Parsons and O. Ces, Microsyst. Nanoeng., 2017, 3, 16091.
- 57 M. J. Owen and P. J. Smith, J. Adhes. Sci. Technol., 1994, 8, 1063–1075.
- 58 M. Lenz, B. Sebastian and P. S. Dittrich, Small, 2019, 15, 1901547.
- 59 F. Jahangiri, T. Hakala and V. Jokinen, Microfluid. Nanofluid., 2019, 24, 2.
- 60 S. K. Nemani, R. K. Annavarapu, B. Mohammadian, A. Raiyan, J. Heil, M. A. Haque, A. Abdelaal and H. Sojoudi, Adv. Mater. Interfaces, 2018, 5, 1801247.
- 61 U. Srinivasan, M. R. Houston, R. T. Howe and R. Maboudian, J. Microelectromech. Syst., 1998, 7, 252–260.
- 62 Gelest Inc, Silane Coupling Agents Connecting Across Boundaries, [https://www.gelest.com/wp-content/uploads/](https://www.gelest.com/wp-content/uploads/Silane_Coupling_Agents.pdf) [Silane_Coupling_Agents.pdf](https://www.gelest.com/wp-content/uploads/Silane_Coupling_Agents.pdf), 2014. Tutorial review μ Burear and A. This include μ Burear and A. Commons Article is licensed on μ Creative Commons Article is licensed under a Commons Attribution-Noncommercial and A. This article is licensed under a c
	- 63 J. H. L. Beal, A. Bubendorfer, T. Kemmitt, I. Hoek and W. M. Arnold, Biomicrofluidics, 2012, 6, 036503.
	- 64 A. B. Theberge, G. Whyte and W. T. S. Huck, Anal. Chem., 2010, 82, 3449–3453.
	- 65 A. R. Abate, D. Lee, T. Do, C. Holtze and D. A. Weitz, Lab Chip, 2008, 8, 516–518.
	- 66 C. T. Riche, C. Zhang, M. Gupta and N. Malmstadt, Lab Chip, 2014, 14, 1834–1841.
	- 67 T. Yang, J. Choo, S. Stavrakis and A. de Mello, Chem. Eur. J., 2018, 24, 12078–12083.
	- 68 W. Barthlott and C. Neinhuis, Planta, 1997, 202, 1–8.
	- 69 S. Wang, X. Yang, F. Wu, L. Min, X. Chen and X. Hou, Small, 2020, 16, 1905318.
	- 70 Y. Zuo, L. Zheng, C. Zhao and H. Liu, Small, 2020, 16, 1903849.
	- 71 R. Ortiz, J. L. Chen, D. C. Stuckey and T. W. J. Steele, ACS Appl. Mater. Interfaces, 2017, 9, 13801–13811.
	- 72 R. Ortiz, J. L. Chen, D. C. Stuckey and T. W. J. Steele, Micro Nano Eng., 2019, 2, 92–103.
	- 73 R. Ortiz, D. C. Stuckey and T. W. J. Steele, Micro Nano Eng., 2019, 3, 82–91.
	- 74 J.-C. Baret, Lab Chip, 2012, 12, 422–433.
	- 75 J. H. Xu, S. W. Li, J. Tan, Y. J. Wang and G. S. Luo, Langmuir, 2006, 22, 7943–7946.
	- 76 B. Riechers, F. Maes, E. Akoury, B. Semin, P. Gruner and J.-C. Baret, Proc. Natl. Acad. Sci. U. S. A., 2016, 113, 11465–11470.
	- 77 Z. Li, A. M. Leshansky, L. M. Pismen and P. Tabeling, Lab Chip, 2015, 15, 1023–1031.
	- 78 S. ten Klooster, S. Sahin and K. Schroën, Sci. Rep., 2019, 9, 7820.
	- 79 M. Seo, C. Paquet, Z. Nie, S. Xu and E. Kumacheva, Soft Matter, 2007, 3, 986–992.
	- 80 J. K. Nunes, S. S. H. Tsai, J. Wan and H. A. Stone, J. Phys. D: Appl. Phys., 2013, 46, 114002.
	- 81 R. K. Shah, H. C. Shum, A. C. Rowat, D. Lee, J. J. Agresti, A. S. Utada, L.-Y. Chu, J.-W. Kim, A. Fernandez-Nieves, C. J. Martinez and D. A. Weitz, Mater. Today, 2008, 11, 18–27.
	- 82 M. Jeyhani, R. Thevakumaran, N. Abbasi, D. K. Hwang and S. S. H. Tsai, Small, 2020, 16, 1906565.
	- 83 M. Jeyhani, V. Gnyawali, N. Abbasi, D. K. Hwang and S. S. H. Tsai, J. Colloid Interface Sci., 2019, 553, 382–389.
	- 84 M. Navi, N. Abbasi, M. Jeyhani, V. Gnyawali and S. S. H. Tsai, Lab Chip, 2018, 18, 3361–3370.
	- 85 M. B. Romanowsky, A. R. Abate, A. Rotem, C. Holtze and D. A. Weitz, Lab Chip, 2012, 12, 802–807.
	- 86 Z. Nie, S. Xu, M. Seo, P. C. Lewis and E. Kumacheva, J. Am. Chem. Soc., 2005, 127, 8058–8063.
	- 87 L. Y. Chu, A. S. Utada, R. K. Shah, J. W. Kim and D. A. Weitz, Angew. Chem., Int. Ed., 2007, 46, 8970–8974.
	- 88 K. van Dijke, G. Veldhuis, K. Schroën and R. Boom, Lab Chip, 2009, 9, 2824–2830.
	- 89 Z. Shi, X. Lai, C. Sun, X. Zhang, L. Zhang, Z. Pu, R. Wang, H. Yu and D. Li, Chem. Commun., 2020, 56, 9056–9066.
- 90 L. Shang, Y. Cheng and Y. Zhao, Chem. Rev., 2017, 117, 7964–8040.
- 91 S. Sohrabi, N. Kassir and M. Keshavarz Moraveji, RSC Adv., 2020, 10, 27560–27574.
- 92 T. S. Kaminski and P. Garstecki, Chem. Soc. Rev., 2017, 46, 6210–6226.
- 93 K. Matuła, F. Rivello and W. T. S. Huck, Adv. Biosyst., 2020, 4, 1900188.
- 94 H. Kleine-Brüggeney, L. D. van Vliet, C. Mulas, F. Gielen, C. C. Agley, J. C. R. Silva, A. Smith, K. Chalut and F. Hollfelder, Small, 2019, 15, 1804576.
- 95 S. Allazetta and M. P. Lutolf, Curr. Opin. Biotechnol., 2015, 35, 86–93.
- 96 E. W. K. Young and D. J. Beebe, Chem. Soc. Rev., 2010, 39, 1036–1048.
- 97 A. M. Nightingale, S.-u. Hassan, B. M. Warren, K. Makris, G. W. H. Evans, E. Papadopoulou, S. Coleman and X. Niu, Environ. Sci. Technol., 2019, 53, 9677–9685.
- 98 A. M. Nightingale, A. D. Beaton and M. C. Mowlem, Sens. Actuators, B, 2015, 221, 1398–1405.
- 99 A. M. Nightingale, G. W. H. Evans, P. X. Xu, B. J. Kim, H. Sammer-ul and X. Z. Niu, Lab Chip, 2017, 17, 1149–1157.
- 100 A. M. Nightingale, C. L. Leong, R. A. Burnish, S.-u. Hassan, Y. Zhang, G. F. Clough, M. G. Boutelle, D. Voegeli and X. Niu, Nat. Commun., 2019, 10, 2741.
- 101 A. M. Nightingale, S.-u. Hassan, G. W. H. Evans, S. M. Coleman and X. Niu, Lab Chip, 2018, 18, 1903–1913.
- 102 Y. Chao and H. C. Shum, Chem. Soc. Rev., 2020, 49, 114–142.
- 103 Y. S. Huh, S. J. Jeon, E. Z. Lee, H. S. Park and W. H. Hong, Korean J. Chem. Eng., 2011, 28, 633–642.
- 104 J. A. De Lora, F. A. Fencl, A. D. Y. Macias Gonzalez, A. Bandegi, R. Foudazi, G. P. Lopez, A. P. Shreve and N. J. Carroll, ACS Appl. Bio Mater., 2019, 2, 4097–4105.
- 105 I. Ziemecka, V. van Steijn, G. J. M. Koper, M. Rosso, A. M. Brizard, J. H. van Esch and M. T. Kreutzer, Lab Chip, 2011, 11, 620–624.
- 106 B.-U. Moon, N. Abbasi, S. G. Jones, D. K. Hwang and S. S. H. Tsai, Anal. Chem., 2016, 88, 3982–3989.
- 107 H. C. Shum, J. Varnell and D. A. Weitz, Biomicrofluidics, 2012, 6, 012808.
- 108 D. Sinton and S. O. Kelley, Lab Chip, 2021, 21, 2330–2332.
- 109 S. Farley, K. Ramsay and K. S. Elvira, Lab Chip, 2021, 21, 2781–2790.
- 110 Y. Iwasa, K. Yamanoi, Y. Kaneyasu and T. Norimatsu, Fusion Sci. Technol., 2018, 73, 258–264.
- 111 F. Gielen, T. Buryska, L. Van Vliet, M. Butz, J. Damborsky, Z. Prokop and F. Hollfelder, Anal. Chem., 2015, 87, 624–632.
- 112 N. P. Macdonald, J. M. Cabot, P. Smejkal, R. M. Guijt, B. Paull and M. C. Breadmore, Anal. Chem., 2017, 89, 3858–3866.
- 113 C. F. Kwiatkowski, D. Q. Andrews, L. S. Birnbaum, T. A. Bruton, J. C. DeWitt, D. R. U. Knappe, M. V. Maffini, M. F. Miller, K. E. Pelch, A. Reade, A. Soehl, X. Trier, M. Venier, C. C. Wagner, Z. Wang and A. Blum, Environ. Sci. Technol. Lett., 2020, 7, 532–543. Cable on a Chip Carticle on 24 January 2022. Downloaded under a Creative Commons Articles. The Commons Articles. The Commons Art
	- 114 I. T. Cousins, G. Goldenman, D. Herzke, R. Lohmann, M. Miller, C. A. Ng, S. Patton, M. Scheringer, X. Trier, L. Vierke, Z. Wang and J. C. DeWitt, Environ. Sci.: Processes Impacts, 2019, 21, 1803–1815.
	- 115 Bekendtgørelse om fødevarekontaktmaterialer og om straffebestemmelser for overtrædelse af relaterede EU-retsakter, <https://www.retsinformation.dk/eli/lta/2020/681>, 2020.
	- 116 State of Maine An Act To Protect the Environment and Public Health by Further Reducing Toxic Chemicals in Packaging, [https://www.maine.gov/dep/safechem/packaging/](https://www.maine.gov/dep/safechem/packaging/LD1433-PL277.pdf) [LD1433-PL277.pdf,](https://www.maine.gov/dep/safechem/packaging/LD1433-PL277.pdf) 2019.
	- 117 D. R. Reyes, H. van Heeren, S. Guha, L. Herbertson, A. P. Tzannis, J. Ducrée, H. Bissig and H. Becker, Lab Chip, 2021, 21, 9–21.
	- 118 C. E. Owens and A. J. Hart, Lab Chip, 2018, 18, 890–901.
	- 119 X. Niu, F. Gielen, A. J. deMello and J. B. Edel, Anal. Chem., 2009, 81, 7321–7325.
	- 120 T. Franke, A. R. Abate, D. A. Weitz and A. Wixforth, Lab Chip, 2009, 9, 2625–2627.
	- 121 E. Rossegger, D. Nees, S. Turisser, S. Radl, T. Griesser and S. Schlögl, Polym. Chem., 2020, 11, 3125–3135.
	- 122 L. Zhu, B. Wang, S. Handschuh-Wang and X. Zhou, Small, 2020, 16, 1903841.