


Cite this: *RSC Adv.*, 2023, 13, 3123

# A doped-polymer based porous silicon photonic crystal sensor for the detection of gamma-ray radiation

Fatma A. Sayed, Hussein A. Elsayed, Ahmed Mehaney, M. F. Eissa and Arafa H. Aly \*

In this research, a theoretical investigation of the one-dimensional defective photonic crystals is considered for the detection of gamma-ray radiation. Each unit cell of the considered one-dimensional photonic crystals (1D PhCs) is composed of two layers designed from porous silicon infiltrated by poly-vinyl alcohol polymer doped with crystal violet (CV) and carbol fuchsin (CF) dyes (doped-polymer) with different porosity. In addition, a single layer of doped-polymer is included in the middle of the designed 1D PhCs to stimulate the localization of a distinct resonant wavelength through the photonic band gap. In particular, the appearance of this resonant mode represents the backbone of our study towards the detection of  $\gamma$ -ray radiation with doses from 0 to 70 Gy. The Bruggeman's effective medium equation, the fitted experimental data to the refractive index of the doped-polymer, and the Transfers Matrix Method (TMM) serve as the mainstay of our theoretical treatment. The numerical findings provide significant contributions to some of the governing parameters such as the thicknesses of the considered materials on the performance of the presented sensor, the effect of incidence angle and the porosity of the considered materials on the resonance wavelength. In this regard, at optimum values of these parameters the sensitivity, quality factor, signal-to-noise ratio, detection limit, sensor resolution, and figure of merit that are obtained are 205.7906 nm RIU<sup>-1</sup>, 9380.483, 49.315,  $2.05 \times 10^{-5}$  RIU,  $3.27 \times 10^{-5}$ , and 2429.31 RIU<sup>-1</sup>, respectively. Therefore, we believe that the suggested design could be of significant interest in many industrial, medical, and scientific applications.

Received 30th November 2022

Accepted 15th January 2023

DOI: 10.1039/d2ra07637c

rsc.li/rsc-advances

## Introduction

Ionizing radiation is a type of high-energy radiation that causes ionization in the materials it passes through. It comprises non-particulate radiation, like X-rays and  $\gamma$ -rays, as well as radiation produced by energetically charged particles, like alpha and beta particles, or by neutrons. Ionizing radiation can alter the exposed material in a variety of ways, including biological, chemical, and physical responses.<sup>1,2</sup> Ionizing radiation has recently become more widely used for a variety of applications.<sup>3,4</sup> Industrial radiation processing and control, cancer cell treatment, medical sterilization, food preservation, and environmental gamma dosimetry are demonstrated among the applications where radiation dosimeters are used.<sup>3,5-7</sup>

Meanwhile, radiation dosimetry is crucial to these ionizing radiations and has attracted a lot of attention.<sup>8</sup> There are different types of radiation dosimetry used to detect ionizing radiations.<sup>4</sup> A scintillation dosimeter is one of the oldest types of dosimeters, which uses the scintillation light produced in particular materials. Scintillation dosimeters work on the principle that the substance being utilized can convert ionizing

radiation into detectable light. It is then converted into an electrical signal using a photodiode or photomultiplier tube.<sup>9</sup> The second type of dosimetry is known as thermoluminescence. Thermoluminescence (TL) is defined as the emission of light from a solid as a result of heat following radiation exposure. A dosimeter based on optically stimulated luminescence works similarly to a TL dosimeter. These types of dosimeters can measure very small dosages and are suited for personal and medical uses.<sup>10-12</sup> Also, some dosimeters rely on changes in the optical fiber and use spectrophotometry to measure the change in Radiation-Induced Attenuation (RIA).<sup>8,13</sup> Moreover, quartz fiber electroscope (QFE) dosimeters, electronic and electrical dosimeters, and film/badge personal dosimeters represent one of the most popular types. However, most of the aforementioned types have some disadvantages that appear in the form of limited shelf life, expensive price, temperature and light impacts that cause fading, and sensitivity to hard handling.<sup>13</sup> These issues primarily raise operating costs for industrial applications. For usage in strain and temperature applications, a lot of research has been done on creating radiation-resistant Fibre Bragg Gratings (FBGs).<sup>14,15</sup> In this regard, optical FBG sensors have proven to be advantageous in many industrial sensing applications. Their primary advantages over electronic, chemical, mechanical, and electrical sensors typically include

TH-PPM Group, Physics Department, Faculty of Science, Beni-Suef University, Beni-Suef, 62521, Egypt. E-mail: arafa.hussien@science.bsu.edu.eg



their higher sensitivity, small size, resistance to harsh environments, immunity to electromagnetic interference, ability to be mass produced at low cost, and ability to measure remotely in real time.<sup>16</sup> In addition, there are dosimeters based on photonic crystal fiber and Bragg gratings structures.<sup>8</sup>

Photonic Crystals (PhCs) are artificial inhomogeneous structures that can be designed or fabricated in one-dimension (1D), two-dimension (2D), or three-dimension (3D) to control and manipulate light's propagation within a specific range of frequencies called the photonic band gap (PBG).<sup>17–19</sup> The difference in refractive indices between the constituent materials leads to the generation of this PBG. The creation of local resonance modes by creating a cavity or (defect) within the periodic structure of PhCs is utilized in sensor applications.<sup>20–22</sup> The PhCs are a promising candidate for application in radiation dosimetry.<sup>8</sup> This is a result of their remarkable stable behavior and post-irradiation recovery characteristics.<sup>8</sup>

When constructing the best PhCs as radiation dosimeters, there are numerous factors and characteristics to consider. The material sensitivity to radiation is the major important factor. The material's susceptibility to radiation interaction is crucial.<sup>8,23</sup> In this study, we need a material with highly sensitive  $\gamma$ -rays radiation used as gamma dosimetry within the dose limits necessary for the specific applications. In this context, polymers with better surface and bulk properties have been more important during the past few decades, because of their low weight, low cost, easy processability, and ease of fabrication of thick and thin samples.<sup>24</sup> The structural changes caused by high-energy radiation interactions with polymeric materials, such as X-rays,  $\gamma$ -rays, neutrons, and electrons, may allow for some fine-tuning of the materials' optical, thermal, mechanical, dielectric, and conductivity properties. Many researchers have been examining the impact of irradiation on doped polymer composite materials to probe the special features.<sup>25</sup>

Due to its high transparency and excellent flexibility, polyvinyl alcohol (PVA), which has the general formula  $[-CH_2-CH(OH)-]_n$ , is a well-known polymer for numerous technical applications.<sup>26</sup> The composites used in the majority of PVA works are sufficiently sensitive to either low or high-energy radiations, which impart improved or degraded physicochemical properties.<sup>25</sup> For example, M. A. Ali Omer *et al.* have suggested the viability of using PVA/Cu<sub>2</sub>O composite films as radiation detectors and personal dosimeters based on optical changes sensitive to  $\gamma$ -rays emitted from <sup>60</sup>Co-source in the range of (0–12) Gy suitable in rural sectors and low-income nations.<sup>11</sup> I. M. Osman *et al.* show the effects of additive and gamma irradiation on the structural and optical properties of polyvinyl alcohol doped with silver nitrate.<sup>27</sup>

In this regard, porous PhCs have exceptional advantages over other ordinary PhCs.<sup>28</sup> Materials with voids or holes are said to be porous materials. Because they have large surface areas, variable pore sizes, and a narrow pore size distribution, porous materials are essential for study.<sup>29</sup> They can be applied in many different fields, including sensing, adsorption, and catalysis, because of these inherent features.<sup>30</sup> The amount of void or pore spaces in a material is measured by its porosity, which is defined as the ratio of void volume to total volume.<sup>31</sup> Porous silicon (PSi) is

a variety of silicon wafers that has nanopores added to their microstructure.<sup>21,32</sup> In 1994, Vincent used electrochemical etching to create the first PhC fabricated from PSi.<sup>33</sup> By electrochemically anodizing crystalline silicon in a solution of hydrofluoric HF acid, porous silicon is commonly produced. The porosity determined by the anodization current density. Lower refractive index values correspond to increased porosity. It is widely believed that the electrochemical etching process in the silicon/fluoride combination is self-limiting and only happens at the interface between porous Si and crystalline substrate, meaning that the already-etched porous layer is unaffected by subsequent electrochemical etching. Consequently, the depth of the porosity can be modified. Because of this, PS multilayers with various refractive index profiles can be produced. One-dimensional photonic structures can be easily and inexpensively fabricated in this way. It has been demonstrated that a shift in the photonic feature can provide a very sensitive method for the detection of any change in the material (the optical properties of the doped polymer) that can enter the pores. The spectral peak position of a multilayer is strongly influenced by the average refractive indices of the layers.<sup>34</sup> Additionally, numerous benefits of the PSi-1DPhCs can appear in the form of their large specific surface area, ease of manufacture, and compatibility with conventional microelectronics processing.<sup>34,35</sup>

Reliance on all of the aforementioned, we present here a new theoretical investigation of the  $\gamma$ -ray radiation dosimeter based on a 1D-PSi-PhC structure with a central defect layer. We are choosing 1D-PhCs due to the low cost and variety of applications.<sup>36,37</sup> The suggested design contains two PSi-layers with different porosity, and thicknesses, besides PVA-polymer containing (CV + CF) as a defect layer. In addition, the pores of these two PSi-layers were infiltrated by PVA-polymer-containing (CV + CF). After this, we investigate the transmittance spectrum of our sensor depending on the theoretical methods that will be explained in the next part. Then we go to the result and discussion part, in which we explain how gamma rays affect the structure and materials emitted from a <sup>60</sup>Co-radioactive source in the range of (0–70 Gy). Also, we show how the PSi-layer changed the refractive index of the doped PVA-polymer, and how the porosity of the PSi-layer affects the refractive index of the doped PVA-polymer. Then, we considered the effect of the  $\gamma$ -ray doses on the resonance wavelength present in PBG, and the performance of our sensor. Also, we study the effect of the geometrical parameters of our sensor such as the effect of the thicknesses of the materials composing this sensor on the resonance wavelength and the sensitivity of our sensor. According to this study, we choose the optimum value for each parameter which gives high values for performance parameters. Additionally, one of the most significant factors impacting the transmittance spectrum of a 1D-PSi-PhCs is the angle of incidence. It is therefore expected to have a significant impact on the defect mode and consequently the 1D PSi PhCs-based sensor. Also, we show how the porosity of the first and the second PSi-layers effect on the position and the intensity of the resonance wavelength. Finally, the novelty of this paper concludes in the use of the defective 1DPhC based on porous silicon infiltrated by a doped-polymer for the detection of



gamma-ray radiation with the highest sensitivity without changing the experimental data of the optical properties of the doped polymer.

## Basic equations and model design

Fig. 1, shows a schematic diagram of a one-dimensional binary PhCs with a defect layer in the form  $[\text{Air}/(\text{AB})^{N_1} \text{D} (\text{AB})^{N_2}/\text{substrate}]$ , where A, B, and D are the  $\text{PSi}_1$ ,  $\text{PSi}_2$ , and the defect layer, respectively. The popular experimental methods for creating PhCs or defective 1DPhCs are layer-by-layer deposition,<sup>38</sup> anodic oxidation procedure,<sup>39,40</sup> colloid self-assembly technology,<sup>41</sup> and glancing angle deposition.<sup>42</sup> Among them, the anodic oxidation procedure would be worth investigating as a highly efficient and low-cost method to prepare the DPCs integral formation because it is relatively simple to create a defective layer by adjusting the periodic voltage waveform.<sup>39,40</sup>

In fact, many theoretical methods, including the transfer matrix method, finite-element method, and plane-wave expansion method, have been proposed for determining the optical properties of PhCs in 1D, 2D, and 3D. But when compared to its counterparts, the transfer matrix (TMM) method is thought to be the most appropriate for analyzing the cases of 1DPhCs.

where,  $t$  is the transmittance coefficient, then the parameters ( $P_o$ ) and ( $P_s$ ) are utilized to define the optical characteristics of the starting medium (air) and substrate for a transverse electric polarization, respectively such that: -

$$P_o = n_o \cos \theta_o, \text{ and } P_s = n_s \cos \theta_s \quad (2)$$

where,  $n_o$ ,  $n_s$  are the refractive index of air and substrate.  $m_{11}$ ,  $m_{12}$ ,  $m_{21}$ , and  $m_{22}$  are the elements of the final matrix of the proposed structure and could be written as the following equation.

$$m = (M_{\text{PSi}_1} M_{\text{PSi}_2})^{N_1} (M_{\text{Doped\_Polymer}}) (M_{\text{PSi}_1} M_{\text{PSi}_2})^{N_2} \\ = \begin{pmatrix} m_{11} & m_{12} \\ m_{21} & m_{22} \end{pmatrix} \quad (3)$$

where,  $M_{\text{PSi}_1}$ ,  $M_{\text{PSi}_2}$ ,  $M_{\text{Doped\_Polymer}}$  is the characteristic matrix for  $\text{PSi}_1$ ,  $\text{PSi}_2$ , and doped polymer (defect layer) donated by  $M_j$ . These matrices are essentially described by the incident angle, the wavelength of the incident electromagnetic waves, the thickness of the specified layer, and its refractive index. The interaction of electromagnetic waves through individual layers (j) can be described as the following equation:<sup>36,41–43</sup> -

$$M_j = \begin{pmatrix} \cos\left(\left(\frac{2\pi d_j}{\lambda}\right)(n_j \cos \theta_j)\right) & -i\left(\frac{c}{n_j \cos \theta_j}\right) \sin\left(\left(\frac{2\pi d_j}{\lambda}\right)(n_j \cos \theta_j)\right) \\ -i\left(\frac{n_j \cos \theta_j}{c}\right) \sin\left(\left(\frac{2\pi d_j}{\lambda}\right)(n_j \cos \theta_j)\right) & \cos\left(\left(\frac{2\pi d_j}{\lambda}\right)(n_j \cos \theta_j)\right) \end{pmatrix} \quad (4)$$

Based on the Maxwell equations and the boundary conditions, this method was frequently used to determine the transmittance spectrum of the electromagnetic waves that were propagating in 1DPhCs.<sup>43–45</sup> The transmittance spectrum is investigated for the 1D-PhCs in the presence of a doped polymer as a defect layer as the following equation.

$$T = \frac{P_s |t|^2}{P_o} = \frac{2P_o}{(m_{11} + m_{12}P_s)P_o + m_{21} + m_{22}P_s} \quad (1)$$

where,  $c$ ,  $\lambda$ ,  $\theta_j$ ,  $d_j$ , and  $n_j$  describe the velocity of light in a vacuum, the wavelength of the incident photons, the angle of incidence through each layer j, the thickness of layer j, and its refractive index, respectively.

Then, to determine the refractive index of the porous silicon layer, the approximation of Bruggeman's effective medium can be used as the following:<sup>21,46</sup>




Fig. 1 Schematic diagram of the 1D-defective PhC. The structure of 1D-DPhC is surrounded by air and glass substrate.



$$n_{\text{(PSi)}} = 0.5 \sqrt{\epsilon + \sqrt{\epsilon^2 + (8n_{\text{(Si)}}^2 n_{\text{(Polymer)}}^2)}} \quad (5)$$

$$\epsilon = 3P(n_{\text{(Polymer)}}^2 - n_{\text{(Si)}}^2) + (2n_{\text{(Si)}}^2 - n_{\text{(Polymer)}}^2) \quad (6)$$

where,  $n_{\text{Si}}$ ,  $n_{\text{Polymer}}$ , and  $P$  are the refractive index of the silicon, the refractive index of the doped polymer inside the pore of the whole PSi layer, and the porosity ratio, respectively. The refractive index of the doped polymer used as a defect layer and infiltrated into the whole PSi layer is calculated by the fitting experimental data. According to the ref. 1, utilizing a solvent casting technique, film samples of the polymer, poly vinyl alcohol, carbol fuchsin, and crystal violet were prepared. These films were exposed to varying doses of  $^{60}\text{Co}$ -source radiation (10, 20, 30, 40, 50, 60, and 70 Gy) at room temperature.

The following fitted equation can be used to express the refractive index of the doped polymer by applying cubic fitting to the experimental data of the refractive index of the doped polymer at various  $\gamma$ -ray doses.<sup>1</sup>

$$n_{\text{D(Polymer)}} = \alpha\lambda^3 + \beta\lambda^2 + \gamma\lambda + \delta \quad (7)$$

where Table 1 lists the values for the constants  $\alpha$ ,  $\beta$ ,  $\gamma$ , and  $\delta$ . With gamma-ray radiation doses ranging from 0 Gy (unirradiated sample) to 70 Gy, the fitting's R-square value is equal to 0.015963.

Then, the values of several factors, such as the sensitivity ( $S$ ), the figure of merits (FOM), the quality factor ( $Q$ ), signal-to-noise ratio (SNR), detection limit (DL), and sensor resolution (SR) could be utilized to describe the effectiveness and performance of any sensor type. The following equations can be used to acquire these parameters.<sup>29,47</sup>

$$S = \frac{\Delta\lambda_{\text{res}}}{\Delta n_{\text{Polymer}}} \quad (8)$$

$$\text{QF} = \left( \frac{\lambda_{\text{res}}}{\Delta\lambda_{1/2}} \right) \quad (9)$$

$$\text{SNR} = \left( \frac{\Delta\lambda_{\text{res}}}{\Delta\lambda_{1/2}} \right) \quad (10)$$

$$\text{DL} = \left( \frac{\lambda_{\text{res}}}{20 S(\text{QF})} \right) \quad (11)$$

$$\text{SR} = (\text{DL})(S) \quad (12)$$

$$\text{FOM} = \left( \frac{S}{\Delta\lambda_{1/2}} \right) \quad (13)$$

where the resonance wavelength  $\lambda_{\text{res}}$ , and the refractive index of the doped polymer ( $n_{\text{Polymer}}$ ) for the unirradiated sample (0 Gy) were used as references to calculate  $\Delta\lambda_{\text{res}}$ , and  $\Delta n_{\text{Polymer}}$  of irradiation samples after exposure to  $\gamma$ -ray doses. For example,  $\Delta\lambda_{\text{res(10 Gy)}} = \lambda_{\text{res(10 Gy)}} - \lambda_{\text{res(0 Gy)}}$ , and  $\Delta n_{\text{Polymer(10 Gy)}} = n_{\text{Polymer(10 Gy)}} - n_{\text{Polymer(0 Gy)}}$ .  $\lambda_{1/2}$  is the full width at half the maximum of the resonance wavelength.

## Results and discussion

Based on the TMM and using MATLAB R2019a software, the transmittance spectrum of the proposed 1D-DPhCs based on PSi-layer is simulated. The spectral range in the visible wavelength for a transverse electric polarization (s-polarization or TE mode) is adopted. The incident radiation at an angle of incidence ( $\theta_0$ ) is perpendicular to the plane of incidence. The refractive indices of the Si, air, and glass, are  $n_{\text{Si}} = 3.7$ ,  $n_{\text{Air}} = 1$ , and  $n_{\text{g}} = 1.52$ , respectively.<sup>43</sup> The refractive index of the PSi and the defect layer (polymer) are considered based on eqn (5)–(7). The thickness of the first layer (PSi<sub>1</sub>), the second layer (PSi<sub>2</sub>), and the defect layer are, respectively,  $d_1 = 30$  nm,  $d_2 = 73$  nm, and  $d_3 = 285$  nm. The porosity of the first layer (PSi<sub>1</sub>), and the second layer (PSi<sub>2</sub>) are  $P_1 = 30\%$ , and  $P_2 = 80\%$ , respectively. For optimization, the period of numbers of the 1st PhC, and 2nd PhC are chosen to be  $N_1 = 17$ , and  $N_2 = 17$ , respectively. Fig. 1, shows that the polymer will be infiltrated the pores of the PSi layers and the defect layer. The sensing mechanism of our structure may be used as a gamma-ray dosimeter. One of the main objectives of this study is to create a radiation-resistant structure for use in nuclear environments for temperature and tension-sensing applications. On the experimental side, gamma-ray radiation affects the materials and the dimensions of our structure.<sup>48,49</sup> The principal materials in our dosimeter are the doped polymer and the porous silicon layer. It is important to note that at an irradiation dose of 1000 kGy, the change in the Si refractive index is less than  $(5 \times 10^{-5})$ .<sup>48</sup> Additionally, at 32 °C and 66.5 kGy, the thermo-optic coefficient of Si is equivalent to  $(2.3 \times 10^{-4} \text{ K}^{-1})$ .<sup>48,50</sup> The radiation thermal effect can raise the temperature of Si by a maximum of 3.2 °C.<sup>51</sup> As a result, the change in Si's refractive index produced by the radiation process for doses between 0 and 70 Gy can be disregarded. Accordingly, any change in the optical properties of our dosimeter is due to the change in the optical properties of the doped polymer only as a result of the influence of doses of gamma rays between 0 and 70 Gy. The effect of gamma-ray radiation on the geometrical dimensions of our dosimeter is also disregarded. This is because Si has a low thermal expansion coefficient ( $\approx 2.6 \times 10^{-6} \text{ K}^{-1}$ ). In particular, the exposure of the designed structure with a dose of 66.5 kGy could raise its temperature 3.2 °C over the room temperature.<sup>49</sup> However, this increase is not effective on the thicknesses of the constituent materials due to their very small thermal expansion coefficients. As a result, the expanding in the thicknesses of these materials

**Table 1** Constants for the doped polymer's refractive index are provided as a function of wavelength at various gamma-ray doses (Gy)

$D_{\gamma}$ (Gy)	$\alpha$ ( $\text{nm}^{-3}$ )	$\beta$ ( $\text{nm}^{-2}$ )	$\gamma$ (nm)	$\delta$
0	$1.7479 \times 10^{-7}$	−0.00025167	0.11796	−15.571
10	$1.5689 \times 10^{-7}$	−0.00022845	0.1083	−14.282
20	$1.3002 \times 10^{-7}$	−0.00019042	0.090693	−11.606
30	$1.2167 \times 10^{-7}$	−0.00017806	0.084739	−10.663
40	$1.0444 \times 10^{-7}$	−0.00015298	0.07293	−8.87
50	$1.013 \times 10^{-7}$	−0.00014864	0.070913	−8.5343
60	$9.754 \times 10^{-8}$	−0.00014305	0.068283	−8.1388
70	$9.6042 \times 10^{-8}$	−0.00014056	0.067049	−7.9382





is not exceeding  $10^{-5}$  nm. This result can be simply investigated from the equation ( $\Delta d = d_0 \alpha \Delta T$ ). Thus, it is also possible to ignore the thermal strain produced by radiation. In conclusion, we believe that the suggested structure can measure gamma-ray radiation without being damaged.

Fig. 2, illustrates the transmittance spectrum of the proposed 1D-PhC without a defect layer and with a defect layer (1D-DPhC). The values of the different geometrical parameters for the two structures are listed in Table 2. In order to achieve the best sensor performance, these parameters are calculated after optimization. We see that in the case of 1D-PhC without a defect layer, the PBG formed in the visible region with a width equal ( $\Delta\lambda = 678.729 - 527.486 = 151.240$  nm). In addition, the intensity of the left band edge, and the right band edge equal 96%, and 95%, respectively. By inserting the doped polymer as a defect layer into the structure, the defect mode (resonance wavelength) is found at wavelength 548.365 nm with an intensity of 80%. In addition, the characteristics of the PBG are enhanced, where the width of the PBG becomes 159.53 nm, the intensity of the left band edge, and the right band edge reached 100%, and these band edges of the PBG become sharp. This defect mode is the mainstay of our designed sensor. In another word, the shift in the position of this resonant peak due to the radiation exposure describes the strategy towards the utilization

of such design in the sensing and detection of Gamma radiation.

The mechanism of the proposed 1D-DPhC is based on the effect of  $\gamma$ -ray radiation on the refractive index of the doped polymer. This refractive index variation leads to a defect mode (resonance wavelength) shift in the transmittance spectrum. Before studying the effect of the doses of  $\gamma$ -ray radiation on our sensor, we need to show the effect of these doses on the refractive index of the material which constituted our sensor. In addition, we show the reason for choosing porous silicon material in our structure. Fig. 3a, shows the refractive index of the doped polymer *versus* the doses of  $\gamma$ -ray radiation from (0 to 70 Gy) at the wavelength ( $\lambda = 548.365$  nm). The refractive index of the doped polymer ( $n_{\text{(PVA/CV+CF)}}$ ) increases gradually as the  $\gamma$ -ray doses increase. Where,  $n_{\text{(PVA/CV+CF)}}$  increases from 2.258 to 2.399, when  $\gamma$ -ray doses increase from (0 to 70 Gy). According to Born and Wolf's theory, the non-enhancement of the polymer's anisotropic properties results from the development of covalent connections between different chains, which explains the increase in the polymer's refractive index after irradiation.<sup>52</sup> In addition, the increase in the polymer's refractive index following irradiation may be the result of ionization and/or atomic displacements caused by a gamma-ray collision with the samples, which may change the internal structure of the polymer films.<sup>1</sup> Fig. 3b, shows the refractive index of the porous silicon infiltrated by doped polymer *versus* the doses of  $\gamma$ -ray radiation from 0 to 70 Gy at the wavelength ( $\lambda = 548.365$  nm). It is evident that, the PSI-layer enhanced the polymer's refractive index. Where, the refractive index increases from 2.258 to 2.949 at  $\gamma$ -ray doses equal to 0 Gy, and from 2.399 to 3.025 at  $\gamma$ -ray doses equal to 70 Gy in the case of PSI-layer. Wherein, the refractive index of porous silicon is dependent on the refractive index of silicon, the refractive index of the material inside the pores (doped polymer), and the porosity value, according to Bruggeman's effective-medium approximation as eqn (5) and (6). The relationship between the PSI's refractive index and porosity variation is represented in Fig. 3c. For all wavelength values in the visible range, the refractive index of the PSI will decrease as the porosity value increases as investigated in Fig. 3d. In particular, PSI with low porosity could receive increased values of the refractive index compared to those at high porosity. Also, the PSI's refractive index decreases linearly with increasing the values of porosity after exposure to  $\gamma$ -ray doses from (0 to 70 Gy), as shown in Fig. 3d. We note that at the same value of porosity, the PSI's refractive index increases with an increase in the  $\gamma$ -ray doses. For example: at  $P = 30\%$ , the PSI's refractive index is equal to 3.251, 3.266, 3.277, and 3.288 at  $\gamma$ -ray doses equal to 0, 20, 40, and 60 Gy, and at  $P = 80\%$ , the PSI's refractive index equal 2.517, 2.558, 2.589, and 2.616 at  $\gamma$ -ray doses equal 0, 20, 40, and 60 Gy. After we saw the effect of the porosity ratio on the refractive index of the porous silicon layer, we chose the optimization value for each layer of porous silicon layers that achieve the highest performance of our sensor.

Briefly, the principle of the sensing mechanism depends on the variation of the refractive index of the doped polymer which is used as a defect layer induced by exposure to  $\gamma$ -ray doses from




Fig. 2 Transmittance spectrum of 1D-binary and defective structure with doped PVA-polymer as a defect layer, at zero gamma-ray radiation.

Table 2 The values of the geometrical parameters of the proposed structures

Geometrical parameters	
Values of 1D-PhC	Values of 1D-DPhC
$d_1 = 30$ (nm) $d_2 = 73$ (nm)	$d_1 = 30$ (nm) $d_2 = 73$ (nm)
$P_1 = 30\%$ $P_2 = 80\%$ $N = 35$	$d_3 = 285$ (nm) $P_1 = 30\%$
	$P_2 = 80\%$ $N_1 = N_2 = 17$




Fig. 3 (a) Variation in the doped polymer's refractive index as a function of  $\gamma$ -ray doses from (0 to 70 Gy), confined with ref. 1. (b) Variation in the PSi layer's refractive index as a function of  $\gamma$ -ray doses from (0 to 70 Gy), and (c) porosity ratio. At wavelength ( $\lambda = 548.365$  nm). (d) The effect of porosity on the PSi layer's refractive index at (0 Gy).

(0 to 70 Gy). This reflects on the position of the defect mode which presents in PBG.

Fig. 4a, shows the effect of  $\gamma$ -ray doses from (0 to 70 Gy) on the resonance wavelength with the same geometrical parameters which presents in Table 2. We note that with increases in the value of  $\gamma$ -ray doses, the resonance wavelength shifts to a higher wavelength, and the intensity of the resonance wavelength slightly decreases. This appears in Fig. 4b, when  $\gamma$ -ray

doses equal 0, 20, 40, and 60 Gy, the position of the resonance wavelength equals 548.365, 556.184, 562.627, and 568.213 nm, and the intensity of the resonance wavelength equals 80.756%, 79.448%, 78.338%, and 77.355%, respectively. This response is essentially dependent on the role of such parameters on the optical path length of the incident photons through the designed structure. In another meaning, the increase in the radiation dose leads to significant increments in the indices of




Fig. 4 (a) The effect of gamma-ray radiation on the transmittance spectrum of our sensor. (b) The resonance wavelength and the sensitivity at different  $\gamma$ -doses (Gy) from (0–70 Gy).






Fig. 5 The initial performance of our gamma-ray radiation sensor.

refraction of both doped polymer and PSi as well as investigated in Fig. 3a and b, respectively. Thus, the shift in the position of the resonant wavelength and the PBG as well is expected to keep the condition of constant phase shift.<sup>17,18,20,38</sup> Several parameters, including the sensitivity ( $S$ ), the figure of merit (FoM), signal-to-noise ratio (SNR), single resolution (SR), detection limit (LD), and quality factor (Q.F), can be used to determine the effectiveness and the performance of this gamma-ray radiation sensor. These parameters' mathematical relationships can be calculated as mentioned in eqn (8)–(13). As we notice in Fig. 5, the behavior for each performance parameter appears in the accuracy of our sensor along with applied doses of  $\gamma$ -ray radiation. The values of these parameters are present in Table 3 at different doses of  $\gamma$ -ray radiation. Find the maximum value for the sensitivity of this sensor equal to  $180.970 \text{ (nm RIU}^{-1}\text{)}$ .

The performance of our suggested gamma-ray radiation sensor will be improved with the help of the optimization approach which describe in the following figures. To do this, the sensitivity values will be computed using the different

design parameters, such as the thicknesses of the first, the second, and the defect layers. So, the geometrical parameters are studied to maximize the resonance wavelength (defect mode) shift and, consequently, the sensor sensitivity at various  $\gamma$ -ray radiation doses. Fig. 6a–d show the effect of the thickness of the first layer PSi<sub>1</sub> on the resonance wavelength. While the other parameters remain constant, the impact of the thickness of the first layer PSi<sub>1</sub> with values of (31, 33, 35, and 36 nm) at various doses (0, 10, 30, and 60 Gy) will be studied. We note that, at the same  $\gamma$ -dose, the position of resonance wavelength shifts to a higher wavelength with an increase in the thickness of the first layer. Eg; At  $\gamma$ -dose is equal (0 Gy), with an increase of  $d_1$  (31, 33, 35, and 36 nm), the values of ( $\lambda_{\text{res}}$ ) will be (552.227, 560.718, 570.939, and 577.361 nm), respectively. Also, Fig. 6b–d give the same behavior as Fig. 6a, but at different  $\gamma$ -doses. These figures show that the value of ( $\lambda_{\text{res}}$ ) increases with increasing the value of  $\gamma$ -doses at the same thickness as the first layer. Fig. 7a, show the resonance wavelength *versus* the doses of  $\gamma$ -ray radiation from (0 to 70 Gy) at different thicknesses of the

Table 3 The initial optimum performance parameters are summarized in this table

D (Gy)	$\lambda_{\text{res}}$ (nm)	Intensity of $\lambda_{\text{res}}$ %	$\Delta\lambda_{\text{res}}$ (nm)	$\Delta\lambda_{1/2}$ (nm)	$S(\text{nm RIU}^{-1})$	Q.F	SNR	DL (RIU)	SR	FOM ( $\text{RIU}^{-1}$ )	$n(d)$	$\Delta n(d)$
0	548.3655	0.80756	—	0.0452	—	12 131	—	—	—	—	2.2580	—
10	552.0392	0.80147	3.6737	0.0503	180.9704	10 974.93	73.035	$2.78 \times 10^{-5}$	$2.78 \times 10^{-3}$	3597.82	2.2783	0.0203
20	556.1842	0.79448	7.8187	0.0578	180.5704	9622.56	135.27	$3.20 \times 10^{-5}$	$5.77 \times 10^{-3}$	3124.05	2.3013	0.0433
30	559.2781	0.78918	10.9126	0.0667	180.3735	8384.97	163.60	$3.69 \times 10^{-5}$	$6.65 \times 10^{-3}$	2704.25	2.3185	0.0605
40	562.6278	0.78338	14.2623	0.0771	179.8524	7297.37	184.98	$4.28 \times 10^{-5}$	$7.69 \times 10^{-3}$	2332.71	2.3373	0.0793
50	565.3367	0.77864	16.9712	0.0855	179.3995	6612.12	198.49	$4.76 \times 10^{-5}$	$8.53 \times 10^{-3}$	2098.23	2.3526	0.0946
60	568.2135	0.77355	19.848	0.0985	179.1335	5768.66	201.50	$5.49 \times 10^{-5}$	$9.83 \times 10^{-3}$	1818.61	2.3688	0.1108
70	573.6865	0.76374	25.321	0.1288	178.4425	4454.08	196.59	$7.21 \times 10^{-5}$	$12.86 \times 10^{-3}$	1385.42	2.3999	0.1419




Fig. 6 The resonance wavelength at different thicknesses of the first layer at, (a)  $D_\gamma = 0$  Gy, (b)  $D_\gamma = 10$  Gy, (c)  $D_\gamma = 30$ , and (d)  $D_\gamma = 60$  Gy. Where,  $d_2 = 73$  nm,  $d_3 = 285$  nm  $N_1 = N_2 = 17$ , and porosity  $P_1 = 30\%$ ,  $P_2 = 80\%$ .

first layer. Also, Fig. 7b, shows the sensitivity of our sensor *versus* the doses of  $\gamma$ -ray radiation from (0 to 70 Gy) at different thicknesses of the first layer. Based on this study, we choose the thickness of the first layer with a value of 31 nm as the optimum value for our sensor. Because of this value give sensitivity with very high stability along applied  $\gamma$ -ray radiation. So, this value will be fixed in all subsequent studies.

The effect of the thickness of the second layer on the resonance wavelength is demonstrated in Fig. 8a–d. These figures give the same behavior as the previous figures which describe the effect of the thickness of the first layer. The difference concludes in the maximization of the position of the resonance wavelength at each thickness of the second layer compared to the thickness of the first layer, this leads to enhancing the




Fig. 7 (a and b) Variation in the resonance wavelength and the sensitivity of our sensor as a function of  $\gamma$ -ray doses from (0 to 70 Gy) at different thicknesses of the first layer, respectively.








Fig. 8 The resonance wavelength at different thicknesses of the second layer at, (a)  $D_\gamma = 0$  Gy, (b)  $D_\gamma = 10$  Gy, (c)  $D_\gamma = 30$ , and (d)  $D_\gamma = 60$  Gy. Where,  $d_1 = 31$  nm,  $d_3 = 285$  nm  $N_1 = N_2 = 17$ , and porosity  $P_1 = 30\%$ ,  $P_2 = 80\%$ .




Fig. 9 (a and b) Variation in the resonance wavelength and the sensitivity of our sensor as a function of  $\gamma$ -ray doses from (0 to 70 Gy) at different thicknesses of the second layer, respectively.

sensitivity of our sensor and other performance parameters. For more details, Fig. 9a, shows the behavior of the resonance wavelength *versus* the doses of  $\gamma$ -ray radiation from (0 to 70 Gy) at different thicknesses of the second layer. Fig. 9b, demonstrated the sensitivity of our sensor. We note that the sensitivity increases with increasing the thickness of the second layer along with applied  $\gamma$ -ray radiation. Based on this figure, we

chose the thickness of the second layer with a value of 75 nm as the optimum value for our sensor. Because of this value give sensitivity with high stability compared to other values, along with applied  $\gamma$ -ray radiation.

The effect of defect layer thickness to maximize the resonance wavelength shift and improved sensitivity is shown in Fig. 10, and 11. Fig. 10a–d demonstrated the effect of the defect




Fig. 10 The resonance wavelength at different thicknesses of the defect layer at, (a)  $D_\gamma = 0$  Gy, (b)  $D_\gamma = 10$  Gy, (c)  $D_\gamma = 30$ , and (d)  $D_\gamma = 60$  Gy. Where,  $d_1 = 31$  nm,  $d_2 = 75$  nm,  $N_1 = N_2 = 17$ , and porosity  $P_1 = 30\%$ ,  $P_2 = 80\%$ .




Fig. 11 (a and b) Variation in the resonance wavelength and the sensitivity of our sensor as a function of  $\gamma$ -ray doses from (0 to 70 Gy) at different thicknesses of the defect layer, respectively.

layer thickness on the resonance wavelength. This study is under the optimum previous values. As shown in Fig. 10a–d, with an increase in the thickness of the defect layer the resonance wavelength shift to a higher value along applied different doses of  $\gamma$ -ray radiation. Fig. 11a, and b show the variation in the resonance wavelength and the sensitivity of our sensor as a function of  $\gamma$ -ray doses from (0 to 70 Gy) at different

thicknesses of the defect layer, respectively. Based on these results, 290 nm should be the optimal value for the defect layer thickness.

Based on the above findings, the final performance parameters of our sensor are demonstrated at different  $\gamma$ -ray radiation in Fig. 12. The higher value of the sensitivity is 205.790 (nm RIU<sup>-1</sup>) at  $\gamma_D = 70$  Gy. Where the value of sensitivity increases






Fig. 12 The final performance of our sensor.

with increasing the doses of  $\gamma$ -ray radiation. This sensor also has a detection limit in the range of  $(2-5) \times 10^{-5}$  for the  $\gamma$ -ray radiation range of (0–70 Gy), which is a crucial parameter indicating how the sensor can detect the smallest changes in doses of  $\gamma$ -ray radiation. The sensor's excellent resolution of all resonance wavelengths for any doses of  $\gamma$ -ray radiation is also indicated by the sensor's low FWHM values (less than 0.1922 nm), which are low values that suggest the sensor has a very good resolution (Fig. 12). Moreover, QF is found to decrease with increasing doses of  $\gamma$ -ray radiation but remains as high as 8615.966. Finally, we highlight this high performance in Table 4. When comparing Table 4 with Table 3, we found how the geometric parameters improved the performance parameters of our sensor. The linear fitting of the performance parameters after optimization can be given according to the following equations:

$$S = -1.0737 \times 10^{-6} D_{\gamma}^5 + 0.000234 D_{\gamma}^4 - 0.01866 D_{\gamma}^3 + 0.65011 D_{\gamma}^2 - 8.5398 D_{\gamma} + 196.47 \quad (14)$$

$$\text{SNR} = 2.0896 \times 10^{-7} D_{\gamma}^5 - 6.1066 \times 10^{-5} D_{\gamma}^4 + 0.0064661 D_{\gamma}^3 - 0.36379 D_{\gamma}^2 + 12.53 D_{\gamma} - 45.433 \quad (15)$$

$$\text{SR} = 2.4924 \times 10^{-9} D_{\gamma}^4 - 3.4323 \times 10^{-7} D_{\gamma}^3 + 1.67 \times 10^{-5} D_{\gamma}^2 - 0.00027176 D_{\gamma} + 0.0046486 \quad (16)$$

$$\text{DL} = 9.4697 \times 10^{-12} D_{\gamma}^4 - 1.3096 \times 10^{-9} D_{\gamma}^3 + 6.63 \times 10^{-8} D_{\gamma}^2 - 1.1977 \times 10^{-6} D_{\gamma} + 2.71 \times 10^{-5} \quad (17)$$

$$\text{FOM} = -7.6129 \times 10^{-6} D_{\gamma}^5 + 0.001159 D_{\gamma}^4 - 0.054938 D_{\gamma}^3 + 0.45096 D_{\gamma}^2 + 4.0757 D_{\gamma} + 2387.2 \quad (18)$$

$$\text{Q. F} = 2.581 \times 10^{-6} D_{\gamma}^6 - 0.00059 D_{\gamma}^5 + 0.0525 D_{\gamma}^4 - 2.1889 D_{\gamma}^3 + 44.135 D_{\gamma}^2 - 481.17 D_{\gamma} + 10735 \quad (19)$$

In the following, we study how the resonance wavelength is affected by the angle of incidence and the porosity of two PSI layers. In addition, we explain why we used the values that we specified in Table 1. The angle of incidence as a function of the

Table 4 The final optimum performance parameters are summarized in this table

$D$ (Gy)	$\lambda_{\text{res}}$ (nm)	Intensity of $\lambda_{\text{res}}$ %	$\Delta\lambda_{\text{res}}$ (nm)	$\Delta\lambda_{1/2}$ (nm)	$S$ (nm RIU $^{-1}$ )	Q. F	SNR	DL (RIU)	SR	FOM (RIU $^{-1}$ )	$n_{\text{(d)}}$	$\Delta n_{\text{(d)}}$
0	562.829	0.81564	—	0.060	—	9380.483	—	—	—	—	2.2580	—
10	566.069	0.8106	3.24	0.0657	159.6059	8615.966	49.315	$2.05 \times 10^{-5}$	$3.27 \times 10^{-3}$	2429.31	2.2783	0.0203
20	570.2238	0.80403	7.3948	0.0721	170.7806	7908.790	102.56	$2.11 \times 10^{-5}$	$3.60 \times 10^{-3}$	2368.66	2.3013	0.0433
30	573.9897	0.7979	11.1607	0.0842	184.4743	6816.979	132.54	$2.28 \times 10^{-5}$	$4.20 \times 10^{-3}$	2190.90	2.3185	0.0605
40	578.031	0.79138	15.202	0.099	191.7023	5838.696	153.55	$2.58 \times 10^{-5}$	$4.94 \times 10^{-3}$	1936.38	2.3373	0.0793
50	580.8495	0.78672	18.0205	0.1107	190.4915	5247.059	162.78	$2.90 \times 10^{-5}$	$5.52 \times 10^{-3}$	1720.79	2.3526	0.0946
60	584.5780	0.78047	21.749	0.132	196.2906	4428.621	164.76	$3.36 \times 10^{-5}$	$6.59 \times 10^{-3}$	1487.05	2.3688	0.1108
70	592.0307	0.7677	29.2017	0.1922	205.7906	3080.284	151.93	$4.66 \times 10^{-5}$	$9.58 \times 10^{-3}$	1070.71	2.3999	0.1419






Fig. 13 The effect of incidence angle on resonance wavelength at, (a)  $D_\gamma = 0$  Gy, (b)  $D_\gamma = 10$  Gy, (c)  $D_\gamma = 30$ , and (d)  $D_\gamma = 60$  Gy. Where,  $d_1 = 31$  nm,  $d_2 = 73$  nm,  $d_3 = 290$  nm  $N_1 = N_2 = 17$ , and porosity  $P_1 = 30\%$ ,  $P_2 = 80\%$ .

wavelength at different doses of  $\gamma$ -ray radiation is studied in Fig. 13a–d. Bragg-Snell law can be used to describe the impact of adjusting the incidence angle on the location of the resonance wavelength.<sup>53</sup> Fig. 13a, it can be observed that with an increase in the value of the incidence angle, the resonance wavelength shifts gradually to the lower wavelength at the same dose of  $\gamma$ -ray radiation. Ex; At  $\gamma$ -dose is equal (0 Gy), with an increase of  $\theta_0$  ( $0^\circ$ ,  $10^\circ$ ,  $20^\circ$ , and  $30^\circ$ ), the values of  $(\lambda_{\text{res}})$  will be (562.828, 561.271, 556.980, and 550.857 nm), respectively. Also, Fig. 13b–d give the same behavior as Fig. 13a, but at different  $\gamma$ -doses. These figures show that the value of  $(\lambda_{\text{res}})$  increases with increasing the value of  $\gamma$ -doses at the same incidence angle. We found the decreasing in the shift of the resonance wavelength lead to decreasing the value of sensitivity and other performance parameters according to eqn (8)–(13).

Fig. 14a–d show the effect of the porosity of the first and the second PSI layers on the resonance wavelength. Where the other parameters equal  $d_1 = 31$  nm,  $d_2 = 75$  nm,  $d_3 = 290$  nm, and we consider the case of normal incidence. Fig. 14a and b, show the impact of the porosity of the first PSI-layer with values of (30, 35, 40, and 45%) at various doses (0, and 10 Gy). We note that, at the same  $\gamma$ -dose, the position of resonance wavelength shifts to a lower wavelength with an increase in the porosity of the first PSI-layer. Eg; At  $\gamma$ -dose is equal to (0 Gy) in Fig. 14a, with an

increase of  $P_1$  (30, 35, 40, and 45%), the values of  $(\lambda_{\text{res}})$  will be (562.829, 560.460, 557.882, and 555.442 nm), respectively. In addition, the full width at half the maximum of the resonance wavelength  $(\lambda_{1/2})$  increase with an increase in the porosity of the first PSI layer. This indicates to the sensitivity of our sensor decrease by increasing the porosity of the first PSI-layer according to eqn (8). Fig. 14c, and d, show the impact of the porosity of the second PSI-layer with values of (80, 82, 84, and 86%) at various doses (0, and 10 Gy). Also, Fig. 14c, and d, give the same behavior as Fig. 14a, and b. According to this behavior, we choose the porosity of the first and the second PSI-layers with a value of 30%, and 80% as the optimum value for our sensor. Because of this values give a high sensitivity with excellent resolution for our sensor. For this reason, we mentioned at the beginning of the study that the porosity of the first and the second PSI-layers with values of 30%, and 80%.

Finally, we contrast the performance of the suggested sensor with earlier works.<sup>8,24,27,54</sup> Compared to other common and more complex structures as shown in Table 5, we believe that our designed structure could be of valuable interest to the radiation communities as a simple, safe, and sensitive tool. Due to a significant contribution that has been devoted towards the fabrication of such devices. Meanwhile, the experimental verifications of the 1D PhCs attracted the






Fig. 14 (a and b) The effect of the porosity of the first layer on resonance wavelength at,  $D_{\gamma} = 0$  Gy, and  $D_{\gamma} = 10$  Gy, respectively. (c and d) The effect of the porosity of the second layer on resonance wavelength at,  $D_{\gamma} = 0$  Gy, and  $D_{\gamma} = 10$  Gy, respectively.

Table 5 A detailed comparison between our design and some earlier radiation dosimeters

Ref.	Sensitivity as present in paper	Based on	Type of paper
60	9.56 and, 12.67 pm/C	The effect of grating fabrication on the FBGs' radiation sensitivity	Experimental
27	None	The possibility for employing gamma-irradiated PVA/AgNO <sub>3</sub> films in many electrical and semiconductor applications	Experimental
61	None	The pure-silica-core photonic crystal fibres' (PSC-PCFs') steady-state gamma-ray radiation response under a cumulative dosage of 500 Gy and a dose rate of 2.38 Gy min <sup>-1</sup>	Experimental
62	None	The creation of porous silicon multilayers after gamma/ion irradiating silicon to create tunable distributed bragg reflectors (DBRs)	Experimental
63	None	The infiltration one-dimensional (1-D) porous silicon photonic crystals (PS-PhCs) with a green-emitting commercial luminescent polymer	Experimental
8	10 pm/C at 1550 nm	Optical fiber bragg grating sensors for gamma ray radiation	Experimental
64	150 (nm RIU <sup>-1</sup> )	2D-PhC for the detection of gamma-ray doses	Theoretical
27	None	Effects of additive and gamma irradiation on the structural and optical properties of the PVA\AgNO <sub>3</sub> films	Experimental
This work	205.7906 nm RIU <sup>-1</sup>	The doped PVA-polymer based on 1D-DPhC sensor for the detection of gamma-ray doses	Theoretical

attention of many researchers.<sup>55–58</sup> In particular, the performance of such a designed sensor is mainly dependent on the control of the constituent of the thicknesses of the layers. In addition, the utilization of PSi through the 1D PhCs for

sensing purposes is experimentally demonstrated.<sup>59</sup> Caroselli *et al.* fabricated a microcavity from PSi between two Bragg mirrors for sensing applications based on the electrochemical etching method.<sup>59</sup>





## Conclusion

The doped PVA-polymer based on 1D-DPhC sensor for the detection of  $\gamma$ -ray radiation in the visible range was designed for the first time. The sensing mechanism of this sensor is based on porous silicon and a doped PVA-polymer that infiltrates its pores. Once the sensor is exposed to  $\gamma$ -rays, the optical properties of the doped PVA-polymer will change, and therefore the optical properties of the porous silicon will change, and this is reflected on the transmittance spectrum and resonance wavelength of our sensor. By fitting the experimental data of the doped PVA-polymer, the Bruggeman's effective medium equation of PSI-layer, and the transfer matrix method for calculating the optical characteristics of the dosimeter structure, the theoretical analysis is studied. The numerical results indicated that the PSI-layers changed the doped PVA-refractive polymer's index. Additionally, they demonstrated how this radiation sensor works by showing how the resonance wavelength shifts when it is exposed to gamma rays. It was also examined how the PSI-layer thickness influences performance in order to achieve the highest sensitivity. In addition, the effect of incidence angle on the defect mode. We also explained why we used the values of the porosity of the two PSI-layers and their effect on the defect mode. The unique feature of this paper is that, when exposed to gamma-ray doses ranging from 0 to 70 Gy, the radiation sensor design obtained a high sensitivity of  $205.7906 \text{ nm RIU}^{-1}$  in the visible region. In addition, quality factor, signal-to-noise ratio, detection limit, sensor resolution, and figure of merit that have been obtained are 9380.483,  $\approx 49.315$ ,  $\approx 2.05 \times 10^{-5} \text{ RIU}$ ,  $\approx 3.27 \times 10^{-5}$ , and  $2429.31 \text{ RIU}^{-1}$ , respectively.

## Data availability

The datasets used and/or analyzed during the current study are available from the corresponding author on reasonable request.

## Author contributions

F. S. conceived the designs. A. H. A., F. S., H. E., A. M. and M. E. designed and conducted the analyses. F. S., H. E., A. M. conducted software. F. S., A. H. A., H. E., A. M. and M. E. analyzed the results. All authors reviewed the manuscript.

## Conflicts of interest

The authors declare no competing interests.

## References

- 1 E. M. Antar, Effect of  $\gamma$ -ray on optical characteristics of dyed PVA films, *J. Radiat. Res. Appl. Sci.*, 2014, 7, 129–134.
- 2 W. J. Cooper, R. D. Curry and K. E. O'Shea, *Environmental applications of ionizing radiation*, John Wiley & Sons, 1998.
- 3 K. Pushpavanam, E. Narayanan and K. Rege, Molecular and nanoscale sensors for detecting ionizing radiation in radiotherapy, *ChemNanoMat*, 2016, 2(5), 385–395.
- 4 D. Chmielewska, *Radiation methods and uses in nanotechnology. Applications of Ionizing Radiation in Materials Processing*, eds Sun Y. and Chmielewski A. G., 2017, pp. 395–414.
- 5 H. Erramli and J. El Asri, Gamma rays: applications in environmental gamma dosimetry and determination samples gamma-activities induced by neutrons, *Use of Gamma Radiation Techniques in Peaceful Applications*, 2019, vol. 109.
- 6 W. McLaughlin, *et al.*, *Dosimetry for radiation processing*, 1989.
- 7 E. A. A. Bashir, *Synthesis and Optimization of Polymer Film Detector (PVACu<sub>2</sub>O) in Radiation Therapy*, Sudan University of Science and Technology, 2018.
- 8 D. Baccini, *et al.*, Gamma irradiation response in photonic crystal and standard optical fiber Bragg grating sensors for radiation dosimetry, in *AOS Australian Conference on Optical Fibre Technology (ACOFT) and Australian Conference on Optics, Lasers, and Spectroscopy (ACOLS) 2019*, International Society for Optics and Photonics, 2019.
- 9 A. H. Aly, A. Mehaney and M. F. Eissa, Ionizing particle detection based on phononic crystals, *J. Appl. Phys.*, 2015, 118(6), 064502.
- 10 Z. S. Rozaila, *et al.*, Ge and B doped collapsed photonic crystal optical fibre, a potential TLD material for low dose measurements, *Radiat. Phys. Chem.*, 2016, 126, 9–13.
- 11 M. A. Ali Omer and E. A. Ali Bashir, Synthesis of polyvinyl alcohol and cuprous oxide (PVA/Cu<sub>2</sub>O) films for radiation detection and personal dosimeter based on optical properties, *J. Radiat. Res. Appl. Sci.*, 2018, 11(3), 237–241.
- 12 M. Afifi, *et al.*, Dosimetric impact of some gamma radiation-induced polymeric materials incorporated silicate using thermoluminescence and ultrasonic techniques, *Silicon*, 2021, 1–10.
- 13 S. O'Keeffe, *et al.*, A review of optical fibre radiation dosimeters, *Sens. Rev.*, 2008, 28(2), 136–142.
- 14 S. Avino, *et al.*, Ionizing radiation detectors based on Ge-doped optical fibers inserted in resonant cavities, *Sensors*, 2015, 15(2), 4242–4252.
- 15 F. Berghmans and A. Gusarov, Fiber Bragg grating sensors in nuclear environments. *Fiber Bragg grating sensors: recent advancements, industrial applications and market exploitation*, 2011, pp. 218–237.
- 16 M. Morante, *Fiber Bragg Grating sensors for harsh environments*, 2018.
- 17 A. Mehaney, H. A. Elsayed and A. M. Ahmed, *Detection of isoprene traces in exhaled breath by using photonic crystals as a biomarker for chronic liver fibrosis disease*, 2021.
- 18 M. M. Abadla, H. A. Elsayed and A. Mehaney, Thermo-optical properties of binary one dimensional annular photonic crystal including temperature dependent constituents, *Phys. E*, 2020, 119, 114020.
- 19 J. Haberko, L. S. Froufe-Pérez and F. Scheffold, Transition from light diffusion to localization in three-dimensional amorphous dielectric networks near the band edge, *Nat. Commun.*, 2020, 11(1), 1–9.



- 20 H. A. Elsayed and A. Mehaney, Theoretical verification of photonic crystals sensor for biodiesel detection and sensing, *Phys. Scr.*, 2020, **95**(8), 085507.
- 21 A. M. Ahmed and A. Mehaney, Ultra-high sensitive 1D porous silicon photonic crystal sensor based on the coupling of Tamm/Fano resonances in the mid-infrared region, *Sci. Rep.*, 2019, **9**(1), 1–9.
- 22 A. Chiappini, *et al.*, Photonic crystal stimuli-responsive chromatic sensors: a short review, *Micromachines*, 2020, **11**(3), 290.
- 23 D. Sporea, *et al.*, *Optical fibers and optical fiber sensors used in radiation monitoring*, 2012.
- 24 S. Raghuvanshi, *et al.*, Effect of gamma irradiation on the optical properties of UHMWPE (Ultra-high-molecular-weight-polyethylene) polymer, *Nucl. Instrum. Methods Phys. Res., Sect. B*, 2012, **271**, 44–47.
- 25 H. Chandrappa, *et al.*, Physico-chemical properties of PVA-Nile blue ( $C_{20}H_{20}ClN_3O$ ) polymer composite structures for  $\gamma$ -ray protection: A comparative  $\gamma$ -ray irradiation studies, *Radiat. Phys. Chem.*, 2021, **184**, 109481.
- 26 F. A. Mir, A. Gani and K. Asokan, Gamma irradiation studies of composite thin films of poly vinyl alcohol and coumarin, *RSC Adv.*, 2016, **6**(2), 1554–1561.
- 27 I. M. Osman, *et al.*, Effects of additive and gamma irradiation on the structural and optical properties of polyvinyl alcohol doped with silver nitrate, *Glob. Sci. J.*, 2021, **9**(6), 2054–2062.
- 28 X. Yue, *et al.*, Porous silicon photonic crystal/silver composite produced by microwave-assisted reduction: applications to surface-enhanced Raman scattering, *Opt. Mater.: X*, 2019, **2**, 100027.
- 29 Z. A. Zaky, A. Sharma and A. H. Aly, Tamm plasmon polariton as refractive index sensor excited by gyroid metals/porous  $Ta_2O_5$  photonic crystal, *Plasmonics*, 2022, **17**(2), 681–691.
- 30 F. A. Harraz, Porous silicon chemical sensors and biosensors: A review, *Sens. Actuators, B*, 2014, **202**, 897–912.
- 31 I. A. Levitsky, Porous silicon structures as optical gas sensors, *Sensors*, 2015, **15**(8), 19968–19991.
- 32 F. Zhong, *et al.*, Optical characteristics of porous silicon photonic crystals prepared on the back surface of silicon wafers, *Optik*, 2020, **201**, 163486.
- 33 G. Vincent, Optical properties of porous silicon superlattices, *Appl. Phys. Lett.*, 1994, **64**(18), 2367–2369.
- 34 M. Salem, *et al.*, Electrochemical stabilization of porous silicon multilayers for sensing various chemical compounds, *J. Appl. Phys.*, 2006, **100**(8), 083520.
- 35 H. Zhang, *et al.*, Optical nose based on porous silicon photonic crystal infiltrated with ionic liquids, *Anal. Chim. Acta*, 2017, **953**, 71–78.
- 36 A. H. Aly and F. A. Sayed, THz cutoff frequency and multifunction  $Ti_2 Ba_2 Ca_2 Cu_3 O_1$  0/G a A s photonic bandgap materials, *Int. J. Mod. Phys. B*, 2020, **34**(10), 2050091.
- 37 K. Maeno, *et al.*, Polymer-based photonic crystal cavity sensor for optical detection in the visible wavelength region, *Anal. Sci.*, 2016, **32**(1), 117–120.
- 38 R. A. Caruso, A. Sussha and F. Caruso, Multilayered titania, silica, and laponite nanoparticle coatings on polystyrene colloidal templates and resulting inorganic hollow spheres, *Chem. Mater.*, 2001, **13**(2), 400–409.
- 39 G. Wang, *et al.*, One-dimensional alumina photonic crystals with a narrow band gap and their applications to high-sensitivity concentration sensor and photoluminescence enhancement, *Superlattices Microstruct.*, 2015, **86**, 546–551.
- 40 P. Yan, *et al.*, Fabrication of one-dimensional alumina photonic crystals with a narrow band gap and their application to high-sensitivity sensors, *J. Mater. Chem. C*, 2013, **1**(8), 1659–1664.
- 41 K. Zhong, *et al.*, Defect mode passband lasing in self-assembled photonic crystal, *ACS Photonics*, 2016, **3**(12), 2330–2337.
- 42 S. R. Kennedy, *et al.*, Fabrication of tetragonal square spiral photonic crystals, *Nano Lett.*, 2002, **2**(1), 59–62.
- 43 F. A. Sayed, H. A. Elsayed and A. H. Aly, Optical properties of photonic crystals based on graphene nanocomposite within visible and IR wavelengths, *Opt. Quantum Electron.*, 2020, **52**(10), 1–16.
- 44 A. H. Aly, *et al.*, MATLAB Simulation-Based Theoretical Study for Detection of a Wide Range of Pathogens Using 1D Defective Photonic Structure, *Crystals*, 2022, **12**(2), 220.
- 45 M. Tammam, *et al.*, Defected photonic crystal array using porous GaN as malaria sensor, in *IOP Conference Series: Materials Science and Engineering*, IOP Publishing, 2021.
- 46 A. Mehaney and A. M. Ahmed, Locally resonant phononic crystals at low frequencies based on porous SiC multilayer, *Sci. Rep.*, 2019, **9**(1), 1–12.
- 47 W. Sabra, *et al.*, Numerical optimization of 1D superconductor photonic crystals pressure sensor for low temperatures applications, *Solid State Commun.*, 2022, 114671.
- 48 Q. Du, *et al.*, Gamma radiation effects in amorphous silicon and silicon nitride photonic devices, *Opt. Lett.*, 2017, **42**(3), 587–590.
- 49 W. Cai, *et al.*, Gamma-radiation effects in pure-silica-core photonic crystal fiber, *Chin. Phys. B*, 2017, **26**(11), 114211.
- 50 G. Cocorullo, *et al.*, Measurement of the thermo-optic coefficient of a-Si: H at the wavelength of 1500 nm from room temperature to 200 °C, *J. Non-Cryst. Solids*, 2002, **299**, 310–313.
- 51 M. S. S. Ibrahim, *et al.*, Highly sensitive photonic crystal gamma ray dosimeter, *Opt. Quantum Electron.*, 2021, **53**(7), 1–19.
- 52 S. El-Fiki, *et al.*, Investigation of the effect of gamma rays on optical properties of polymers, *Radiat. Phys. Chem.*, 1996, **47**(5), 761–764.
- 53 A. H. Aly and H. A. Elsayed, Defect mode properties in a one-dimensional photonic crystal, *Phys. B*, 2012, **407**(1), 120–125.
- 54 J. Canning, *et al.*, Gamma irradiation effects in photonic crystal fibre Bragg gratings, in *Australian Institute of Physics (AIP) Congress*, 2018.
- 55 H. Shen, *et al.*, One-dimensional photonic crystals: fabrication, responsiveness and emerging applications in 3D construction, *RSC Adv.*, 2016, **6**(6), 4505–4520.



- 56 L. González-García, *et al.*, Single-step fabrication process of 1-D photonic crystals coupled to nanocolumnar TiO<sub>2</sub> layers to improve DSC efficiency, *Opt. Express*, 2015, **23**(24), A1642–A1650.
- 57 M. Shaban, *et al.*, Tunability and sensing properties of plasmonic/1D photonic crystal, *Sci. Rep.*, 2017, **7**(1), 1–10.
- 58 K.-i. Fukukawa and M. Ueda, Recent progress of photosensitive polyimides, *Polym. J.*, 2008, **40**(4), 281–296.
- 59 R. Caroselli, *et al.*, Real-time and in-flow sensing using a high sensitivity porous silicon microcavity-based sensor, *Sensors*, 2017, **17**(12), 2813.
- 60 S. Lin, *et al.*, Effect of grating fabrication on radiation sensitivity of fiber Bragg gratings in gamma radiation field, *IEEE Trans. Nucl. Sci.*, 2011, **58**(4), 2111–2117.
- 61 A. Entezam, *et al.*, Thermoluminescence response of Ge-doped cylindrical-, flat-and photonic crystal silica-fibres to electron and photon radiation, *PLoS One*, 2016, **11**(5), e0153913.
- 62 V. Vendamani, *et al.*, Fabrication of porous silicon based tunable distributed Bragg reflectors by anodic etching of irradiated silicon, *Nucl. Instrum. Methods Phys. Res., Sect. B*, 2015, **358**, 105–111.
- 63 V. Robbiano, *et al.*, C-Si hybrid photonic structures by full infiltration of conjugated polymers into porous silicon rugate filters, *Nanomater. Nanotechnol.*, 2018, **8**, 1847980418788404.
- 64 M. S. S. Ibrahim, M. K. G. Hamed and M. M. El-Okr, Highly sensitive photonic crystal gamma ray dosimeter, *Opt. Quantum Electron.*, 2021, **53**, 348.

