


 Cite this: *RSC Adv.*, 2025, **15**, 19421

Study on the quantitative detection of SO_2F_2 based on spectral analysis combined with laser spectroscopy

Zhigang Cao, Bin Liu, Yinghan Xiang, Shuai Liang and Xu Guo

Accurate monitoring of insulation failure in SF_6 gas-insulated equipment is essential for ensuring power grid reliability. In the early stages of equipment failure, the characteristic decomposition product SO_2F_2 is generated. By detecting its concentration and variation, insulation defects can be identified. In this paper, SO_2F_2 detection based on laser absorption spectroscopy was studied. The infrared spectral characteristics of SO_2F_2 and its coexisting gases were analyzed. It was found that SO_2F_2 exhibits a strong absorption peak at 2763 cm^{-1} , which is not affected by interference from its coexisting gases. An ICL laser with a wavelength of 3619 nm was selected for SO_2F_2 detection. A laser absorption spectroscopy experimental platform was established to conduct quantitative research on trace levels of SO_2F_2 . The detection performance of two methods—direct absorption spectroscopy and harmonic modulation—was compared. The results demonstrate that both methods can accurately detect SO_2F_2 within the $0\text{--}600\text{ ppm}$ concentration range, with the harmonic modulation method exhibiting significantly better sensitivity and repeatability. The response to the direct absorption spectroscopy system is 0.782 mV ppm^{-1} , with a repeatability error of 2.525 ppm and a detection limit of 3.94 ppm . The harmonic modulation system shows a response of $11.433\text{ mV ppm}^{-1}$, which is about 15 times higher than that of the direct absorption spectroscopy. Its repeatability error is 0.937 ppm , which is only 0.37 times that of direct absorption spectroscopy, and the detection limit is 357.56 ppb , which is about 11 times lower than that of direct absorption spectroscopy.

Received 23rd September 2024

Accepted 17th April 2025

DOI: 10.1039/d4ra06854h

rsc.li/rsc-advances

1 Introduction

Since sulfur hexafluoride (SF_6) gas has excellent insulation and arc-extinguishing properties, SF_6 gas-insulated equipment has been widely used in power grids.^{1–4} With the rapid increase in the number of SF_6 gas-insulated devices, higher reliability standards are increasingly required. However, owing to defects in manufacturing technology, loosening of parts caused by vibration during transportation, metal scraps generated during installation, and aging during use, the equipment may develop insulation defects. These defects gradually deteriorate during long-term operation and can cause partial discharge (PD). If PD is not detected in a timely manner, it can evolve into insulation breakdown, leading to equipment failure and threatening the safety of the power grid.^{5–8} Therefore, it is of great significance to carry out research on PD detection for SF_6 gas-insulated equipment.

The PD process in SF_6 gas-insulated equipment is often accompanied by acoustic, optical, thermal, and electromagnetic radiation. Diagnostic methods based on these phenomena include the pulse current method, ultrasonic method and ultra-high frequency (UHF) method.^{9–12} However, multi-point

grounding of equipment can cause the pulse current generated by PD to shunt, resulting in a very low signal-to-noise ratio that precludes accurate detection. The ultrasonic and UHF methods have strong anti-interference capabilities, but when the PD signal propagates inside the equipment, it will produce multiple refractions due to the complexity of the internal structure, which will greatly attenuate the signal.

At present, the detection of SF_6 decomposition products has become an important technique for on-site monitoring of equipment in operation and has a significant effect on improving the defect diagnosis capabilities and operational reliability of the equipment.^{13–16} This method offers advantages of little interference from the external environment, high sensitivity, and good accuracy. Furthermore, since decomposition products increase with the number of PD times, on-site detection of these products can more effectively reflect the development of internal faults in equipment. The international standard IEC60480-2004 states that the low-fluorine sulfide produced in the early stages of SF_6 gas discharge decomposition are highly unstable, and SO_2F_2 is commonly generated during the latent period of hidden defects or early-stage defects of the equipment.¹⁷ By detecting its concentration and variation, insulation defects in equipment can be identified.^{18–20} Therefore, the research and development of detection instruments with high measurement accuracy and

State Grid Tongliao Power Supply Company, Tongliao 028000, China



good reliability for SO_2F_2 detection are key to the detection of SF_6 decomposition products. In addition, SO_2F_2 is widely used for termite control in buildings, warehouses and containers. Given its toxicity, occupational safety regulations demand highly accurate detection of SO_2F_2 .

The main methods for detecting SO_2F_2 in SF_6 decomposition products are gas chromatography and nanosensors. However, gas chromatography suffers from limitations such as complex sampling pathways, long detection times, and poor portability, making it difficult to meet the requirements for on-site detection. Alternatively, nanosensors face challenges such as easy poisoning and serious cross-interference between gases, making it difficult to accurately assess the concentration of SO_2F_2 gas during on-site application.^{21,22} Spectral detection technology leverages the unique spectral “fingerprints” of gases, allowing for the elimination of cross-interference effects, thereby achieving highly selective and sensitive detection.²³

Yassine *et al.* conducted a series of studies on the application of SO_2F_2 as a fumigant insecticide and developed a miniaturized two-chamber photoacoustic spectroscopy detection device, which achieved good results and enabled accurate detection of SO_2F_2 .^{24,25} Zhang *et al.* conducted preliminary analysis of the spectral characteristics of SO_2F_2 and proposed a relevant detection method,²⁶ but they did not conduct an in-depth analysis of the impact of spectral cross-interference between gases and did not confirm whether the method could meet the requirements of

real scenarios. In the specific scenario of SF_6 decomposition product detection, there are many gas components (such as SOF_2 , CO_2 , HF, H_2S and water vapor) within the equipment, and SF_6 as a background gas exhibits strong infrared spectral absorption.²⁷⁻³¹ Therefore, further research is needed. Through spectral analysis of various gases, the optimal detection band for SO_2F_2 can be identified, and the advantages of laser spectroscopy technology can be used to overcome the limitations of existing methods and achieve highly selective and sensitive detection of SO_2F_2 .

In summary, in this paper, in response to the urgent need for quantitative detection of SO_2F_2 , a trace gas detection method based on laser spectroscopy was studied. First, through theoretical simulation of the HITRAN database combined with Fourier transform infrared spectroscopy (FTIR) detection experiments, the infrared spectral characteristics of SO_2F_2 and its coexisting gases in a SF_6 gas-insulated equipment were obtained, the spectral cross-interference between SO_2F_2 and other gases was analyzed, and the optimal SO_2F_2 detection band and corresponding laser were determined. Subsequently, a gas concentration detection platform based on direct absorption spectroscopy and harmonic modulation methods was established, enabling high-precision detection of SO_2F_2 . Furthermore, detection performance of the two methods was compared. The findings of this study provide theoretical and technical support for the accurate detection of SO_2F_2 .




Fig. 1 The long optical path gas cell.



2 Platform and method

2.1 Gas infrared spectrum detection

In order to analyze the potential spectral overlapping and interference between multiple gas components and SO_2F_2 , it is first necessary to build a gas detection experimental platform based on long-path FTIR. Then, the infrared spectral information for SF_6 background gas and typical trace-level SF_6 decomposition products can be obtained, and the effective SO_2F_2 detection band is selected to lay the foundation for the selection of laser parameters. The long-path FTIR gas detection experimental platform is shown in Fig. 1. It mainly consists of an FTIR spectrometer (Hamamatsu Tracer-100), a long optical path gas cell (PIKE Technologies), a high-precision digital pressure gauge, a vacuum pump, and various standard gases. The gas cell is a variable-path White cell. Its optical path is composed of three reflectors (comprising two fixed mirrors and one movable mirror). The top moving mirror is connected to the top micrometer through a cylindrical positioning pin. By adjusting the top micrometer, the position of the moving mirror changes, thereby altering the number of light reflections within the cell and adjusting the optical path length. Based on experimental analysis, 8 m was selected as the optical path length. Detection experiments were carried out using trace standard gases. First, the standard gas was filled into a gas sampling bag and connected to the inlet of the gas cell. The gas cell was then evacuated. Once a vacuum state was achieved, the gas sampling bag valve was opened to fill the standard gas into the gas cell.

The gas cell is used to ensure an appropriate absorption optical path length for accurately measuring the spectral information of trace gases. The background gas and target gas at a certain concentration were filled into the gas cell to obtain the infrared spectrum of the background signal and the absorption intensity and transmittance of the target gas as a function of wavenumber.

2.2 Laser spectroscopy gas detection platform

The laser spectroscopy gas detection platform is shown in Fig. 2, which is mainly composed of three parts: the gas path, the optical path, and the electronic circuit. The gas path includes the standard gas to be tested, the gas distribution instrument, a variable-path White cell, a pressure gauge and a vacuum pump. The standard gas is diluted to various concentrations using the gas distribution instrument and then introduced into the gas cell for detection. All measurements were conducted under ambient temperature and atmospheric pressure conditions. The optical path consists of an ICL laser, the gas cell and a photodetector. The circuit includes a laser current driver and temperature controller, a signal generator, a lock-in amplifier, a data acquisition module and a host computer. During the detection process, air in the gas cell was first evacuated using the vacuum pump, followed by introducing N_2 . Then, different concentrations of the gas were prepared using the gas distribution instrument and filled then introduced into the gas cell at a flow rate of 300 mL min^{-1} . Data acquisition commenced once the system reached a steady state and the signal stabilized.




Fig. 2 The laser absorption spectroscopy gas detection platform.




The basic detection principle is as follows: when a certain concentration of SO_2F_2 gas is introduced into the gas cell, the signal generator outputs a modulation signal that enables the laser to scan across the infrared absorption peak of SO_2F_2 . Next, the interaction between the laser and the gas is increased after multiple reflections within the gas cell. Finally, the photodetector converts the transmitted optical signal into an electrical signal, which is processed by the lock-in amplifier and transmitted to the host computer for display and recording. In this study, direct absorption spectroscopy and harmonic modulation methods are employed to investigate the quantitative detection of SO_2F_2 . The detection performance of these two methods is evaluated and compared in terms of sensitivity, signal stability, and detection limit.


3 Results and discussion

3.1 Analysis of the spectral characteristics of SO_2F_2

To verify the reliability of the spectral results obtained from the experimental platform, the spectral information of SO_2F_2 from the HITRAN database was first compared with the spectral data measured using the experimental platform, and the results are shown in Fig. 3. As illustrated in Fig. 3(b), some absorption peaks appear saturated in the actual measurement, resulting in slight distortions in the waveform of the absorption peak. A comprehensive comparison of Fig. 3(a) and (b) reveals that the absorption cross-section obtained from the HITRAN database is in the same wavelength band as the absorption peak of the



(a) The SO_2F_2 absorption cross section in the HITRAN database



(b) The actual measurement results of the SO_2F_2 absorption spectrum

Fig. 3 Theoretical and experimental analysis of the SO_2F_2 infrared spectrum.

measured absorption spectrum, which confirms the reliability of the experimental platform.

3.2 Analysis of the spectral interference of SO_2F_2 and its coexisting gases

Fig. 4 presents a comparison of the absorption cross sections of SO_2F_2 and its coexisting gases (SOF_2 , HF , H_2S , H_2O , CO , and CO_2) across various spectral bands. The absorption spectrum of SOF_2 (which is not available in the HITRAN database) was obtained through experimental measurements, while the absorption cross sections of SO_2F_2 and the other coexisting gases were sourced from the HITRAN database. As shown in Fig. 4, the absorption spectrum of SO_2F_2 gas is mainly concentrated in the $1200\text{--}3000\text{ cm}^{-1}$ range. Two prominent absorption peaks are observed at 1270.1 cm^{-1} and 1503.5 cm^{-1} with no significant cross-interference from other SF_6 decomposition products.

Since SF_6 is the background gas within the equipment, its interference with the infrared spectrum of SO_2F_2 must be considered. To assess this, SF_6 absorption cross section was




Fig. 4 Spectral analysis of SO_2F_2 and its coexisting gases.




Fig. 5 Infrared absorption cross section of SO_2F_2 and SF_6 .






Fig. 6 Analysis of cross-interference of infrared absorption cross sections of SO_2F_2 and SF_6 in the $2700\text{--}2800\text{ cm}^{-1}$ region.

magnified 3000 times and compared with that of SO_2F_2 , as shown in Fig. 5. It can be observed that the absorption spectrum of SO_2F_2 at 1270.1 cm^{-1} overlaps with that of SF_6 and is effectively obscured. Although the absorption cross section at 1503.5 cm^{-1} for SO_2F_2 is very strong, it overlaps with the absorption spectrum of SF_6 .

As shown in Fig. 3, a relatively weak absorption peak of SO_2F_2 appears in the $2500\text{--}3000\text{ cm}^{-1}$ region. When this is compared with the interference spectra of various SF_6 decomposition products, it is evident that no significant interference from other gases occurs within this band. Therefore, to identify a SO_2F_2 gas detection band with minimal cross-interference, further analysis was conducted on the interference effect of SF_6 background gas in this spectral region (Fig. 6). The results reveal that SO_2F_2 exhibits a distinct absorption peak at 2763 cm^{-1} , which is largely unaffected by other coexisting gases and can thus be used as an optimal detection band.

3.3 SO_2F_2 detection laser selection

According to the above experiments and the HITRAN database analysis, as shown in Fig. 4, SO_2F_2 exhibits absorption within the $500\text{--}4500\text{ cm}^{-1}$ spectral range at the following wavenumbers: 544 cm^{-1} , 886 cm^{-1} , 1270 cm^{-1} , 1503 cm^{-1} , 1729 cm^{-1} , 2120 cm^{-1} , 2350 cm^{-1} , 2533 cm^{-1} , 2763 cm^{-1} , 3000 cm^{-1} , 3308 cm^{-1} , 3609 cm^{-1} , and 4013 cm^{-1} . Among these, the absorption bands at 544 cm^{-1} and 886 cm^{-1} require costly laser sources, making them unsuitable for practical use. The six absorption peaks at 1270 cm^{-1} , 1729 cm^{-1} , 2120 cm^{-1} , 2350 cm^{-1} , 2533 cm^{-1} , and 3000 cm^{-1} are subjected to interference from coexisting gases. The absorption peaks at 3308 cm^{-1} , 3609 cm^{-1} , and 4013 cm^{-1} are relatively weak, resulting in low signal-to-noise ratio and sensitivity, which render them unsuitable. Additionally, the absorption cross section of SO_2F_2 at 1503 cm^{-1} is significantly affected by SF_6 interference. Therefore, the absorption band at 2763 cm^{-1} (corresponding wavelength: 3619 nm) offers the best detection performance for SO_2F_2 in the presence of SF_6 decomposition products.




Fig. 7 Cross-interference between SO_2F_2 and other gases in the band around 2763 cm^{-1} (3619 nm).

This infrared spectral analysis confirms the feasibility of using laser spectroscopy for the selective and quantitative detection of SO_2F_2 in the presence of SF_6 decomposition products. Accordingly, as shown in Fig. 7, a short-wavelength mid-infrared ICL laser (Nanoplus, 3619 nm) was selected for SO_2F_2 detection in subsequent experiments.

3.4 SO_2F_2 detection based on ICL laser absorption spectroscopy

3.4.1 SO_2F_2 concentration analysis based on direct absorption spectroscopy. The laser wavelength can be tuned by adjusting the temperature and current of the laser. To ensure that the output wavelength of the ICL laser corresponds accurately to the absorption peak of SO_2F_2 gas (3619 nm), the laser wavelength tuning range was first characterized to determine the working temperature and current parameters of the laser. The working temperature range of the laser is $20\text{--}40\text{ }^\circ\text{C}$, and the current range is $40\text{--}120\text{ mA}$, within which the output wavelength spans approximately $3610\text{--}3626\text{ nm}$. The laser




Fig. 8 SO_2F_2 absorption spectra of laser at different working temperatures.



temperature was set to 25 °C, 30 °C, 35 °C, and 40 °C, and the corresponding background and absorption signals were recorded. The absorption spectra of 400 ppm SO_2F_2 obtained at different temperatures were merged, as shown in Fig. 8. It was observed that in the range of 3612–3624 nm, the experimentally measured absorption spectra were consistent with the spectral data from the FTIR platform and HITRAN database, with notably enhanced spectral resolution. The absorption peak of SO_2F_2 was found to be the strongest at 3619.3 nm. When the laser operated at 35 °C and the driving current was 40–120 mA, the laser output wavelength spanned 3615.4–3623.37 nm, fully covering the SO_2F_2 absorption peak of at 3619.3 nm.

As mentioned in the previous section, when the operating temperature of the ICL laser is maintained at 35 °C and the driving current is within the range of 40–120 mA, the laser tuning range fully covers the absorption spectrum of SO_2F_2 . The direct absorption method was employed for the experiments owing to its intuitive nature and simple system configuration. The working temperature of the ICL laser is set to 35 °C, and the center current of the current driver is set to 80 mA. A 10 Hz low-frequency sawtooth wave with a 400 mV amplitude was applied *via* the signal generator. The optical path length of the White long optical path cell was set to 8 m. The laser beam emitted by the ICL laser was collimated and directed into the gas cell, where it underwent multiple reflections. After interacting with the target gas, the transmitted beam was collected by a photodetector. A gas distribution system was used to prepare and introduce SO_2F_2 at specified concentrations into the gas cell for detection.

The average of 100 sets of data was taken as the signal value. First, the spectrum of N_2 was recorded to serve as the background spectrum. Subsequently, 600 ppm SO_2F_2 was introduced into the gas cell, and its direct absorption signal was recorded (Fig. 9). A pronounced signal depression was observed compared with the background signal. As the gas concentration decreased, this depression significantly reduced. Therefore, it can be suggested that this is the SO_2F_2 absorption signal. According to the Lambert–Beer law, taking the logarithm of the




Fig. 10 Absorption spectrum of 600 ppm SO_2F_2 after background subtraction.

ratio of the background signal to the absorption signal can eliminate background noise and yield an absorbance value containing the concentration information. Fig. 10 shows the result obtained by subtracting the background from the absorption signal presented in Fig. 9.

The gas distribution instrument was used to prepare SO_2F_2 gas mixtures at concentrations of 100 ppm, 200 ppm, 300 ppm, 400 ppm, 500 ppm and 600 ppm with N_2 as the buffer gas, and the absorbance values of SO_2F_2 at different concentrations were obtained according to the above steps of average filtering and background subtraction. Fig. 11 presents the direct absorption spectra of SO_2F_2 at six different concentrations. The experimental results demonstrate that as the SO_2F_2 gas concentration increased, the absorption intensity gradually increased, indicating a good positive correlation between gas concentration and signal intensity.

According to Fig. 11, the signal intensity amplitudes at different sampling points within the absorption spectrum at the




Fig. 9 The background gas and 600 ppm SO_2F_2 absorption signal.




Fig. 11 Direct absorption spectra of SO_2F_2 at different concentrations.







Fig. 12 Linear fitting of the direct absorption spectroscopy.

same concentration vary. To facilitate a more intuitive inversion of the SO_2F_2 concentration, the signal intensity at the absorption peak is selected for concentration estimation. The peak signal intensities corresponding to different SO_2F_2 concentrations were extracted from Fig. 11. A linear fit was performed using gas concentration as the horizontal axis and peak signal intensity as the vertical axis, as shown in Fig. 12. The resulting linear correlation coefficient (R^2) was 0.997, indicating a good linear relationship between gas concentration and signal intensity. The response of the direct absorption spectroscopy detection system was $0.782 \text{ mV ppm}^{-1}$.

Repeatability refers to the consistency of multiple measurement results for the same measured target and is a key parameter for evaluating the reliability of an instrument. The standard deviation is used to describe repeatability. A 100 ppm SO_2F_2 gas mixture was prepared, and multiple consecutive measurements were conducted using direct absorption spectroscopy. The results are shown in Table 1, with the calculated repeatability error to be 2.525 ppm.

The detection limit is a key parameter for evaluating the performance of an instrument and the sensitivity of a measurement method. The detection limit is determined on the basis of the signal-to-noise ratio, defined as the sample concentration at which the signal amplitude is k times the standard deviation of baseline noise. Generally, a signal-to-noise ratio of 3 : 1 is used, meaning the detection limit corresponds to the concentration at which the signal equals three times the noise level. The detection limit was calculated using the following equation:

$$D = 3N \times \frac{Q}{I} = 3 \frac{Q}{S_{\text{NR}}} \quad (1)$$

Fig. 13 100 ppm SO_2F_2 signal amplitude and standard deviation based on direct absorption spectroscopy.

where D is the detection limit, I is the signal response value, Q is the target gas concentration, and N is the noise.

As shown in Fig. 13, the signal amplitude and standard deviation over 20 measurement cycles for 100 ppm SO_2F_2 are presented. The peak signal is 0.09414, and the corresponding standard deviation is 0.00124, yielding a signal-to-noise ratio of 76. Based on this, the detection limit was calculated to be 3.94 ppm.

3.4.2 SO_2F_2 concentration analysis based on harmonic modulation method. In this section, the concentration of SO_2F_2 is measured using the second harmonic modulation detection method. The concentration of SO_2F_2 was determined by analyzing the second harmonic signal, and the main indicators of the detection method were evaluated. The working temperature of the ICL laser was set to 35 °C, and the current of the laser driver was set to 80 mA. The signal generator applied a 10 Hz, 200 mV low-frequency sawtooth wave on channel CH_1 and a 25 kHz, 200 mV high-frequency sine wave on channel CH_2 . The high-frequency sine signal was coupled with the low-frequency sawtooth wave. A gas distribution instrument was used to mix the SO_2F_2 of the desired concentrations and deliver the gas into the gas cell for detection.


To avoid the influence of phase drift on the detection quality, the system uses the R value (defined as the square root of the sum of the squares of the X and Y demodulated signals from the lock-in amplifier) as the concentration inversion waveform. Fig. 14(a) shows the second harmonic R value of the SO_2F_2 signal at 350 ppm, while Fig. 14(b) presents the corresponding X value.

As demonstrated in the previous section, the absorption line of SO_2F_2 near 3619 nm is not a single, well-isolated absorption


Table 1 Repeated measurement values of the direct absorption spectroscopy system

Number of measurements	1	2	3	4	5	6
Inversion concentration (ppm)	102.31	103.06	101.60	98.77	99.42	96.37





(a) Second harmonic R signal



(b) Second harmonic X signal

Fig. 14 Second harmonic signal value of 350 ppm SO_2F_2 .

line but rather a complex composite absorption band formed by the superposition of multiple absorption lines. Compared with a standard single absorption line, this composite band exhibits broader linewidth and stronger absorbance. Therefore, the second harmonic signal demodulated by the lock-in amplifier significantly differs from the typical second harmonic waveform associated with a single line. The second harmonic signal of SO_2F_2 is a superposition of the second harmonic signals corresponding to the multiple overlapping absorption lines at this wavelength region.

The second harmonic absorption spectra of SO_2F_2 at six different concentrations are shown in Fig. 15. The experimental results show that, as the SO_2F_2 concentration increased, the second harmonic signal amplitude rises, demonstrating a clear positive correlation between concentration and signal intensity.

The gas concentration and corresponding second harmonic signal peak intensity were subjected to linear fitting, as shown in Fig. 16. The linear correlation R^2 for the linear fit is 0.997, indicating an excellent linear relationship between the gas



Fig. 15 Second harmonic spectrum of SO_2F_2 at different concentrations.

Fig. 16 The linear fitting of the second harmonic method.

concentration and the second harmonic signal amplitude. The harmonic modulation detection system response was calculated to be $11.433 \text{ mV ppm}^{-1}$. The second harmonic method yielded a stronger signal intensity and the response increased by about 15 times compared with the direct absorption spectroscopy method. This is more conducive to the detection of weak signals and can effectively improve the gas detection limit.


The repeatability of the second harmonic method was calculated according to the method described in the previous section. As shown in Table 2, the calculated repeatability error was 0.937 ppm, which was only 0.37 times that of the direct absorption spectroscopy method. The calculated peak signal-to-noise ratio for 20 measurements of 100 ppm SO_2F_2 signal was 839.1, as shown in Fig. 17. Accordingly, the detection limit was calculated to be 357.56 ppb. This demonstrates detection limit was significantly reduced by about 11 times compared with the direct absorption spectroscopy method.

The above findings demonstrate that using a 3619 nm ICL laser in combination with laser absorption spectroscopy enables highly selective and sensitive quantitative detection of SO_2F_2 . Compared with traditional detection methods



Table 2 Repeated measurement values of the second harmonic system

Number of measurements	1	2	3	4	5	6
Inversion concentration (ppm)	99.74	101.03	98.97	101.42	100.86	99.23

Fig. 17 100 ppm SO_2F_2 signal amplitude and standard deviation based on the harmonic modulation method.

employing broadband light sources and optical filters, laser spectroscopy offers superior selectivity and effectively avoid interference from complex gas components in the SF_6 decomposition product detection scenario. Moreover, in contrast to the approach reported in the study by Zhang *et al.*,¹⁹ the ICL laser used in this study is more cost-effective and maintains high detection accuracy. Laser absorption spectroscopy is considered an online monitoring technology with good application potential and significant advantages in terms of portability and reliability.³² The findings of this study provide a practical and efficient solution for the online detection of abnormal gases within SF_6 gas-insulated equipment.

4 Conclusion

To enable accurate detection of trace SO_2F_2 gas within SF_6 gas-insulated equipment, this study investigated gas detection methods based on laser absorption spectroscopy, built an FTIR gas spectrum analysis platform and a laser absorption spectroscopy gas detection platform, obtained the infrared spectral characteristics of SO_2F_2 and its coexisting gases, and then selected the most suitable laser for SO_2F_2 detection. Subsequently, laser absorption spectroscopy was employed to achieve high-precision SO_2F_2 detection. The conclusions are as follows:

(1) Infrared spectral analysis of SO_2F_2 and its coexisting gases show that SO_2F_2 exhibits a strong absorption peak at 2763 cm^{-1} , which is not affected by the interference from its coexisting gases. The corresponding 3619 nm wavelength ICL laser is suitable for SO_2F_2 detection.

(2) ICL laser direct absorption spectroscopy enables accurate detection of SO_2F_2 gas. Within the concentration range of 0–

600 ppm, the gas concentration shows a good linear relationship with signal peak intensity ($R^2 = 0.997$). The system response is 0.782 mV ppm^{-1} , the repeatability error is 2.525 ppm , and the detection limit is 3.94 ppm .

(3) The ICL laser harmonic modulation method further enhances SO_2F_2 gas detection performance. In the concentration range of 0–600 ppm, a good linear relationship ($R^2 = 0.997$) is maintained between concentration and signal peak intensity. The system response is $11.433\text{ mV ppm}^{-1}$, which is about 15 times higher than that of direct absorption spectroscopy. The repeatability error is 0.937 ppm , which is only 0.37 times that of direct absorption spectroscopy. The detection limit is 357.56 ppb , which is about 11 times lower than that of direct absorption spectroscopy.

Data availability

The data supporting this article has been included as part of the article.

Conflicts of interest

There are no conflicts to declare.

References

- 1 P. Widger and A. M. Haddad, Evaluation of SF_6 leakage from gas insulated equipment on electricity networks in Great Britain, *Energies*, 2018, **11**(8), 2037.
- 2 H. Cui, X. Zhang, Z. Jun and Z. Ying, Nanomaterials-based gas sensors of SF_6 decomposed species for evaluating the operation status of high-voltage insulation devices, *High Volt.*, 2019, **4**(4), 242–258.
- 3 H. Koch, F. Goll, T. Magier, *et al.*, Technical aspects of gas insulated transmission lines and application of new insulating gases, *IEEE Trans. Dielectr. Electr. Insul.*, 2018, **25**(4), 1448–1453.
- 4 Y. Zhuang, X. Hu, B. Tang, *et al.*, Effects of SF_6 decomposition components and concentrations on the discharge faults and insulation defects in GIS equipment, *Sci. Rep.*, 2020, **10**(1), 15039.
- 5 X. Zhang, L. Yu, X. Wu and W. Hu, Experimental sensing and density functional theory study of H_2S and SOF_2 adsorption on Au-modified graphene, *Adv. Sci.*, 2015, **2**(11), 1500101.
- 6 G. Wang, H. E. Jo, S. J. Kim, *et al.*, Measurement and analysis of partial discharges in SF_6 gas under HVDC, *Measurement*, 2016, **91**, 351–359.
- 7 S. Okabe, T. Ohno, S. Yamauchi, *et al.*, Development of Gas Sensors for Detecting SF_6 Decomposition Products and Locating Faults in GIS Amperometric Solid State Ionic



Sensor, *IEEE Trans. Sensors Micromachines*, 1997, **117**(10), 526–531.

8 P. Kaur and T. Choudhury, *Early Detection of SF₆ Gas in Gas Insulated Switchgear*[C]//2016 7th India International Conference on Power Electronics (IICPE), IEEE, 2016, pp. , pp. 1–6.

9 J. Li, X. Zhang, X. Han, *et al.*, A partial discharge detection method for SF₆ insulated inverted current transformers adopting inner shield case as UHF sensor, *IEEE Trans. Power Deliv.*, 2018, **33**(6), 3237–3239.

10 A. S. Mahdi, Z. Abdul-Malek and R. N. Arshad, SF₆ decomposed component analysis for partial discharge diagnosis in GIS: A review, *IEEE Access*, 2022, **10**, 27270–27288.

11 C. Toigo, T. Vu-Cong, F. Jacquier, *et al.*, Partial discharge behavior of protrusion on high voltage conductor in GIS/GIL under high voltage direct current: Comparison of SF₆ and SF₆ alternative gases, *IEEE Trans. Dielectr. Electr. Insul.*, 2020, **27**(1), 140–147.

12 X. Han, J. Li, L. Zhang, *et al.*, A novel PD detection technique for use in GIS based on a combination of UHF and optical sensors, *IEEE Trans. Instrum. Meas.*, 2018, **68**(8), 2890–2897.

13 D. Chen, X. Zhang, H. Xiong, Y. Li, J. Tang, S. Xiao and D. Zhang, A First-Principles Study of the SF₆ Decomposed Products Adsorbed Over Defective WS₂ Monolayer as Promising Gas Sensing Device, *IEEE Trans. Device Mater. Reliab.*, 2019, **19**(3), 473–483.

14 Y. Zhang, W. Yu, D. Wang, *et al.*, Carbon monoxide detection based on the carbon nanotube-coated fiber gas sensor, *Photonics*, 2022, **9**(12), 1001.

15 X. Zhang, J. Yan, Y. Zhang, *et al.*, Infrared Spectrum Analysis and Quantitative Detection of SF₆ Characteristic Decomposition Components SO₂F₂ and SOF₂, *IEEE Trans. Dielectr. Electr. Insul.*, 2022, **29**(4), 1316–1323.

16 D. Wang, R. Zhuo, Y. Zhang, *et al.*, An All-Fiber FLRD System for SO₂ Detection Based on Graphene-Coated Microfiber, *Photonics*, 2023, **10**(8), 863.

17 IEC60480-2004, *Guidelines for the Checking and Treatment of Sulfur Hexafluoride (SF₆) Taken from Electrical Equipment and Specification for its Re-use*, 2004.

18 Y. Fu, M. Rong, K. Yang, *et al.*, Calculated rate constants of the chemical reactions involving the main byproducts SO₂F, SOF₂, SO₂F₂ of SF₆ decomposition in power equipment, *J. Phys. D: Appl. Phys.*, 2016, **49**(15), 155502.

19 X. Zhang, Z. Zhu, Y. Zhang, *et al.*, The detection of SF₆ decomposition components SO₂F₂, SOF₂ using mid-infrared TDLAS at 6.635 μm and 7.462 μm, *Vib. Spectrosc.*, 2022, **123**, 103459.

20 W. T. Tsai, The decomposition products of sulfur hexafluoride (SF₆): Reviews of environmental and health risk analysis, *J. Fluorine Chem.*, 2007, **128**(11), 1345–1352.

21 A. J. G. Fá, R. Faccio and I. López-Corral, Detection of SOF₂ and SO₂F₂ through aluminium nitride nanosheets: A DFT study, *Appl. Surf. Sci.*, 2021, **538**, 147899.

22 H. Cui, X. Zhang, J. Zhang, *et al.*, Nanomaterials-based gas sensors of SF₆ decomposed species for evaluating the operation status of high-voltage insulation devices, *High Volt.*, 2019, **4**(4), 242–258.

23 X. Zhang, Y. Zhang, J. Tang, *et al.*, Optical technology for detecting the decomposition products of SF₆: a review, *Opt. Eng.*, 2018, **57**(11), 110901.

24 H. Yassine, C. Weber, A. Eberhardt, *et al.*, Detection of SO₂F₂ Using a Photoacoustic Two-Chamber Approach, *Sensors*, 2023, **24**(1), 191.

25 H. Yassine, C. Weber, N. Brugger, *et al.*, Towards a miniaturized photoacoustic detector for the infrared spectroscopic analysis of SO₂F₂ and refrigerants, *Sensors*, 2022, **23**(1), 180.

26 X. Zhang, Z. Zhu, Y. Zhang, *et al.*, The detection of SF₆ decomposition components SO₂F₂, SOF₂ using mid-infrared TDLAS at 6.635 μm and 7.462 μm, *Vib. Spectrosc.*, 2022, **123**, 103459.

27 M. Dong, C. Zhang, M. Ren, *et al.*, Electrochemical and infrared absorption spectroscopy detection of SF₆ decomposition products, *Sensors*, 2017, **17**(11), 2627.

28 J. Tang, F. Liu, X. Zhang, *et al.*, Partial discharge recognition based on SF₆ decomposition products and support vector machine, *IET Sci. Meas. Technol.*, 2012, **6**(4), 198–204.

29 H. Yuan, X. Wang, A. Yang, *et al.*, Detection of decomposition products of SF₆/air gas mixture by electron attachment mass spectrometry, *High Volt.*, 2022, **7**(3), 536–544.

30 J. Tang, F. Zeng, X. Zhang, *et al.*, Relationship between decomposition gas ratios and partial discharge energy in GIS, and the influence of residual water and oxygen, *IEEE Trans. Dielectr. Electr. Insul.*, 2014, **21**(3), 1226–1234.

31 W. Yuanyuan, W. Ning, J. Shengchang, *et al.*, *Study on SF₆ Gas Decomposition Products of Typical GIS Defect Models by Infrared Detection*[C]//2011 1st International Conference on Electric Power Equipment-Switching Technology, IEEE, 2011, pp. 496–499.

32 M. Gu, J. Chen, Y. Zhang, *et al.*, Portable TDLAS sensor for online monitoring of CO₂ and H₂O using a miniaturized multi-pass cell, *Sensors*, 2023, **23**(4), 2072.

