

CRITICAL REVIEW

[View Article Online](#)
[View Journal](#) | [View Issue](#)



Cite this: *Environ. Sci.: Water Res. Technol.*, 2026, 12, 1062

Ammonia oxidizer adaptation to low dissolved oxygen concentrations for biological nutrient removal – a review on oxygen affinity, dual-substrate limitation, and decay

Kester McCullough, *^{ab} Charles B. Bott ^b and Peter A. Vanrolleghem ^a

Low dissolved oxygen (DO) operation in suspended growth biological nutrient removal (BNR) systems has become increasingly important for energy-efficient and intensified treatment processes. Novel strategies like continuous low DO, ammonia-based aeration control (ABAC), partial-denitrification anammox (PdNA), and partial-nitrification anammox (PNA) are becoming more commonplace and can drive processes to operate in DO regimes far below conventional norms. Yet nitrification, particularly the first step (ammonia oxidation), must be maintained. This review provides the first comprehensive overview of experimental data on ammonia oxidizer adaptation to low DO, along with analysis on how and why ammonia oxidizer oxygen kinetics respond to these low DO environments. This review examines the available evidence that stable ammonia oxidation at low DO is possible and usually corresponds to a reduction in the estimated ammonia oxidation Monod oxygen half-saturation coefficient (K_{O_2}). These changes can arise from intrinsic shifts in microbial community structure (particularly increased comammox *Nitrospira* (CMX) abundance), from extant factors like floc and microcolony size, or both. Despite evidence for these shifts, the drivers, limits, and durability of kinetic adaptation remain open questions. Also reviewed is the potential interaction of oxygen and substrate affinity, which is poorly understood and infrequently studied, especially under the non-starvation ammonia conditions common in advanced processes. This review also highlights a need to better study ammonia oxidizer decay and decay rate adaptation to low DO. Despite being critical to determining ammonia oxidizer population and thus nitrification capacity, decay kinetics under low DO remain largely unmeasured, mischaracterized, or assumed constant. Existing methods for determining decay are not well suited to capture or characterize the impacts of low DO operation. These findings suggest a necessary shift in practice: ammonia oxidation kinetic parameters, especially K_{O_2} , should not be treated as fixed parameters. SRT, DO, substrate concentration, and community structure all interact to drive nitrification performance. This review seeks to provide a comprehensive and systematic review of existing experimental results within each of these domains, with perspective on future research needs and implications for design and operation.

Received 28th August 2025,
Accepted 22nd February 2026

DOI: 10.1039/d5ew00844a

rsc.li/es-water

Water impact

Reduction in WWRF operating DO (*i.e.* low-DO treatment) allows for major energy savings and novel treatment approaches. However, low-DO processes design is still an open question, especially with respect to nitrification. This critical review examines the evidence for stable nitrification at low DO, analyzes the drivers for nitrifier kinetic change in response to low DO, and highlights future research needs.

1 Introduction

Low dissolved oxygen (DO) biological nutrient removal (BNR) processes are the subject of increasing research interest as a tool for process intensification. Operating an activated sludge process at lower DO requires less air supply thus significantly reducing energy. Additionally, novel nitrogen removal approaches like ammonia based aeration control (ABAC), or

^a ModelEAU, Département de génie civil et de génie des eaux, Université Laval, Québec, QC G1V 0A6, Canada. E-mail: kester.mccullough.1@ulaval.ca

^b Hampton Roads Sanitation District, 1434 Air Rail Avenue, Virginia Beach, VA, 23455, USA



shortcut nitrogen removal strategies like partial-denitrification anammox (PdNA) and partial-nitrification anammox (PNA) which often rely on maintaining a specific ratio of unoxidized ammonia and nitrite/nitrate (*i.e.* ammonia-versus-NO_x (AvN) control), often lead to lower bulk-liquid DO concentrations.^{1–3} In all of these scenarios, maintaining aerobic ammonia oxidation capacity is critical to maintaining high quality effluent.

To avoid losing nitrification capacity when a BNR process is transitioned to low DO, the ammonia oxidizing organisms must adapt or their population must increase. While ammonia oxidizing populations are complex and contain diverse species, broadly speaking the ammonia oxidizers, or some fraction thereof, must attain a higher affinity for oxygen to operate at similar rates in a reduced oxygen environment and thus allow the treatment process to maintain nitrogen removal capacity.

Early research into nitrification processes in wastewater treatment noted the importance of dissolved oxygen,^{4–6} and the relationship between DO concentration and ammonia oxidation activity was often conceptualized as a Monod function.^{7,8} An example set of Monod curves for two different nitrifying populations with different maximum rates and Monod oxygen half saturation coefficients (K_{O_2}) values are shown in Fig. 1 to illustrate how these kinetics impact rates. In this example only the single Monod function of oxygen is shown, thus ammonia is assumed to be non-limiting (further sections of this paper go into detail on methods for treating multiple limitations).

Stenstrom and Poduska as late as 1980, noted that "...the reported effects of DO concentration on maximum growth rate and process dynamics are varied, and not well understood".⁹ They claimed based on surveying the preceding 20 years of work from pure cultures, soil organisms, and activated sludge processes that nitrifiers were limited in their ammonia oxidation rate below DO concentrations of 1.0–2.0 mgO₂ per L, but concluded that with long enough solids retention time

(SRT) nitrification can be achieved with a DO concentration of 0.5–1.0 mgO₂ per L, and that 0.3 mgO₂ per L is the lowest DO concentration at which nitrification can be considered possible. From these and other early findings, official design guidance for nitrification within BNR processes suggested operating at a DO of 2.0 mgO₂ per L to maximize nitrification efficiency without aerating unnecessarily.¹⁰ This principle is generally recommended to this day¹¹ and even codified in design documents such as the Recommended Standards for Wastewater Facilities¹² and the EPA Manual on Nitrogen Control.¹³

While this early literature mentions variance in nitrifier oxygen kinetics and contains studies of systems that operated at what would today be considered low DO, research was also conducted on explicitly operating nitrification at lower DO to better understand how this could be reliably achieved and understood. This research can be understood in the broader framework of variability in microbial kinetics as it is treated in wastewater processes. It has been noted by multiple researchers that kinetic parameters can vary between systems and over time, and in 1996 Grady *et al.*¹⁴ proposed terminology to characterize the sources of parameter change. Kinetics were conceived of as "intrinsic" or "extant". Intrinsic kinetics were proposed to mean those to which the commonly used kinetic parameter symbols referred, but more particularly the kinetics of the underlying organism of interest, *i.e.* "If the kinetics truly reflect unrestricted growth they are representative only of the nature of the organisms and the substrate".¹⁴ Extant kinetic parameters then are the microbial kinetics as they are observed in the system, or expressed by the organism given factors like the existing or recent conditions of substrate concentrations, mixing and advection, floc or biofilm structure and size, *etc.* Fig. 2 provides a graphical summary of the extant and intrinsic factors covered in this review, namely the ammonia oxidizing community makeup (intrinsic), the microcolony size (extant), and the floc size (extant).

Indeed numerous factors impact the observed or estimated (or apparent) K_{O_2} for a given biomass on a given substrate within a given system, such as advection, diffusion, floc size and density, temperature, inhibition, substrate and enzyme concentrations, and more,¹⁵ as well as the dependence of the half-saturation coefficient on the maximum growth rate.¹⁶ Many of these phenomena are difficult to measure, however, and this study focuses on the intrinsic and extant drivers for which data are available in the literature. As a consequence of this, the challenge of transferability must also be considered in any discussion on kinetic parameter estimation. Due to the number of factors that influence observed kinetics, and the differing conditions between batch-scale tests and full-scale processes, kinetics estimated *ex situ* may not perfectly capture *in situ* kinetics.^{15,17} Better tools should be developed for *in situ* parameter estimation to better understand the topics covered herein.

For the sake of brevity and focus, NOB oxygen kinetics and their potential for adaptation are not within the scope of



Fig. 1 Two theoretical Monod functions showing ammonia oxidation rate as a function of oxygen with different maximum rates (μ_1 and μ_2) and K_{O_2} ($K_{O_2,1}$ and $K_{O_2,2}$).





Fig. 2 Potential drivers of change in observed ammonia-oxidizer oxygen affinity K_{O_2} . Intrinsic drivers reflect shifts in the ammonia-oxidizing community (toward organisms with inherently different kinetics), while extant drivers reflect physiological/operational acclimation or phenomena. These mechanisms act across different scales, from cells to aggregates/flocs.

this paper, and studies exist comparing the observed differential response to operating DO of AOB *vs.* NOB.^{18–20} The focus of the kinetic portions of this work is explicitly on the first step of nitrification, ammonia oxidation (although comammox are capable of both steps). Similarly, N_2O emission dynamics are not covered in this review. Although early studies suggested that low DO operation may increase N_2O , particularly *via* autotrophic denitrification,^{21–23} recent studies appear promising (*e.g.* Jimenez *et al.*²⁴ found that low DO adapted biomass produced more than two-fold lower N_2O emissions than high DO adapted biomass exposed to low DO in a batch test). Further investigation is warranted on the impacts of long-term, stable, low DO operation on N_2O production.

This critical analysis of the existing literature on low DO ammonia oxidation covers.

1) A review of studies wherein low DO ammonia oxidation is observed but ammonia oxidation kinetic adaptation is not explained.

2) A review of low DO nitrification studies wherein intrinsic kinetic changes are documented (for example, a different ammonia oxidizing species or strain is present).

3) A review of low DO nitrification studies wherein extant kinetic changes are documented.

4) A review of literature and concepts on the impact of single and multiple substrate limitations with respect to ammonia and oxygen for ammonia oxidation.

5) A review of literature on the decay rate of nitrifiers and how the many unknowns about decay may impact low DO nitrification.

2 Observations of ammonia oxidation adaptation to low DO

The possibility of ammonia oxidizer adaptation to low DO conditions has been observed by researchers in the past. This section provides an overview of observations of this

phenomenon, demonstrating its existence, irrespective of whether the authors of those studies attempted to justify or explain it. Subsequent sections discuss the potential intrinsic and extant causes of this phenomenon, and existing limitations in the research.

An early and influential study, Hanaki *et al.*²⁵ conducted experiments using lab-scale reactors and synthetic wastewater with and without organic carbon operating at a 0.5 mgO_2 per L DO and non-limiting DO. They estimated K_{O_2} by comparing activities between these two batches, thus assuming the ammonia oxidizers in both reactors had the same oxygen kinetics, and found a value on the lower end of what may be considered typical. They reported that the ammonia oxidizers in the nitrification culture that grew at low DO conditions apparently had a much higher yield, which was used to explain how the apparent rates in both batches differed little despite operating at high/low DO setpoints and having the same K_{O_2} . It seems likely in this experiment that potential variations in ammonia oxidizer kinetics may have been incorporated in the assumptions and resultant calculations for other kinetic parameters, and it should be noted the yield values and biomass values could not be calculated directly but only relative to the rate.²⁶ operated chemostats with nitrifiers derived from soil samples and determined that reduction in oxygen concentrations led to decreased K_{O_2} for both ammonia oxidizing bacteria (AOB) and nitrite oxidizing bacteria (NOB), but that reducing DO too far led to severely reduced nitrification rates. Park *et al.*²⁷ modified one of eight parallel trains at a full-scale UCT process to low DO operation (under 0.5 mgO_2 per L) and found that the nitrification rate in the train did not decrease and it maintained complete nitrification. Of interest in this experiment was that all of the activated sludge was recombined in the clarifiers, meaning all of the nitrifiers were continuously exposed to low and high DO conditions. Daebel *et al.*²⁸ operated two activated sludge pilot processes and determined that the K_{O_2} value of nitrifiers were time-dependent, providing evidence that these kinetics should not be treated as constants.



Liu and Wang²⁹ ran a series of lab-scale enriched nitrifier reactors at 10, 20, and 40 day SRTs across a range of DO concentrations from 0.1 to 5.0 mgO₂ per L. They fit their process data across these operating conditions to a model that included a single value for K_{O_2} for nitrifier growth (meaning adaptation *per se* was not modelled) and a separate K_{O_2} value for nitrifier decay. It was hypothesized that the K_{O_2} for decay was high enough to offset (through increased nitrifying biomass) the decrease in rate that low DO caused, as minimal loss of nitrification was seen at the low DOs.

Fan *et al.*³⁰ and Wang *et al.*³¹ both operated lab-scale reactors at high and low DO and found lower K_{O_2} for AOB at low DO conditions, the latter also identifying an increase in AOB yield coefficient. Microbial community analysis was performed and an increase in nitrifier abundance at low DO was noted, although the population composition of the genera tested did not appear to change appreciably at the two DO conditions.

Fig. 3 summarizes the findings of studies that specifically reported ammonia oxidizer K_{O_2} values at both high and low operating DO concentrations. Operating DO and ammonia oxidizer K_{O_2} values from each study are shown along with relative ammonia oxidation capacity contours (see the Fig. 3 caption for more detailed explanation). From these results, it is clear some researchers have found that ammonia oxidation capacity has been maintained or even increased as DO was reduced, but others have found a loss of relative ammonia oxidation capacity as a consequence of operating at low DO (due to insufficient adaptation). Despite varied experimental

conditions in the studies shown in this figure, ammonia oxidation K_{O_2} adaptation occurred, establishing the possibility of such adaptation. The rest of this manuscript attempts to detail the possible drivers of this adaptation; differences in adaptation may have been due to changes in floc morphology, microcolony structure, or nitrifier population (although not all of the studies included in this figure report on each of these metrics).

3 Ammonia oxidizer adaptation to low DO due to change in intrinsic kinetics

Changes to intrinsic ammonia oxidizer kinetics have been investigated primarily by looking at microbial community composition and attempting to identify shifts in the strains or species that make up the ammonia oxidizing community at high and low DO concentrations. Early work noted overall shifts in ammonia oxidizing populations that included canonical ammonia oxidizers and explored the sublineages present. Ammonia oxidizing archaea (AOA) were also the subject of investigation as they were found in multiple low DO systems. More recently, comammox were discovered and garnered significant attention due to their heretofore unknown but widespread presence in wastewater treatment processes; multiple researchers finding significant presence of these nitrifiers in low DO systems. Each of these types of population shifts (and the attendant changes in intrinsic kinetics) have been observed at low DO, but the understanding of how, why,



Fig. 3 Ammonia oxidation capacity contour plot showing relative ammonia oxidation rate for different values of operating DO and ammonia oxidizer K_{O_2} . Relative ammonia oxidation rate assumes all else is held equal and is calculated via the Monod function ($S_{O_2}/(K_{O_2} + S_{O_2})$) where S_{O_2} is the operating DO. Gray lines indicate equal-rate contours, *i.e.* all combinations of operating DO and ammonia oxidizer K_{O_2} that fall along a contour will give the same relative ammonia oxidation rate. When operating DO is reduced, ammonia oxidizer K_{O_2} must also reduce along a slope parallel the nearest line, or ammonia oxidation capacity will be different at the lower operating DO. Experimental findings where estimates of ammonia oxidizer K_{O_2} was reported at different operating DO are shown on the plot. Slopes less than the slope of surrounding contours indicate a loss of capacity, greater slopes a gain of capacity (the more significant the deviation, the greater the relative loss or gain in capacity). Studies included in this figure are only those that specifically reported both high and low operating DO values and ammonia oxidizer K_{O_2} .



and to what extent these population shifts will occur in any given low DO process is still an area of active research.

3.1. Canonical ammonia oxidizing bacteria

Ammonia oxidizing bacteria (AOB) are a broad set of chemolithotrophic bacteria capable of oxidizing ammonia to nitrite; known for over a century.³² Numerous researchers have investigated their potential to perform ammonia oxidation at low DO concentrations. Park and Noguera³³ ran two chemostats with enriched nitrifier cultures (10 day SRT) at high and low DO concentrations. It was determined that the reactors grew nitrifiers that were phylogenetically distinguishable, but both belonged to the *Nitrosomonas europaea* sublineage. The researchers claim that the modelled K_{O_2} values for the two enrichments differed, but the differences appeared quite small and the confidence intervals of the estimates overlapped. Interestingly, the determined maximum specific growth rate for the low DO culture was significantly higher than for the high DO, but this is not commented on in the work. This work also documents a full-scale experiment in which two parallel activated sludge treatment trains were maintained, one with high DO and one with low DO for 6 months. At the end of the experiment, the AOB identified in the low DO process mostly belonged to the *Nitrosomonas europaea* sublineage, while the high DO train AOB were primarily associated with *N. oligotropha*. Park and Noguera³⁴ also found that by isolating and kinetically testing two strains of AOB found in low DO nitrifying reactors that one had a high affinity for oxygen and a low affinity for ammonia (0.24 mgO₂ per L and 1.62 mgN per L respectively) and the other had a low affinity for oxygen and a high affinity for ammonia (1.22 mgO₂ per L and 0.48 mgN per L respectively). Bellucci *et al.*³⁵ ran two sets of high and low (0.5 mgO₂ per L) DO reactors on synthetic wastewater with the same SRT to demonstrate the ability of nitrifiers to grow and fully nitrify in low DO conditions. The ammonia oxidizers that grew in the low DO reactor were capable of complete ammonia removal and were estimated to have an unusually high yield. The yield was inferred from calculations where the AOB population (X_{AOB}) was determined using a combination of biomass measures assuming a specific cell size and density and cell counts from qPCR. Metagenomic techniques were also employed to determine that the ammonia oxidizing community in the low DO reactor was a subset of and contained fewer species than the ammonia oxidizing community in the high DO reactor.

3.2. Ammonia oxidizing archaea

Numerous researchers identified the potential for AOA to play a role in low DO nitrification. AOA have been noted to be successful ammonia oxidizers at extremely low DO concentrations (<0.1 mgO₂ per L).^{36,37} Measurements of intrinsic AOA K_{O_2} have been performed by multiple researchers; reported values range from 0.038–0.125 mgO₂ per L (see Table 1). These K_{O_2} values are lower than those typically estimated for canonical or mixed nitrifier communities, which range from 0.25 to >1.0 mgO₂ per L under typical operating DO.²⁰ Researchers have also found AOA present in full-scale activated sludge plants.^{38–40}

Park *et al.*⁴⁶ used PCR to measure the presence of archaeal amoA in sludge samples from five water resource recovery facilities (WRRFs) operating at long SRTs and low DO. Their results provided evidence that AOA may be common in low DO nitrifying reactors. Wells *et al.*⁴⁷ analyzed the abundance of different organisms in a full-scale WRRF and found the abundance of AOB amoA genes were strongly negatively correlated with operating DO and no correlation was found between DO and AOA amoA gene abundance. However, the plant was only operated at high DO concentrations. This was proposed as evidence that specific AOB may adapt to low DO conditions better than others (in this case *Nitrosospira*), and others have identified this possibility as well.⁴⁸ Giraldo *et al.*⁴⁹ observed that in a full-scale membrane bioreactor operated at low DO, the biomass had a very low K_{O_2} value and using qPCR identified AOA as the dominant nitrifier. Liu *et al.*⁵⁰ operated a 40 day SRT lab-scale membrane activated sludge reactor fed with synthetic wastewater at high DO (2.0 mgO₂ per L) and low DO (0.4 mgO₂ per L) and found that AOB abundance decreased while AOA abundance increased dramatically with lowering DO. The reported ratio of AOA/AOB amoA in the low DO condition was >19×. Jimenez *et al.*²⁴ conducted a survey of 13 full-scale low DO facilities and found that for plants operated below 0.5 mgO₂ per L, AOA abundance was 20% on average. Data were also provided for a single plant that transitioned from an operating DO of 2.0 mgO₂ per L to 0.3 mgO₂ per L, and AOA abundance was found to increase significantly from 9% (±6.2%) to 31% (±8.4%).

Since the development of methods to detect AOA, not all researchers experimenting with low DO nitrification have found them. Liu and Wang⁵¹ operated two bench-scale

Table 1 Estimated AOA Monod oxygen-half saturation values from the literature. Values in parenthesis are reported standard deviations

Study	Reported K_{O_2} (mgO ₂ per L)	Organism	Enrichment
Martens-Habbena <i>et al.</i> ⁴¹	0.125 (0.018)	Marine AO (<i>Ca. Nitrosopumilus maritimus</i> strain SCM1)	Pure culture
Park <i>et al.</i> ⁴²	0.064 (0.014)	Marine sediment AOA (strain AR)	Enrichment culture
Qin <i>et al.</i> ⁴³	0.109 (0.00042)	Marine AO (<i>Ca. Nitrosopumilus maritimus</i> strain SCM1)	Pure culture
Qin <i>et al.</i> ⁴³	0.038 (0.00048)	Marine AOA (strain PS0)	Pure culture
Straka <i>et al.</i> ⁴⁴	0.093 (0.016)	Freshwater AOA (strain DW and AC2)	Enrichment culture
Straka <i>et al.</i> ⁴⁴	0.090 (0.045)	Soil AOA (<i>Nitrososphaera viennensis</i>)	Pure culture
Xie <i>et al.</i> ⁴⁵	0.131 (0.08)	Activated sludge + soil AOA (<i>Nitrosocosmicus</i> sp.)	Enrichment culture



activated sludge reactors fed synthetic wastewater at 10 day and 40 day SRTs. Both reactors were operated in periods with high and low DO and no AOA were detected in either phase. Canonical AOB remained the dominant ammonia oxidizer and it was hypothesized this was due to the greatly reduced nitrifier decay rate at low DO which allowed the total population size of the nitrifiers to increase, not due to a change in K_{O_2} , yield, or growth rate. Arnaldos *et al.*⁵² ran two enriched culture sequencing-batch-reactors (SBRs) at high and low DO. AOA were not detected in either reactor but the same lineage of AOB was predominant in both; the low DO ammonia oxidizers had a lower K_{O_2} . Interestingly, the low DO nitrifying community developed enhanced expression of a heme protein within the cells, which was hypothesized to decrease the intracellular DO concentrations thus increasing the diffusive force of oxygen into the cell from the bulk liquid. Fitzgerald *et al.*⁵³ ran two lab-scale, enriched culture reactors at 10 day SRTs at DO concentrations of 0.3 mgO₂ per L or less. One of the reactors was seeded with sludge from a WRRF operating at high DO, the other from a WRRF operating at low DO. Almost no AOA were detected in either seed sludge or at the end of the experiment, demonstrating that AOA were not necessary for successful low DO nitrifier adaptation. The reactor seeded with low DO acclimated sludge began nitrifying at low DO quickly (<25 days) while the reactor seeded with high DO acclimated sludge took over 80 days to adapt and nitrify fully.

The state of the current literature on AOA as major factors in low DO nitrification is not clear, although there is no doubt remaining that AOA are capable of ammonia oxidation at very low DO concentrations and are present in some wastewater treatment plants. The earliest reports on the phenomena found both the presence⁴⁶ and absence³⁵ of AOA in low DO nitrifying reactors. Over a decade later, researchers of low DO nitrification still find conflicting results.^{50,53} The literature exploring this issue comes primarily from bench-scale reactors fed with synthetic wastewater at conditions that may differ from full-scale processes or from comparisons between samples taken from different wastewater treatment plants. At the very least, it would appear unwise from an engineering design perspective to rely upon the growth of AOA for low DO nitrification, and caution would be advised in reading too much into the measured kinetic parameters of different AOA strains as indicative of what would be expected in a full-scale WRRF. The exact conditions that cause the presence or absence of AOA in low DO processes are still not fully understood, and additional kinetic factors such as ammonia affinity and differential growth rates between and within species undoubtedly play a role.

3.3. Comammox

In 2015, a *Nitrospira* species was discovered that was capable of complete nitrification of ammonia to nitrate.^{54,55} This organism is referred to as comammox (complete ammonia oxidation) and has been of interest to researchers given its potential favorable kinetics for low DO, lower N₂O emissions,⁵⁶ and prevalence within nitrification processes despite being previously unrecognized. Different comammox (CMX) strains and clades have been identified, and they have been found in a diversity of activated sludge processes^{57–62} and even drinking water systems⁶³ around the world. It has been suggested that CMX have low maximum ammonia rate and high growth yield.⁶⁴ This is particularly interesting because for the past 30 years some researchers reported that nitrifiers had high yield when adapted to low DO (see Section 3.1). Recently attempts have been made to characterize the intrinsic K_{O_2} of these organisms (Table 2); both studies found CMX to have extremely high oxygen affinity ($K_{O_2} < 0.02$ mgO₂ per L).

Camejo *et al.*⁵⁸ operated an 80 day SRT SBR fed synthetic wastewater and seeded with biomass from a full-scale process. Oxygen concentrations were kept low (<0.5 mgO₂ per L) and significant CMX abundance was noted (very little AOA were identified). During a second phase of the experiment, still at low DO, CMX abundance dropped to near zero but full nitrification was maintained; no other known AOB or AOA were detected in this second phase and the authors speculated the presence of still-unrecognized ammonia oxidizing organisms. Roots *et al.*⁶⁷ operated an intermittently aerated SBR using real wastewater for influent. DO setpoints were kept at 1.0 mgO₂ per L or lower and complete nitrification was achieved; the process performed better than the full-scale high DO nitrification reactor at the facility from which the raw influent was taken, which was used as a control. After significant time operating at reduced DO, CMX composed >90% of ammonia oxidizers (measured by amoA) in the reactor. It should be noted the reactor was run with a very long SRT (99 days). Beach and Noguera⁶⁸ pointed out some potential issues with qPCR primers in use at the time with detecting CMX and designed three new primers for some candidate CMX species; they found CMX present in the majority of samples analyzed from low DO systems, none in the high DO systems, and noted that the largest abundance was found in systems with long SRTs. How *et al.*⁶⁰ operated a lab-scale nitrifying SBR fed real wastewater at a DO concentration of 1.7 mgO₂ per L and then 0.9 mgO₂ per L with a 20 day SRT and consistently achieved full nitrification. CMX were found to be the dominant nitrifiers throughout the experiment. Wen *et al.*²⁰ reported on a full-scale membrane bioreactor (MBR) process that transitioned from relatively low

Table 2 Estimated CMX Monod oxygen-half saturation values from the extant literature. Values in parenthesis are reported 95% confidence intervals

Study	Reported K_{O_2} (mgO ₂ per L)	Organism and enrichment
Hou <i>et al.</i> ⁶⁵	0.006 (0.001)	<i>Ca. Nitrospira nitrosa</i> -dominant enriched sludge
Zhu <i>et al.</i> ⁶⁶	0.017 (0.002)	" <i>Nitrospira</i> -dominant" sludge (comammox enrichment)



(0.8 mgO₂ per L) to even lower (0.5 mgO₂ per L) operation at an 18 day SRT. Complete nitrification was maintained at both DO setpoints, and the already relatively low determined K_{O_2} of AOB (0.23 mgO₂ per L) decreased further to 0.19 mgO₂ per L (although the error of these parameter estimates is not reported in the study, and it is possible these two values are not significantly different). *Nitrospira* were detected as the main nitrifying organism during the study, and it was speculated that these could be comammox or another unknown AOB. Li *et al.*⁶⁹ operated two bench-scale MBRs at high and low DO, 2.0 mgO₂ per L and 0.5 mgO₂ per L respectively, and found that while both were capable of full nitrification, the high DO reactor ammonia removal was more consistent. CMX was found to be the dominant nitrifier in both reactors, particularly in the low DO reactor (the CMX/AOB amoA ratio was >17). Jimenez *et al.*²⁴ found in their low DO survey that for full-scale plants operated below 0.5 mgO₂ per L, CMX abundance was 66% on average. In the same study, a single plant was monitored before and after transition from an operating DO of 2.0 mgO₂ per L to 0.3 mgO₂ per L; CMX abundance was found to increase significantly from 11% (±4.7%) to 60.5% (±10.9%). Two recent studies have attempted comammox enrichment for the purpose of kinetic estimation. Hou *et al.*⁶⁵ attempted to enrich *Candidatus Nitrospira nitrosa* under low DO conditions and succeed in increasing its prevalence 26.5 fold; the results of their subsequent kinetic measurements are shown in Table 2. Zhu *et al.*⁶⁶ comparatively enriched *Nitrospira*-dominant (comammox) and *Nitrosomonas*-dominant floccular sludges and also reported a lower apparent oxygen affinity constant for the *Nitrospira*-dominant sludge, which are reported in Table 2.

Two studies have discussed the potential for only certain clades of CMX to be preferentially selected by low DO. Zheng *et al.*⁷⁰ cultivated activated sludge samples in lab-scale reactors fed only ammonia with different DO concentrations ranging from 0.5–17 mgO₂ per L. CMX were found to be the majority nitrifiers in each reactor and in the lowest oxygen reactor were enriched significantly beyond the predominance found in the seed sludge. AOB and AOA were also detected, but at much lower levels (making up 10% or less of the nitrifying population as measured by 16 s rRNA gene abundance). The majority of CMX in the low DO reactors was made up of a CMX strain from clade A, although they noted a different clade A strain appeared to be more prevalent at higher DO. Sabba *et al.*⁶² noted increased comammox abundance in a low DO process (10–12 day SRT) and a high DO process (12–14 day SRT), and found no comammox at another high DO facility (8.5 day SRT). The low DO facility had a very low estimated K_{O_2} for nitrifiers (0.05 mgO₂ per L) but this estimate was made using DO measurements that only went down to 0.25 mgO₂ per L and CMX clade A and clade B were present. Both high DO facilities had higher estimated K_{O_2} for nitrifiers (0.5 mgO₂ per L at both) and one had CMX clade A present. Thus, it was suggested that the ability of CMX to grow at low DO and provide complete nitrification may not be a feature of the species, but only of specific strains.

Two early studies on CMX in nitrification processes operated reactors at quite long SRTs,^{58,67} and other researchers have noted that CMX may be more prevalent or require long SRT systems.⁵⁹ However, more recent full-scale low DO studies have found CMX in abundance in relatively shorter (<15 day) SRT systems,⁶² including its consistent presence in over a dozen full-scale low DO facilities with SRTs ranging from 4.5–18.2 days.²⁴ It appears, then, that long SRT is not a requirement for low DO CMX. Much is also left to learn about potential differences within CMX strains, and why some experiments appear to show CMX predominance at both low and high DO concentrations. As CMX may not be particular to low DO, the understanding of their role and presence in engineered systems is currently not enough to design around.

It does not appear that any low DO activated sludge studies, since the discovery of CMX and development of primers to detect it, have failed to detect CMX (although Liu *et al.*⁵⁰ found it to be only a very small fraction); this may in fact be evidence against its particular significance to engineering design. If the organism is so ubiquitous, especially at low DO, then no special steps may be necessary to grow it. If it can be shown to have measurably different in-process kinetics, this still may not necessitate a focus on the organism itself for design (unlike the case of other novel organisms like anammox), only that those different kinetics are used for design purposes.

To provide a clear picture of the current low DO knowledge landscape, studies where both high and low DO operation were documented, and estimated ammonia oxidizer K_{O_2} values were provided for both, are shown in Table 3. The nitrifier population information, if provided, is also summarized therein.

4 Ammonia oxidizer adaptation to low DO due to change in extant kinetics

The second category of changes to the kinetics relevant to ammonia oxidizer low DO adaptation is change in the extant, or observed, kinetics. Extant kinetics may include anything not considered in the intrinsic kinetics of the organisms; for nitrifiers this has often been advection and diffusion limiting mechanisms, such as the floc size (in a suspended growth system) and more recently the microcolony size and number (within the floc). Both of these factors have been found relevant to nitrifier oxygen kinetics, and are thus of interest when considering adaptation to low DO.

4.1. Floc size

Based on a general understanding of advection and diffusion, floc size (and the related field of biofilm formation/thickness) have long been of interest to wastewater process researchers. Early on Beccari *et al.*⁷² demonstrated an empirical relationship between K_{NH} and measured floc size. Beccari *et al.*⁷³ then developed an early model to demonstrate that floc size



Table 3 Overview of ammonia oxidizer kinetic outcomes from studies that specifically reported both operating DO and estimated ammonia oxidizer K_{O_2} values for high and low operating DO values. Standard deviations are reported, where present, as provided by original study authors

Study	Processes	Operating DO (mgO ₂ per L)		Estimated K_{O_2} (mgO ₂ per L)		Same biomass ^a	Comment
		High	Low	High	Low		
Sabba <i>et al.</i> ⁶²	Full-scale BNR	5.00	0.71	0.50	0.05	N	No AOA detected. CMX clade A found at high DO, CMX clade A + clade B found at low DO
Wang <i>et al.</i> ³¹	Lab-scale BNR	2.00	0.50	0.39 ± 0.05	0.29 ± 0.04	Y	Slightly higher canonical AOB and <i>Nitrospira</i> abundance at low DO
Wen <i>et al.</i> ²⁰	Full-scale MBR	0.80	0.30	0.23	0.19	Y	No AOA detected. <i>Nitrospira</i> was the only known nitrifier detected
Keene <i>et al.</i> ⁷¹	Full-scale BNR + pilot BNR	1.80	0.33	1.38 ± 0.23	0.30 ± 0.14	N	No AOA detected. Overall nitrifier population diverged between high and low DO processes
Fan <i>et al.</i> ³⁰	Lab-scale BNR	1.00	0.50	0.54 ± 0.09	0.14 ± 0.02	Y	—
Liu and Wang ²⁹	Lab-scale BNR	4.2	0.16	0.71	0.39	Y	—
Jimenez <i>et al.</i> ²⁴	Full-scale BNR (A/O)	2.0	0.3	0.5	0.2	Y	Increase in AOA and CMX abundance, details provided in text

^a “Same biomass” indicates whether a study compared the behavior of a single biomass in a process at different operating conditions (Y), or two different biomasses from two different processes (N), where operating conditions, process configurations, and influent characteristics may differ.

significantly impacted nitrifier oxygen kinetics, and validated this model with experimental data. Their steady-state model assumed uniform biomass distribution with fixed intrinsic kinetic parameters in a spherical floc with negligible external diffusional resistance (essentially no boundary layer). Experimental data to validate the model came from batch tests run with non-limiting ammonia concentrations and low TSS concentrations (very high F/M) wherein DO was increased to non-limiting conditions and modelled as it dropped to zero; floc sizes were measured with a particle size analyzer. They found that at particle size diameters $\leq 40 \mu\text{m}$ the internal diffusion resistances can be neglected, but at larger diameters (common in wastewater treatment) and especially at low DO the impact of floc size becomes pronounced: larger internal diffusion resistance will lead to higher apparent measurements of K_{O_2} .

Chu *et al.*⁷⁴ conducted measurements of heterotrophic K_{O_2} in a respirometer at various mixing energies (mean energy dissipation rate). They found that decreased mixing energies led to larger floc diameters and much higher K_{O_2} value below a minimal threshold. It should be noted, however, that mixing energy can affect both floc size and advection, and this study does not attempt to differentiate these impacts separately. Manser *et al.*⁷⁵ operated an MBR and a conventional activated sludge (CAS) pilot plant to develop and measure the oxygen kinetics of small (80 μm) and large (300–500 μm) floc systems respectively (both at 20 day SRT with non-limiting DO concentrations). Floc size was measured using a laser light scattering device. A model was developed similar to Beccari *et al.*⁷³ except that a boundary layer was included and the floc biomass was heterogenous – nitrifiers were assumed to be concentrated in the interior of the floc and heterotrophs were distributed uniformly throughout. The experimental and modelling results demonstrated that AOB, NOB, and OHO K_{O_2} values were estimated to be 2–3 times higher in the process with larger

floc sizes, and this difference could be reasonably well explained with their floc model. Daigger *et al.*⁷⁶ used DO microprobes to actually measure the DO concentration within individual flocs, providing direct evidence of what had previously been speculated and modelled to occur. Wu *et al.*⁷⁷ used sonication to break apart flocs and achieve different floc sizes. They found that the measured K_{O_2} of AOB increased from $\sim 0.20 \text{ mgO}_2 \text{ per L}$ at 50 μm average floc diameter to $\sim 1.25 \text{ mgO}_2 \text{ per L}$ at 450 μm average floc diameter. However, the NOB K_{O_2} was found to be less sensitive to floc diameter. The lower NOB K_{O_2} observed in this study was explained by their 1-D diffusion model, but the authors speculate microcolony structure (discussed in the next section) plays an important role as well. Keene *et al.*⁷¹ demonstrated that their low DO pilot process ($< 0.33 \text{ mgO}_2 \text{ per L}$) had smaller floc sizes compared with the control high DO full-scale process (152 μm vs. 117 μm , measured *via* image analysis). Ammonia oxidizers in the low DO pilot had a lower measured K_{O_2} as well (0.30 $\text{mgO}_2 \text{ per L}$ vs. 1.38 $\text{mgO}_2 \text{ per L}$). Based on the previously published models and experimental data, Keene *et al.*⁷¹ finding such a large difference in K_{O_2} with such a small difference mean floc diameter may well be evidence against floc size necessarily being a major driver of K_{O_2} in these systems. Yu *et al.*⁷⁸ explored AOB/NOB kinetic competition but in the process of doing so reported estimated AOB K_{O_2} values at varying floc sizes. Data from these studies, as well as those on the impact of microcolony size on nitrifier K_{O_2} , are summarized in Fig. 4. This figure shows the overall positive correlation, and even similar slopes found amongst some researchers, between floc size and nitrifier K_{O_2} across a wide range of particle sizes.

Floc size may significantly influence ammonia oxidizer K_{O_2} , and is itself influenced by process operational conditions. SRT in particular has been observed to play a role in floc size. Hocaoglu *et al.*⁷⁹ found a reduction in floc size at






Fig. 4 Reported ammonia oxidizer K_{O_2} values for differing floc sizes and microcolony sizes as reported in the literature.

reduced SRT (60 days to 20 days) in an MBR along with lower model-estimated K_{O_2} values. Li and Stenstrom⁸⁰ also documented a positive relationship between SRT and floc size in a lab-scale MLE, lab-scale IFAS, as well as with full-scale data.

4.2. Microcolonies

In addition to floc size, what occurs within the floc may determine observed K_{O_2} , just as much, if not more. While this field of research is much newer, there has been significant research interest in the impacts of nitrifier microcolonies, or cell clusters, within flocs. Manser *et al.*⁸¹ ran an MBR and CAS pilot in parallel and found using metagenomic techniques no significant difference in nitrifying population. They found that the MBR system not only lead to smaller floc sizes, but to smaller AOB microcolony sizes as well. Picioreanu *et al.*⁸² constructed a 3D model of AOB and NOB microcolonies within flocs at different sizes and used this to analyze the data previously collected by Manser *et al.*⁸¹ They demonstrated with this model that larger microcolonies, like larger flocs, lead to higher observed K_{O_2} values. They claim the impact of colony size is more significant than the impact of floc size, but this significance is itself contingent upon numerous additional variables (biomass concentration, number of colonies, uniformity of colony size, *etc.*). Picioreanu *et al.*⁸² also claimed that in general longer SRT could lead to larger microcolonies, mirroring the relationship with floc size. Thus, longer SRTs may lead to higher extant K_{O_2} values, if microcolony size is in-fact a dominant driving force in the phenomena.

Keene *et al.*⁷¹ observed, along with the reduction in floc size mentioned previously, a reduction in AOB colony size at low DO. This reduction (40%) was larger than the noted reduction in floc size (20%). Either or both of these

reductions are posited to have contributed to the lower observed K_{O_2} of nitrifiers at low DO. Law *et al.*¹⁹ in a study on AOB *vs.* NOB kinetic selection *via* DO concentration changes, demonstrated that AOB and NOB expressed very different microcolony structures. They suggest, among other things, that apparent half-saturation values may be a function of microcolony shape and porosity, not merely microcolony diameter, adding an additional layer of complexity to the claims of Picioreanu *et al.*⁸²

5 Single and multiple substrate limitations in the context of ammonia and oxygen limitation of ammonia oxidation

The majority of work on low DO nitrification processes has been done on systems that achieve, or seek to achieve, complete ammonia oxidation. However, novel processes such as ammonia based aeration control (ABAC), partial-denitrification anammox (PdNA), and partial-nitritation anammox (PNA) and their various implementations are designed to perform incomplete aerobic nitrification, leaving an appreciable ammonia concentration throughout the nitrification process. For the anammox processes, ammonia is not oxidized completely in the aerobic process so that anaerobic ammonia oxidation may occur. These processes have been an area of intense research for the past few years, and full-scale implementations have been achieved.^{83,84} The drivers for PdNA and PNA are reduced external carbon demand for denitrification, reduced oxygen demand for aerobic ammonia oxidation, and reduced supplemental alkalinity design. These processes can also realize significant capacity savings, as maximum available aerobic SRT for nitrification generally determines the capacity of a BNR



steady state operation across a range of DO setpoints and fit a model to the reactors' effluent NH_x vs. DO. This model assumed two separate, but constant, K_{O_2} for growth rate and decay rate (each a single Monod function). This model form, in disallowing for adaptation (different K_{O_2} at different DO setpoint), forces the variability across the DO operating conditions to be a function of decay difference, and the model fits are very dependent on very small differences in effluent ammonia. Further, this work also suggested that the nitrifiers do adapt and different K_{O_2} values were measured using batch-tests from the highest and lowest DO reactors. However, the authors do not attempt to reconcile these two methods, and no attempt is made to separately batch-test measure the decay rate or K_{O_2} for the decay rate.

Mehrani *et al.*¹⁰¹ proposed a lower value for comammox decay rate than conventional nitrifiers but did not provide a literature source for this value. As far as can be determined, no explicit considerations for decay rate have been proposed for AOA.

Methods used to measure decay generally follow the same format: a reactor of sludge is aerated for many days and samples are taken from this reactor at intervals and the maximum nitrification rate is measured.¹⁰² The decline in this maximum nitrification rate over time is an indicator of the decay rate. It should be noted, then, that this method to measure decay rate is subject to the problems of transferability as well, and here to a large degree as the conditions in the decay reactor will differ widely from those the organisms ever experience in the treatment process. There are no commonly accepted alternatives to measure this parameter. There are shorter-duration, but still *ex situ*, methods for measuring maximum specific growth rate and decay simultaneously, but these require assumptions about one or the other value and do not get around the transferability problem.

Melcer *et al.*¹⁰³ performed a comprehensive evaluation of many kinetic estimation methods including nitrifier decay rate. They note that estimated decay rates in the literature have not only varied widely, but varied with time as different methods for measuring decay were popular during different decades. Experimental methods for determining maximum specific growth rate will be more or less sensitive to decay rates depending on the SRT of the experiment. A new modelling approach to estimate decay was developed by this group, taking into account the ammonia released by heterotrophic death-lysis-hydrolysis in the decay reactor. This method requires regularly measuring the nitrate concentration in the decay reactor but can impact the calculated nitrifier decay value by almost 50%. If this is the case, this would call into question many of the nitrifier decay rate estimates published before this paper, as this method was novel when introduced. Pruden *et al.*¹⁰⁴ provide the most comprehensive recent analysis of nitrifier decay rate measurements in which decay rate measurements were performed using typical methods and DNA measurement methods. Using the method of Melcer *et al.*¹⁰³ they found

similar values of nitrifier decay rates. However, it was noted in their work that considering the ammonia production in the decay reactor from heterotrophic decay made almost no difference to the estimated decay rate, in stark contrast with Melcer *et al.*¹⁰³ They also noted considered variability in nitrifier activity measurements (more so AOB than NOB) across hundreds of tests at various times and temperatures, noting that many outlier values had to be discarded (and different decay values were estimated, depending on which values were taken to be outliers). Importantly, the AOB decay rate estimated using DNA measures was 50% less than the AOB decay rate estimated by loss of nitrification activity.

The potential for nitrifier dormancy rather than true decay should also be considered. Because decay is typically inferred from a loss of measured nitrification activity, it can be difficult to distinguish inactivity from biomass loss. Dormancy is generally viewed as reversible, but the timescale for reactivation is not well defined. Comparative measurements of dormancy *versus* decay are also limited. For example, AOB can maintain abundance while showing significantly reduced amoA expression during cold-temperature nitrification failure.¹⁰⁵ Johnston *et al.*¹⁰⁶ found that AOB and AOA could be revived after two months of starvation, long after AOB amoA dropped below detection limits. Pruden *et al.*¹⁰⁴ note that molecular detection does not confirm viability, while culture-based counts can underestimate viable cells (*e.g.*, sublethal injury can yield nonculturable but still viable cells). Friedrich *et al.*¹⁰⁷ also suggested that differential DNA marker *versus* activity decay rates may be due to dormancy.

For consideration in design, it is likely that decay rates and their kinetics play a role in low DO nitrification and adaptation, but to what extent is not easily demonstrated. Decay rate is a critical kinetic as it determines the population (X_{NITRO}) of nitrifiers in a process at a given load and SRT, and the nitrifier population and maximum specific growth rate together determine the maximum ammonia uptake rate of the process, which governs capacity. It is also well established that nitrifier decay rates depend on oxygen concentrations (at the very least, they are quite different between anoxic and aerobic conditions). Given a model structure where decay rates vary as a function of DO it would be difficult to determine whether nitrifiers at low DO have lower decay rates *per se* (intrinsic kinetics) or they are merely kinetically limited due to operating DO (extant kinetics) and would be harder still to determine if this decay kinetic factor is itself altered by operating DO concentration (K_{O_2} -decay is itself adapting). A discussion of extant and intrinsic decay kinetics and decay kinetic adaptation with respect to nitrifiers and oxygen appears to be absent from the literature.

Current decay rate values, and their associated oxygen kinetics, despite being one of the most important factors affecting nitrifier population and therefore nitrification capacity, should be met with some skepticism as:

- 1) It is not clear whether decay oxygen kinetics should share the same K_{O_2} value as growth rate, and if not, how it should be measured.



3) No attempt has been made to understand decay adaptation to low DO and what proportion is extant or intrinsic.

3) No explicit measures of decay rates at low DO exist, only extrapolations from high DO decay or anoxic decay.

4) Decay rates in the existing literature may have been measured without taking into account ammonia release from heterotroph decay, but reports vary significantly on whether this matters.

5) AOB decay rate is much more variable than NOB decay rate even when measured using the best methods available, but it is not clear why.

6) AOB decay does not align with death (measured *via* DNA destruction) implying some kind of dormancy may occur, and measured decay rates may only reflect an immediate effect on nitrification capacity.

7) Current measures of decay are *ex situ* methods that differ drastically from extant, in-process conditions.

7 Conclusions

This critical review has surveyed the literature on low dissolved oxygen ammonia oxidation with regard to understanding the mechanisms by which ammonia oxidizer communities adapt to low dissolved oxygen conditions. The evidence demonstrates that stable ammonia oxidation at low DO is achievable in activated sludge systems and consistently correlates with reduced apparent ammonia oxidizer K_{O_2} values. Studies spanning laboratory reactors to full-scale wastewater treatment plants have documented successful ammonia oxidation at DO concentrations well below the conventional 2.0 mgO₂ per L threshold.

Although early studies noted the possibility for ammonia oxidizer adaptation to low DO conditions, in the intervening decades enough data has been gathered to lay out a more concrete understanding of this phenomenon. The mechanisms underlying this adaptation can be characterized as belonging to two different pathways, although they lie along a spectrum: intrinsic and extant changes; the available data on these mechanisms has been presented in this study.

Intrinsic kinetic adaptation involves shifts in the ammonia-oxidizing community toward organisms with higher oxygen affinity. Both AOA and CMX have been shown to have very high oxygen affinity, and both have been documented in low DO systems. In fact, every low DO nitrification study that has looked for CMX has found them. Work on improving CMX detection method accuracy is ongoing; further information on CMX primer development and specificity for detecting clade A and clade B can be found in.^{108–110} The predominance of these organisms with lower intrinsic K_{O_2} would suggest lower observed K_{O_2} in these systems, which the published research demonstrates.

Extant kinetic adaptation encompasses a broad category of physical and structural changes that affect the apparent oxygen affinity of the biomass without necessarily changing the underlying microbial community. Significant data with

respect to ammonia oxidation and operating DO has been gathered for two of these factors: floc size and microcolony size. Multiple studies have demonstrated a link between floc size and apparent K_{O_2} as well as microcolony size and K_{O_2} . Increased floc size leads to higher apparent K_{O_2} , most likely through an increase of diffusional resistance against DO entering the floc.

It remains unclear how intrinsic (community) shifts and extant (mass-transfer/structure) effects interact *in situ*, largely because almost no studies reporting reduced apparent K_{O_2} concurrently quantified floc or microcolony structure. The limited available evidence (one study) suggests that intrinsic shifts can be the dominant driver. In the only study that paired oxygen-kinetics shifts with detailed community characterization, a substantial decrease in apparent K_{O_2} coincided with a marked nitrifier community shift (including increased CMX) while floc size changed little, implying that extant changes were not necessary to explain the observed kinetic improvement.⁷¹ More broadly, even if unmeasured floc or microcolony changes occurred in other studies, the consistent magnitude and direction of apparent K_{O_2} reductions across systems indicates that any concurrent extant effects were not sufficient to overwhelm the net shift toward higher apparent oxygen affinity observed under sustained low-DO operation.

The pathway to low DO ammonia oxidation, and thus increased potential for process intensification is then: changing operating conditions (lower DO) places enough selective pressure on ammonia oxidizers to generate a community shift over time, which eventually lowers the apparent K_{O_2} and allows for maintaining a substantial fraction of ammonia removal capacity at the reduced operating DO. The timeline for implementing this is not well established; Jimenez *et al.*,²⁴ surveying over a dozen full-scale low DO facilities, reported that approximately 20 days was needed for full acclimation. It was also reported that the facilities in the study also did not need to increase their SRT to accommodate reduced ammonia removal rates, meaning capacity was maintained as well.

This critical review also surveyed the literature on additional important considerations for ammonia oxidation at low DO. 1) Higher available substrate (ammonia) concentration, a feature in advanced processes like ABAC or those with downstream anammox like PNA or PdNA, may have a significant impact on apparent ammonia oxidizer kinetics, but little research has addressed this explicitly. 2) Significant open questions remain for the impact of oxygen on ammonia oxidizer decay rates, which are critical for process design and kinetic estimation or modelling. 3) Ammonia oxidizer decay rates are likely impacted by operation at low DO and are critical for predicting nitrification capacity, but they are difficult to measure and kinetically parameterize due to problems of methodological accuracy and transferability; numerous open questions remain.

For designers, owners, and operators, process intensification is an important and attainable goal. But these novel processes typically demand operation at DOs outside the typical ranges, and the limits of current knowledge and process design are



tested. This is compounded as these operating conditions significantly impact and interact with each other, but the state-of-knowledge must be advanced, as these processes need to be designed, built, and operated. Kinetic adaptation is real, although questions remain about the durability of these shifts, but it is not sufficient to assume static ammonia oxidation kinetics, especially with respect to oxygen. Delineating the intrinsic and extant nature of these shifts provides some evidence about this, but significant work remains to be done. Future work must also resolve outstanding questions around decay kinetics and substrate interactions, especially in systems with residual ammonia concentrations, to better predict system capacity and resilience under low DO conditions.

Conflicts of interest

The authors declare that they have no known competing financial interests or personal relationships that could have appeared to influence the work reported.

Data availability

No primary research results, software or code have been included and no new data were generated or analysed as part of this review.

Acknowledgements

This work was supported in-part by the NSERC Discovery Grant RGPIN-2021-04347 'Towards digital twin-based control of water resource recovery facilities – Methods supporting the use of adaptive hybrid digital twins'.

References

- 1 P. Regmi, B. Sturm, D. Hiripitiyage, N. Keller, S. Murthy and J. Jimenez, Combining continuous flow aerobic granulation using an external selector and carbon-efficient nutrient removal with AvN control in a full-scale simultaneous nitrification-denitrification process, *Water Res.*, 2022, **210**, 117991.
- 2 P. Regmi, M. W. Miller, B. Holgate, R. Bunce, H. Park, K. Chandran, B. Wett, S. Murthy and C. B. Bott, Control of aeration, aerobic SRT and COD input for mainstream nitritation/denitritation, *Water Res.*, 2014, **57**, 162–171.
- 3 L. Rieger, I. Takács and H. Siegrist, Improving nutrient removal while reducing energy use at three swiss WWTPs using advanced control, *Water Environ. Res.*, 2012, **84**, 170–188.
- 4 E. Arderm and W. T. Lockett, Experiments on the oxidation of sewage without the aid of filters, *J. Soc. Chem. Ind., London*, 1914, **33**, 523–539.
- 5 S. Rideal, The aeration test for sewage effluents, *Analyst*, 1901, **26**, 197–202.
- 6 S. Rideal, The purification of sewage by bacteria, *J. R. Soc. Arts*, 1897, **46**, 81–90.
- 7 G. Knowles, A. L. Downing and M. J. Barrett, Determination of kinetic constants for nitrifying bacteria in mixed culture,

- with the aid of an electronic computer, *Microbiology*, 1965, **38**, 263–278.
- 8 B. A. Southgate, *Water Pollution Research*, Water Pollution Research Board, H. M. Stationery Office, London, UK, 1963.
- 9 M. K. Stenstrom and R. A. Poduska, The effect of dissolved oxygen concentration on nitrification, *Water Res.*, 1980, **14**, 643–649.
- 10 D. S. Parker, *Process Design Manual for Nitrogen Control*, U.S. Environmental Protection Agency, Technology Transfer, Washington, DC, USA, 1975.
- 11 C. P. L. Grady, G. T. Daigger and N. G. Love, *Biological Wastewater Treatment*, IWA Publishing, London, UK, 2011.
- 12 *Recommended standards for wastewater facilities*, Albany, N. Y, 2014.
- 13 O. K. Scheible, M. Mulbarger, P. Sutton, T. Simpkin, G. Daigger, J. Heidman, M. Yoder, D. Schwinn and D. Storrier, *Process design manual: Nitrogen control*, U.S. Environmental Protection Agency, Office of Research and Development, Center for Environmental Research Information, Risk Reduction Engineering Laboratory; Office of Water, Office of Wastewater Enforcement and Compliance, Washington, DC, USA, EPA/625/R-93/010, 1993.
- 14 C. P. L. Grady, B. F. Smets and D. S. Barbeau, Variability in kinetic parameter estimates: A review of possible causes and a proposed terminology, *Water Res.*, 1996, **30**, 742–748.
- 15 M. Arnaldos, Y. Amerlinck, U. Rehman, T. Maere, S. Van Hoey, W. Naessens and I. Nopens, From the affinity constant to the half-saturation index: Understanding conventional modeling concepts in novel wastewater treatment processes, *Water Res.*, 2015, **70**, 458–470.
- 16 A. Shaw, I. Takács, K. R. Pagilla and S. Murthy, A new approach to assess the dependency of extant half-saturation coefficients on maximum process rates and estimate intrinsic coefficients, *Water Res.*, 2013, **47**, 5986–5994.
- 17 I. B. Petersen, *PhD Thesis*, Ghent University, Belgium, 2000.
- 18 R. Blackburne, Z. Yuan and J. Keller, Partial nitrification to nitrite using low dissolved oxygen concentration as the main selection factor, *Biodegradation*, 2008, **19**, 303–312.
- 19 Y. Law, A. Matysik, X. Chen, S. Swa Thi, T. Q. Ngoc Nguyen, G. Qiu, G. Natarajan, R. B. H. Williams, B.-J. Ni, T. W. Seviour and S. Wuertz, High dissolved oxygen selection against *Nitrospira* sublineage in full-scale activated sludge, *Environ. Sci. Technol.*, 2019, **53**, 8157–8166.
- 20 J. Wen, M. W. LeChevallier and W. Tao, Nitrification kinetics and microbial communities of activated sludge as a full-scale membrane bioreactor plant transitioned to low dissolved oxygen operation, *J. Cleaner Prod.*, 2020, **252**, 119872.
- 21 T. J. Goreau, W. A. Kaplan, S. C. Wofsy, M. B. McElroy, F. W. Valois and S. W. Watson, Production of NO₂- and N₂O by nitrifying bacteria at reduced concentrations of oxygen, *Appl. Environ. Microbiol.*, 1980, **40**, 526–532.
- 22 R. A. Kester, W. De Boer and H. J. Laanbroek, Production of NO and N₂O by pure cultures of nitrifying and denitrifying bacteria during changes in aeration, *Appl. Environ. Microbiol.*, 1997, **63**, 3872–3877.



- 23 G. Tallec, J. Garnier, G. Billen and M. Gossiaux, Nitrous oxide emissions from denitrifying activated sludge of urban wastewater treatment plants, under anoxia and low oxygenation, *Bioresour. Technol.*, 2008, **99**, 2200–2209.
- 24 J. Jimenez, K. Bauhs, M. Miller, P. Dold, A. Al-Omari, M. Garrido, D. Hiripitiyage, M. Wittman, G. Burger, K. Chandran and B. Sturm, Low dissolved oxygen nitrification through kinetic selection, *Water Res.*, 2025, 124642.
- 25 K. Hanaki, C. Wantawin and S. Ohgaki, Nitrification at low levels of dissolved oxygen with and without organic loading in a suspended-growth reactor, *Water Res.*, 1990, **24**, 297–302.
- 26 H. J. Laanbroek and S. Gerards, Competition for limiting amounts of oxygen between *Nitrosomonas europaea* and *Nitrobacter winogradskyi* grown in mixed continuous cultures, *Arch. Microbiol.*, 1993, **159**, 453–459.
- 27 H.-D. Park, L.-M. Whang, S. R. Reusser and D. R. Noguera, Taking advantage of aerated-anoxic operation in a full-scale University of Cape Town process, *Water Environ. Res.*, 2006, **78**, 637–642.
- 28 H. Daebel, R. Manser and W. Gujer, Exploring temporal variations of oxygen saturation constants of nitrifying bacteria, *Water Res.*, 2007, **41**, 1094–1102.
- 29 G. Liu and J. Wang, Quantifying the chronic effect of low DO on the nitrification process, *Chemosphere*, 2015, **141**, 19–25.
- 30 H. Fan, L. Qi, G. Liu, Y. Zhang, Q. Fan and H. Wang, Aeration optimization through operation at low dissolved oxygen concentrations: Evaluation of oxygen mass transfer dynamics in different activated sludge systems, *J. Environ. Sci.*, 2017, **55**, 224–235.
- 31 L. Wang, B. Li, Y. Li and J. Wang, Enhanced biological nitrogen removal under low dissolved oxygen in an anaerobic-anoxic-oxic system: Kinetics, stoichiometry and microbial community, *Chemosphere*, 2021, **263**, 128184.
- 32 S. Winogradsky, Recherches sur les organismes de la nitrification, *Ann. Inst. Pasteur*, 1890, **4**, 213–331.
- 33 H.-D. Park and D. R. Noguera, Evaluating the effect of dissolved oxygen on ammonia-oxidizing bacterial communities in activated sludge, *Water Res.*, 2004, **38**, 3275–3286.
- 34 H.-D. Park and D. R. Noguera, Characterization of two ammonia-oxidizing bacteria isolated from reactors operated with low dissolved oxygen concentrations, *J. Appl. Microbiol.*, 2007, **102**, 1401–1417.
- 35 M. Bellucci, I. D. Ofițeru, D. W. Graham, I. M. Head and T. P. Curtis, Low-dissolved-oxygen nitrifying systems exploit ammonia-oxidizing bacteria with unusually high yields, *Appl. Environ. Microbiol.*, 2011, **77**, 7787–7796.
- 36 M. J. L. Coolen, B. Abbas, J. van Bleijswijk, E. C. Hopmans, M. M. M. Kuypers, S. G. Wakeham and J. S. Sinninghe Damsté, Putative ammonia-oxidizing Crenarchaeota in suboxic waters of the Black Sea: A basin-wide ecological study using 16S ribosomal and functional genes and membrane lipids, *Environ. Microbiol.*, 2007, **9**, 1001–1016.
- 37 C. A. Francis, K. J. Roberts, J. M. Beman, A. E. Santoro and B. B. Oakley, Ubiquity and diversity of ammonia-oxidizing archaea in water columns and sediments of the ocean, *Proc. Natl. Acad. Sci. U. S. A.*, 2005, **102**, 14683–14688.
- 38 T. Limpiyakorn, Y. Shinohara, F. Kurisu and O. Yagi, Communities of ammonia-oxidizing bacteria in activated sludge of various sewage treatment plants in Tokyo, *FEMS Microbiol. Ecol.*, 2005, **54**, 205–217.
- 39 T. Zhang, T. Jin, Q. Yan, M. Shao, G. Wells, C. Criddle and H. H. P. Fang, Occurrence of ammonia-oxidizing Archaea in activated sludges of a laboratory scale reactor and two wastewater treatment plants, *J. Appl. Microbiol.*, 2009, **107**, 970–977.
- 40 N. Sinthusith, A. Terada, M. Hahn, P. (Lek) Noophan, J. Munakata-Marr and L. A. Figueroa, Identification and quantification of bacteria and archaea responsible for ammonia oxidation in different activated sludge of full-scale wastewater treatment plants, *J. Environ. Sci. Health, Part A: Toxic/Hazard. Subst. Environ. Eng.*, 2015, **50**, 169–175.
- 41 W. Martens-Habbena, P. M. Berube, H. Urakawa, J. R. de la Torre and D. A. Stahl, Ammonia oxidation kinetics determine niche separation of nitrifying Archaea and Bacteria, *Nature*, 2009, **461**, 976–979.
- 42 B.-J. Park, S.-J. Park, D.-N. Yoon, S. Schouten, J. S. S. Damsté and S.-K. Rhee, Cultivation of autotrophic ammonia-oxidizing archaea from marine sediments in coculture with sulfur-oxidizing bacteria, *Appl. Environ. Microbiol.*, 2010, **76**, 7575–7587.
- 43 W. Qin, K. A. Meinhardt, J. W. Moffett, A. H. Devol, E. V. Armbrust, A. E. Ingalls and D. A. Stahl, Influence of oxygen availability on the activities of ammonia-oxidizing archaea, *Environ. Microbiol. Rep.*, 2017, **9**, 250–256.
- 44 L. L. Straka, K. A. Meinhardt, A. Bollmann, D. A. Stahl and M.-K. H. Winkler, Affinity informs environmental cooperation between ammonia-oxidizing archaea (AOA) and anaerobic ammonia-oxidizing (Anammox) bacteria, *ISME J.*, 2019, **13**, 1997–2004.
- 45 J. Xie, J. Yan, H. He, D. Lin, Y. Chen, Y. Li, X. Huang and H. Zhang, Evaluation of the key factors to dominate aerobic ammonia-oxidizing archaea in wastewater treatment plant, *Int. Biodeterior. Biodegrad.*, 2021, **164**, 105289.
- 46 H.-D. Park, G. F. Wells, H. Bae, C. S. Criddle and C. A. Francis, Occurrence of ammonia-oxidizing archaea in wastewater treatment plant bioreactors, *Appl. Environ. Microbiol.*, 2006, **72**, 5643–5647.
- 47 G. F. Wells, H.-D. Park, C.-H. Yeung, B. Eggleston, C. A. Francis and C. S. Criddle, Ammonia-oxidizing communities in a highly aerated full-scale activated sludge bioreactor: betaproteobacterial dynamics and low relative abundance of Crenarchaea, *Environ. Microbiol.*, 2009, **11**, 2310–2328.
- 48 H.-D. Park, J. M. Regan and D. R. Noguera, Molecular analysis of ammonia-oxidizing bacterial populations in aerated-anoxic orbital processes, *Water Sci. Technol.*, 2002, **46**, 273–280.
- 49 E. Giraldo, P. Jjemba, Y. Liu and S. Muthukrishnan, Ammonia oxidizing archaea, AOA, population and kinetic changes in a full scale simultaneous nitrogen and phosphorous removal mbr, *Proc. Water Environ. Fed.*, 2011, **2011**, 3156–3168.



- 50 G. Liu, X. Wu, D. Li, L. Jiang, J. Huang and L. Zhuang, Long-term low dissolved oxygen operation decreases N₂O emissions in the activated sludge process, *Environ. Sci. Technol.*, 2021, **55**, 6975–6983.
- 51 G. Liu and J. Wang, Long-term low DO enriches and shifts nitrifier community in activated sludge, *Environ. Sci. Technol.*, 2013, **47**, 5109–5117.
- 52 M. Arnaldos, S. A. Kunkel, B. C. Stark and K. R. Pagilla, Enhanced heme protein expression by ammonia-oxidizing communities acclimated to low dissolved oxygen conditions, *Appl. Microbiol. Biotechnol.*, 2013, **97**, 10211–10221.
- 53 C. M. Fitzgerald, P. Camejo, J. Z. Oshlag and D. R. Noguera, Ammonia-oxidizing microbial communities in reactors with efficient nitrification at low-dissolved oxygen, *Water Res.*, 2015, **70**, 38–51.
- 54 H. Daims, E. V. Lebedeva, P. Pjevac, P. Han, C. Herbold, M. Albertsen, N. Jehmlich, M. Palatinszky, J. Vierheilig, A. Bulaev, R. H. Kirkegaard, M. von Bergen, T. Rattei, B. Bendinger, P. H. Nielsen and M. Wagner, Complete nitrification by *Nitrospira* bacteria, *Nature*, 2015, **528**, 504–509.
- 55 M. A. H. J. van Kessel, D. R. Speth, M. Albertsen, P. H. Nielsen, H. J. M. Op den Camp, B. Kartal, M. S. M. Jetten and S. Lücker, Complete nitrification by a single microorganism, *Nature*, 2015, **528**, 555–559.
- 56 F. Sabba, A. Terada, G. Wells, B. F. Smets and R. Nerenberg, Nitrous oxide emissions from biofilm processes for wastewater treatment, *Appl. Microbiol. Biotechnol.*, 2018, **102**, 9815–9829.
- 57 M. K. Annavajhala, V. Kapoor, J. Santo-Domingo and K. Chandran, Comammox functionality identified in diverse engineered biological wastewater treatment systems, *Environ. Sci. Technol. Lett.*, 2018, **5**, 110–116.
- 58 P. Y. Camejo, J. S. Domingo, K. D. McMahon and D. R. Noguera, Genome-enabled insights into the ecophysiology of the comammox bacterium “*Candidatus Nitrospira nitrosa*”, *mSystems*, 2017, e00059-17.
- 59 I. Cotto, Z. Dai, L. Huo, C. L. Anderson, K. J. Vilardi, U. Ijaz, W. Khunjar, C. Wilson, H. De Clippeleir, K. Gilmore, E. Bailey and A. J. Pinto, Long solids retention times and attached growth phase favor prevalence of comammox bacteria in nitrogen removal systems, *Water Res.*, 2020, **169**, 115268.
- 60 S. W. How, A. S. M. Chua, G. C. Ngoh, T. Nittami and T. P. Curtis, Enhanced nitrogen removal in an anoxic-oxic-anoxic process treating low COD/N tropical wastewater: Low-dissolved oxygen nitrification and utilization of slowly-biodegradable COD for denitrification, *Sci. Total Environ.*, 2019, **693**, 133526.
- 61 N. R. Maddela, Z. Gan, Y. Meng, F. Fan and F. Meng, Occurrence and roles of comammox bacteria in water and wastewater treatment systems: A critical review, *Engineering*, 2022, **17**, 196–206.
- 62 F. Sabba, E. Redmond, C. Ruff, M. Ramirez, M. Young, M. J. Song, S. Yoon and L. Downing, Exploring community and kinetic shifts in nitrifying microbial communities in low dissolved oxygen activated sludge facilities for energy-efficient biological nitrogen removal, *ACS ES&T Water*, 2024, **4**, 707–718.
- 63 A. J. Pinto, D. N. Marcus, U. Z. Ijaz, Q. M. Bautista-de Iose Santos, G. J. Dick and L. Raskin, Metagenomic evidence for the presence of comammox *Nitrospira*-like bacteria in a drinking water system, *mSphere*, 2015, e00054-15.
- 64 K. D. Kits, C. J. Sedlacek, E. V. Lebedeva, P. Han, A. Bulaev, P. Pjevac, A. Daebeler, S. Romano, M. Albertsen, L. Y. Stein, H. Daims and M. Wagner, Kinetic analysis of a complete nitrifier reveals an oligotrophic lifestyle, *Nature*, 2017, **549**, 269–272.
- 65 J. Hou, Y. Zhu, Y. Shi, L. Lin, F. Meng, M. Xu, L. Yang, B.-J. Ni and X. Chen, Enrichment and Kinetic Profiling of *Candidatus Nitrospira nitrosa* Culture Reveal Mechanisms Underlying Its Prevalence in Wastewater Treatment Systems, *Environ. Sci. Technol.*, 2025, **59**, 15272–15281.
- 66 Y. Zhu, J. Hou, F. Meng, M. Xu, L. Lin, L. Yang and X. Chen, Comparative enrichment of complete ammonium oxidation bacteria in floccular sludge reactors: Sequencing batch reactor vs. continuous stirred tank reactor, *Water Res.*, 2025, **27**, 100305.
- 67 P. Roots, Y. Wang, A. F. Rosenthal, J. S. Griffin, F. Sabba, M. Petrovich, F. Yang, J. A. Kozak, H. Zhang and G. F. Wells, Comammox *Nitrospira* are the dominant ammonia oxidizers in a mainstream low dissolved oxygen nitrification reactor, *Water Res.*, 2019, **157**, 396–405.
- 68 N. K. Beach and D. R. Noguera, Design and assessment of species-level qPCR primers targeting comammox, *Front. Microbiol.*, 2019, **10**, 36.
- 69 D. Li, F. Fang and G. Liu, Efficient nitrification and low-level N₂O emission in a weakly acidic bioreactor at low dissolved-oxygen levels are due to comammox, *Appl. Environ. Microbiol.*, 2021, **87**, e00154-21.
- 70 M. Zheng, G. Mu, A. Zhang, J. Wang, F. Chang, J. Niu, X. Wang, T. Gao and Z. Zhao, Predominance of comammox bacteria among ammonia oxidizers under low dissolved oxygen condition, *Chemosphere*, 2022, **308**, 136436.
- 71 N. A. Keene, S. R. Reusser, M. J. Scarborough, A. L. Grooms, M. Seib, J. Santo Domingo and D. R. Noguera, Pilot plant demonstration of stable and efficient high rate biological nutrient removal with low dissolved oxygen conditions, *Water Res.*, 2017, **121**, 72–85.
- 72 M. Beccari, M. Franzini and R. Ramadori, in *Proc. Int. Workshop on Advanced Biological Processes*, National Research Council Rome, Italy, 1985, pp. 28–30.
- 73 M. Beccari, A. C. D. Pinto, R. Ramadori and M. C. Tomei, Effects of dissolved oxygen and diffusion resistances on nitrification kinetics, *Water Res.*, 1992, **26**, 1099–1104.
- 74 K. H. Chu, H. M. van Veldhuizen and M. C. M. van Loosdrecht, Respirometric measurement of kinetic parameters: Effect of activated sludge floc size, *Water Sci. Technol.*, 2003, **48**, 61–68.
- 75 R. Manser, W. Gujer and H. Siegrist, Consequences of mass transfer effects on the kinetics of nitrifiers, *Water Res.*, 2005, **39**, 4633–4642.



- 76 G. T. Daigger, C. D. Adams and H. K. Steller, Diffusion of oxygen through activated sludge flocs: Experimental measurement, modeling, and implications for simultaneous nitrification and denitrification, *Water Environ. Res.*, 2007, **79**, 375–387.
- 77 J. Wu, Y. Li and M. Zhang, Activated sludge floc morphology and nitrifier enrichment can explain the conflicting reports on the oxygen half-saturation index for ammonium oxidizing bacteria (AOB) and nitrite oxidizing bacteria (NOB), *J. Chem. Technol. Biotechnol.*, 2017, **92**, 2673–2682.
- 78 L. Yu, S. Chen, W. Chen and J. Wu, Experimental investigation and mathematical modeling of the competition among the fast-growing “r-strategists” and the slow-growing “K-strategists” ammonium-oxidizing bacteria and nitrite-oxidizing bacteria in nitrification, *Sci. Total Environ.*, 2020, **702**, 135049.
- 79 S. M. Hocaoglu, G. Insel, E. U. Cokgor and D. Orhon, Effect of low dissolved oxygen on simultaneous nitrification and denitrification in a membrane bioreactor treating black water, *Bioresour. Technol.*, 2011, **102**, 4333–4340.
- 80 Z. Li and M. K. Stenstrom, Impacts of SRT on particle size distribution and reactor performance in activated sludge processes, *Water Environ. Res.*, 2018, **90**, 48–56.
- 81 R. Manser, W. Gujer and H. Siegrist, Membrane bioreactor versus conventional activated sludge system: Population dynamics of nitrifiers, *Water Sci. Technol.*, 2005, **52**, 417–425.
- 82 C. Picioreanu, J. Pérez and M. C. M. van Loosdrecht, Impact of cell cluster size on apparent half-saturation coefficients for oxygen in nitrifying sludge and biofilms, *Water Res.*, 2016, **106**, 371–382.
- 83 M. Bachmann, C. Lawrence, N. Wiczorek, T. Scott, E. Shelton, B. Elliott, M. Parsons, S. Klaus and C. Bott, Full-scale implementation of partial denitrification-anammox in IFAS processes: Cost savings and operational strategies, *Water Environ. Res.*, 2025, **97**, e70093.
- 84 R. Fofana, M. Parsons, C. Long, K. Chandran, K. Jones, S. Klaus, B. Trovato, C. Wilson, H. De Clippeleir and C. Bott, Full-scale transition from denitrification to partial denitrification-anammox (PdNA) in deep-bed filters: Operational strategies for and benefits of PdNA implementation, *Water Environ. Res.*, 2022, **94**, e10727.
- 85 K. McCullough, S. Klaus, M. Parsons, C. Wilson and C. B. Bott, Advancing the understanding of mainstream shortcut nitrogen removal: Resource efficiency, carbon redirection, and plant capacity, *Environ. Sci.: Water Res. Technol.*, 2022, **8**, 2398–2410.
- 86 R. D. Megee, J. F. Drake, A. G. Fredrickson and H. M. Tsuchiya, Studies in intermicrobial symbiosis. *Saccharomyces cerevisiae* and *Lactobacillus casei*, *Can. J. Microbiol.*, 1972, **18**, 1733–1742.
- 87 F. G. Bader, Analysis of double-substrate limited growth, *Biotechnol. Bioeng.*, 1978, **20**, 183–202.
- 88 H. R. Bungay, Growth rate expressions for two substrates one of which is inhibitory, *J. Biotechnol.*, 1994, **34**, 97–100.
- 89 T. Mankad and H. R. Bungay, Model for microbial growth with more than one limiting nutrient, *J. Biotechnol.*, 1988, **7**, 161–166.
- 90 H. A. Stewart, A. Al-Omari, C. Bott, H. De Clippeleir, C. Su, I. Takacs, B. Wett, A. Massoudieh and S. Murthy, Dual substrate limitation modeling and implications for mainstream deammonification, *Water Res.*, 2017, **116**, 95–105.
- 91 J. Geets, N. Boon and W. Verstraete, Strategies of aerobic ammonia-oxidizing bacteria for coping with nutrient and oxygen fluctuations, *FEMS Microbiol. Ecol.*, 2006, **58**, 1–13.
- 92 J. H. Ahn, R. Yu and K. Chandran, Distinctive microbial ecology and biokinetics of autotrophic ammonia and nitrite oxidation in a partial nitrification bioreactor, *Biotechnol. Bioeng.*, 2008, **100**, 1078–1087.
- 93 T. Limpiyakorn, M. Fürhacker, R. Haberl, T. Chodanon, P. Srithep and P. Sonthiphand, amoA-encoding archaea in wastewater treatment plants: A review, *Appl. Microbiol. Biotechnol.*, 2013, **97**, 1425–1439.
- 94 T. Limpiyakorn, P. Sonthiphand, C. Rongsayamanont and C. Polprasert, Abundance of amoA genes of ammonia-oxidizing archaea and bacteria in activated sludge of full-scale wastewater treatment plants, *Bioresour. Technol.*, 2011, **102**, 3694–3701.
- 95 R. Manser, W. Gujer and H. Siegrist, Decay processes of nitrifying bacteria in biological wastewater treatment systems, *Water Res.*, 2006, **40**, 2416–2426.
- 96 H. Siegrist, I. Brunner, G. Koch and L. C. Phan, Reduction of biomass decay rate under anoxic and anaerobic conditions, *Water Sci. Technol.*, 1999, **39**, 129–137.
- 97 E. J. T. M. Leenen, A. A. Boogert, A. A. M. van Lammeren, J. Tramper and R. H. Wijffels, Dynamics of artificially immobilized *Nitrosomonas europaea*: Effect of biomass decay, *Biotechnol. Bioeng.*, 1997, **55**, 630–641.
- 98 M. Henze, W. Gujer, T. Mino and M. C. M. van Loosdrecht, *Activated Sludge Models ASM1, ASM2, ASM2d and ASM3*, IWA Publishing, London, UK, 2000.
- 99 G. Munz, C. Lubello and J. A. Oleszkiewicz, Modeling the decay of ammonium oxidizing bacteria, *Water Res.*, 2011, **45**, 557–564.
- 100 O. Nowak, K. Svardal and P. Schweighofer, The dynamic behaviour of nitrifying activated sludge systems influenced by inhibiting wastewater compounds, *Water Sci. Technol.*, 1995, **31**, 115–124.
- 101 M.-J. Mehrani, X. Lu, P. Kowal, D. Sobotka and J. Mąkinia, Incorporation of the complete ammonia oxidation (comammox) process for modeling nitrification in suspended growth wastewater treatment systems, *J. Environ. Manage.*, 2021, **297**, 113223.
- 102 B. Petersen, K. V. Gernaey, M. Henze and P. A. Vanrolleghem, in *Biotechnology for the Environment: Wastewater Treatment and Modeling, Waste Gas Handling*, ed. S. N. Agathos and W. Reineke, Kluwer Academic Publishers, Dordrecht, The Netherlands, 2003, pp. 101–186.
- 103 *Methods for wastewater characterization in activated sludge modeling*, ed. H. Melcer, P. Dold, R. M. Jones, C. M. Bye, I. Takacs, H. D. Stensel, A. W. Wilson, P. Sun and S. Bury,



